

Transformer neutral jumper bus bar must be relocated for alternate voltages.

2-Voltage Output option is shown here with 400VAC and 208VAC as alternate voltages.

Other PDU and monitoring configuration changes are required as part of the voltage reconfiguration.

36" clearance in the rear OR  
36" on both sides of the PDU is required  
to perform reconfiguration.

