

Point Name

Event Date-Time Stamp

Dot indicator is always red with a yellow exclamation point for alarms; the corresponding point in the digital or analog points screen will also show a red indicator.

Reset clears all alarms in the log.

Alarms			
Point Name	Event	Event Date-Time Stamp	
Input 2 MCSw	Open	Fri Aug 22 2014 13:54:58.104	
SAS 1 S2	Unavailable	Fri Aug 22 2014 13:54:57.182	
SAS 2 S2	Unavailable	Fri Aug 22 2014 13:54:57.182	
SAS 3 S2	Unavailable	Fri Aug 22 2014 13:54:57.182	
Summary	Alarm	Fri Aug 22 2014 13:54:57.182	
Low S 2 Volts AB		Fri Aug 22 2014 13:54:56.616	
Low S 2 Volts BC		Fri Aug 22 2014 13:54:56.616	
Low S 2 Volts CA		Fri Aug 22 2014 13:54:56.616	

Change in point causing alarm

Reset

Home Alarms Log Plots Analog Digital Switch More ▶