When there are active alarms, the central panel in screens headers is **red** (**orange** if only warnings present).

When there are no active alarms, the central panel in screens headers is **green**

| POWER DISTRIBUTION INC. | ⚠ | Alarms: 4 Warnings: 1 Zeros: 0 | 🔔 🏠 ⚙ ❓ | 4/13/2018 08:41 AM guest |

**Active Alarm 1 to 5 of 5**

| Alarm | Name | Alert | Eastern Daylight Time |
|-------|---------|-------------------|----------------------------|
| 1 | Panel 1 | CT1 Warning | Fri, Apr 13, 2018, 5:00 AM |
| 2 | System | Communication Loss | Fri, Apr 13, 2018, 12:26 AM |
| 3 | Panel 2 | Ia High | Fri, Apr 13, 2018, 12:18 AM |
| 4 | Panel 2 | Ib High | Fri, Apr 13, 2018, 12:18 AM |
| 5 | Panel 2 | Ic High | Fri, Apr 13, 2018, 12:18 AM |

Touch the central header on any screen to display the **Active Alarm** screen.

| POWER DISTRIBUTION INC. | ✓ OK | 🔔 🏠 ⚙ ❓ | 4/17/2018 01:47 PM Admin |

**Latched Alarm 1 to 13 of 13**

| Alarm | Name | Alert | Eastern Daylight Time |
|-------|-------------|------------------|-----------------------------|
| 1 | Input | Van Low | Tue, Apr 17, 2018, 11:54 AM |
| 2 | Input | Vcn Low | Tue, Apr 17, 2018, 11:54 AM |
| 3 | Input | Vbn Low | Tue, Apr 17, 2018, 11:54 AM |
| 4 | Transformer | Thermal Over Temp | Tue, Apr 17, 2018, 11:52 AM |
| 5 | Transformer | Input CB Aux | Tue, Apr 17, 2018, 11:51 AM |
| 6 | Input | Frequency Low | Mon, Apr 16, 2018, 1:02 AM |
| 7 | Output | Frequency Low | Mon, Apr 16, 2018, 1:02 AM |
| 8 | Output | Vbc Low | Mon, Apr 16, 2018, 1:02 AM |
| 9 | Output | Vca Low | Mon, Apr 16, 2018, 1:02 AM |
| 10 | Output | Vcn Low | Mon, Apr 16, 2018, 1:02 AM |
| 11 | Output | Vbn Low | Mon, Apr 16, 2018, 1:02 AM |
| 12 | Output | Vcn Low | Mon, Apr 16, 2018, 1:02 AM |
| 13 | Output | Vab Low | Mon, Apr 16, 2018, 1:02 AM |

Cleared alarms are retained on **Latched Alarms** screen, until cleared.

| POWER DISTRIBUTION INC. | ✓ OK | 🏠 ⚙ ❓ | 4/17/2018 02:54 PM guest |

**Log events 1 to 23 of 100**

| Log | Source | Event | Action | Eastern Daylight Time |
|-----|-------------|-------------------|---------------|-----------------------------|
| 1 | Output | Vca Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 2 | Input | Frequency Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 3 | Input | Van Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 4 | Output | Frequency Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 5 | Input | Vcn Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 6 | Output | Vbn Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 7 | Output | Van Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 8 | Input | Vbn Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 9 | Output | Vbc Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 10 | Output | Vab Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 11 | Transformer | Input CB Aux | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 12 | Transformer | Thermal Over Temp | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 13 | Input | Vcn Low | Alarm Cleared | Tue, Apr 17, 2018, 2:11 PM |
| 14 | 172.18.*.69 | USER: Admin | Log In | Tue, Apr 17, 2018, 11:54 AM |
| 15 | 172.18.*.69 | USER: Admin | Log in | Tue, Apr 17, 2018, 1:35 PM |
| 16 | Input | Vcn Low | Alarm Cleared | Tue, Apr 17, 2018, 11:54 AM |
| 17 | Input | Vcn Low | New Alarm | Tue, Apr 17, 2018, 11:54 AM |
| 18 | Input | Vbn Low | Alarm Cleared | Tue, Apr 17, 2018, 11:54 AM |
| 19 | Input | Vbn Low | Alarm Cleared | Tue, Apr 17, 2018, 11:54 AM |
| 20 | Input | Van Low | Alarm Cleared | Tue, Apr 17, 2018, 11:54 AM |
| 21 | Input | Vcn Low | New Alarm | Tue, Apr 17, 2018, 11:54 AM |
| 22 | Input | Vbn Low | New Alarm | Tue, Apr 17, 2018, 11:54 AM |
| 23 | Input | Van Low | New Alarm | Tue, Apr 17, 2018, 11:54 AM |

Cleared alarms are also retained on the **Log** screen, until cleared.