



PowerHub 2 PDU  
Monitoring  
Compartment



PDU is shipped with  
jumper installed in  
terminal block **TB8**.

**One-Stage SKRU key  
release:**  
The jumper in **TB8** keeps  
external permissive signal  
permanently **CLOSED** or  
**ENABLED**.

**Two-Stage SKRU key  
release:**  
Remove jumper in **TB8**.  
Connect **NO** dry contact.  
Closing the dry contact  
enables the ColorMonitor  
synch and SKRU key release  
process.