

(4) 2/0 cables (**ABCN**) with compression lugs are already attached to the input of the Retrofit Bypass Cabinet RPP Switch.

(1) #2 AWG **Ground** cable is coiled and attached to the Output (Busway) ground bus in the Retrofit Bypass Cabinet.

The cables are pre-cut to the correct length.

