





- 1. ALL ELECTRICAL WORKS HEREIN SHALL BE DONE IN ACCORDANCE WITH THE LATEST PROVISION OF THE PEC. LOCAL ORDINANCES OF THE CITY OF BAGUIO AND ALL THE REQUIREMENTS OF THE BENECO.
- 2. THE ELECTRIC SERVICE VOLTAGE OF THE BUILDING SHALL BE 220 VOLTS, SINGLE PHASE, 60 HERTZ SYSTEM.
- 3. ALL ELECTRICAL MATERIALS TO BE USED SHALL BE BRAND NEW AND OF THE APPROVED TYPE FOR LOCATION AND PURPOSE INTENDED
- 4. MINIMUM SIZE OF WIRE SHALL BE 2.0 mm2 THHN WIRE AND THE MINIMUM SIZE OF CONDUIT SHALL BE 15 mm DIA UNLESS SPECIFIED
- 5. ALL BRANCH CIRCUITS SHALL NOT EXCEED 80% OF ITS RATING







NTS

GENERAL NOTES

EE