International Paper – Riverdale Mill
601 County Road 78
Selma, AL 36702-8311
Phone: 334-872-3481

February 20, 2026

RECEIVED
FEB 26 2026
ADEM AIR DIVISION

Mr. Aubrey White, Chief
Air Division
Alabama Department of Environmental Management
1400 Coliseum Boulevard
Montgomery, AL 36110-2400

Re: 2025 Source Obligation Report for No. 2 Bark Boiler Equipment Replacement Project
International Paper – Riverdale Mill
Permit No. 104-0003

Dear Mr. White:

International Paper (IP) owns and operates a Kraft pulp and paper mill in Selma, Alabama (Riverdale Mill, or Mill). The Mill is submitting this source obligation report pursuant to Alabama Department of Environmental Management's (ADEM) response to the No. 2 Bark Boiler Grate Replacement project (Project) application. The source obligation report (Attachment 1 to this letter) details emissions of nitrogen oxides (NO_X) from January 2025 through December 2025 for the Project in accordance with Alabama Administrative Code (A.A.C.) r. 335-3-14-.04(17)(e)(4).

The notification submitted to ADEM in August 2022 serves as the pre-construction documentation required by A.A.C. r. 335-3-14-.04(17)(e)(1) and (2). The Mill maintains a copy of this notification in its files. The No. 2 Bark Boiler Grate was replaced during the No. 2 Bark Boiler outage in 2023. The No. 2 Bark Boiler commenced post-project regular operation after the outage, which initiated the 5-year tracking for NO_X emissions. The Mill calculates and maintains a record of the annual NO_X emissions from the No. 2 Bark Boiler in units of tons per year (tpy) on a calendar year basis in accordance with A.A.C. r. 335-3-14-.04(17)(e)(3). The source obligation report for 2025 is the third of five required annual reports.

Table 1-1 presents the Baseline Actual Emissions (BAE) from the original 2022 submittal. Table 1-2 details the actual NO_X emissions from the No. 2 Bark Boiler during the reporting period, and Table 1-3 presents the actual project-related emissions increases for NO_X during the reporting period.

Should you have any questions about this submittal, please feel free to contact Fred Francis at (334) 418-5154 or Frederick.Francis@ipaper.com.

RECEIVED
FEB 26 2026
ADEM
FRONT DESK

Based on information and belief formed after reasonable inquiry, I certify, to the best of my knowledge, that the statements and information in this submission are true, accurate, and complete.

Sincerely,
IP Riverdale Mill

Micah Evans
Mill Manager

cc: Fred Francis (IP Riverdale Mill)
Kelly Finch (IP Riverdale Mill)
Susie Bowden (ALL4)

Attachments: Attachment 1 – Source Obligation Summary for No. 2 Bark Boiler

ATTACHMENT 1 –
SOURCE OBLIGATION SUMMARY FOR NO. 2 BARK BOILER

Table 1-1
Summary of Baseline Actual Emissions (BAE)
International Paper – Riverdale Mill

Source	BAE (tpy)
	NO_X
No. 2 Bark Boiler	631.93
Baseline Period	**July-12**
	June-14
BAE Total	**631.93**

Table 1-2
Summary of 2025 No. 2 Bark Boiler Actual Emissions
International Paper – Riverdale Mill

Pollutant	Emissions Factors	Units	Reference	Annual Emissions (tpy) [a]
Combined Fuel				
NO_X	0.25	lb/MMBtu	Annual CEMS average from 2025	373.54
Total				
NO_X				373.54

[a] Annual emissions are based on the following fuel firing rates:

Fuel	Fuel Usage	Units
Bark	1,510,898	MMBtu
Natural Gas	1,159,094	MMBtu
Paper Recycling Residuals	36,855	MMBtu
WWTP Residuals	79,348	MMBtu
CrossTies	198,723	MMBtu
Combined Fuel	2,984,918	MMBtu

Table 1-3
Summary of 2025 Actual Emissions Increases and PSD Applicability
International Paper – Riverdale Mill

Source	Status	Emissions (tpy)
		NO_X
Actual Emissions		
No. 2 Bark Boiler	Modified	373.54
Baseline Actual Emissions (BAE)		
No. 2 Bark Boiler	Modified	631.93
Total Emissions Increase (Actual - BAE)		***-258.40***
PSD Significant Levels		***40***
PSD Significant?		**No**