Bissey, Steven

From: Frederick Francis <frederick.francis@ipaper.com>
Sent: Friday, March 6, 2026 3:11 PM
To: Bissey, Steven
Cc: Kelly M. Simmons; Shelly Pruden
Subject: RE: [External] :Inventory Questions
Attachments: Inventory Response (3.5.24) to ADEM.xlsx

Answers below, along with attached spreadsheet.

- Backup NCG Incinerator – stack height above grade (ft), stack inside diameter (ft), stack gas temperature at exit (?F), stack volume of gas discharge (ACFM), stack gas exit velocity (ft/s), UTM coordinates for the stack, and NOx potential to emit for the unit
    - Stack height above grade (ft) = 150 ft
    - Stack inside diameter (ft) = 2.5 ft
    - Stack gas temperature at exit (°F) = ~700 °F
    - Stack volume of gas discharge (acfm) = ~13,400 acfm
    - Stack gas exit velocity (ft/s) = ~45.5 ft/s
    - UTM coordinates = E-W: 512,461 m, N-S: 3,587,986 m, Zone: 16N
    - NOx PTE = 2.43 tpy
- No. 1 Recovery Furnace – NOx potential to emit for the unit = 264.44 tpy
- No. 1 Power Boiler - NOx potential to emit for the unit, has this unit been shutdown yet following startup of PB3 and the date of shutdown. PB1 down as of 4/17/25
    - PTE = 350.32
    - Shutdown date = April 17, 2025
- No. 1 Bark Boiler – NOx potential to emit for the unit = 241.08 tpy
- No. 3 Package Boiler (NEW) – LAT/LON - 32°25'33.93"N 86°52'09.40"W, DD - 32.4260916667 - 86.8692777778, UTM - 16N 512289.97 3587673.85

Please let me know if you need any additional information.

~~fred francis

Fred Francis
Senior Environmental Engineer

Frederick.Francis@ipaper.com
T: 334-418-5154
M: 912-678-5897

International Paper

601 County Road 78
Selma, AL 36703

internationalpaper.com

From: Bissey, Steven <steven.bissey@adem.alabama.gov>
Sent: Monday, March 2, 2026 1:52 PM

To: Frederick Francis <frederick.francis@ipaper.com>
Subject: [External] :Inventory Questions

Good afternoon,

The IP Riverdale Mill was recently pulled into a background inventory for a potential PSD project for another facility. I am reviewing data for this inventory pull, and I have a few outstanding items to clear up.

Could you please provide the following information:

- Backup NCG Incinerator – stack height above grade (ft), stack inside diameter (ft), stack gas temperature at exit (?F), stack volume of gas discharge (ACFM), stack gas exit velocity (ft/s), UTM coordinates for the stack, and NOx potential to emit for the unit
- No. 1 Recovery Furnace – NOx potential to emit for the unit
- No. 1 Power Boiler - NOx potential to emit for the unit, has this unit been shutdown yet following startup of PB3 and the date of shutdown
- No. 1 Bark Boiler – NOx potential to emit for the unit
- No. 3 Package Boiler (NEW) – UTMs for the emission point

I need to have this data reviewed by Friday, March 6. Please let me know if you will not be able to respond before then.

Thank you,

Steven Bissey
Air Division
Alabama Department of Environmental Management
Post Office Box 301463
Montgomery, Alabama 36130-1463
Office : (334) 270-5671
Fax : (334) 279-3044
www.adem.alabama.gov
steven.bissey@adem.alabama.gov

Mission: Assure for all citizens of the state a safe, healthful and productive environment