ICS Trainer Rack

Level 5

L5BM_MC01
IP: 192.168.100.18

IP: 192.168.100.11

Managed L2 Switch
IP: 192.168.100.30

Managed L2 Switch
IP: 10.5.20.30

L4-Host-1

L4H1_RAC
IP: 10.5.20.10

L4H1_Attacker
IP: 10.5.20.205

WAN

Level 4

Managed L2 Switch
IP: 10.4.20.30

L4H1_Spare
IP: 10.4.20.10

L4H1_MailServer
IP: 10.4.20.21

L4BM_OfficePC
10.4.20.22

Enterprise Network

DMZ

North Firewall
IP: 10.4.20.254 / 10.5.20.254

L3 Switch
IP: 10.1.20.30

DMZ-Host-1

DMZH1_LogServer *IP: 10.1.20.13*
DMZH1_SIEM *IP: 10.1.20.15*
DMZH1_MSSQL *IP: 10.1.20.14*

DMZ-Host-2

DMZH2_EPO *10.1.20.11*
DMZH2_ADWSUS *IP: 10.1.20.12*
DMZH2_SINEMARC *IP: 10.1.20.16*
DMZH2_SINECNMS *IP: 10.1.20.20*
DMZH2_DC *IP: 10.1.20.17*
DMZH2_SINECINS *IP: 10.1.20.21*

DMZBM_SSM *IP: 10.1.20.18*
DMZBM_SSMSensor *IP: 10.1.20.19*

DMZ Network

Level 3

IP: 192.168.100.12

L3-Host-1

L3H1_Historian
IP: 192.168.30.10

DMZH2_MaintServer
Server
IP: 192.168.30.11

South Firewall
IP: 10.1.20.254 / 192.168.30.254

Managed L2 Switch
IP: 192.168.30.30

Operations Management Network

IP: 192.168.100.15

IP: 192.168.100.13

Host Management Network

Level 2

Wireless AP
IP: 192.168.20.30

Unmanaged Switch
IP: N/A (no mgmt IP)

L2-Host-1

L2H1_OSC01
192.168.21.10

L2H1_OSC02
192.168.21.11

IP: 192.168.100.16

Terminal Network

L2H1_ES01
IP: 192.168.20.11

L2H1_OSS01
IP: 192.168.20.10

L2BM_B&R
IP:192.168.20.12

IP: 192.168.100.17

Managed L2 Switch
IP: 192.168.20.254

System Network

Level 1

Firewall
IP: 192.168.1.254, 192.168.2.254, 192.168.3.254, 192.168.4.254

Managed L2 Switch
IP: 192.168.3.30

Power- Control Network

SAS Network

Managed L2 Switch
IP: 192.168.2.30

Pharma - Safety Network

Managed L2 Switch
IP: 192.168.1.30

Pharma - Control Network

PCS
192.168.1.0/24

CPU 410
IP: 192.168.1.10

ET 200SP
IP: 192.168.1.11

SIS
192.168.2.0/24

CPU 410F
IP: 192.168.2.10

IO RACK
IP: 192.168.2.11

SAS
VLAN: 192.168.3.0/24

Breaker IED 1
IP: 192.168.3.10

Breaker IED 2
IP: 192.168.3.11

RTU
IP: 192.168.3.12

PLC
VLAN: 192.168.3.0/24

Wago PLC
IP: 192.168.3.13

Level 0

3D Model Test Bed

Pharmaceutical CSTR
Feed dosing, agitation, temp PID, discharge

Transmission / Distribution
Voltage, Current, Power, Breaker Positions

Power Generation
Fuel- > Boiler - > Turbine - > Generator

Tabletop Trainee Kit

1 Virtual Machines

VM HOST

Hacker 1

USB to Ethernet Adapter

WAN
192.168.210.0/24

Firewall
VLAN A, B, WAN

1 Operator + Engineering Station
IP: 192.168.110.10

L2 Managed Switch
IP: 192.168.110.30

VLAN B: System Network
192.168.110.0/24

VLAN A: Control Network
192.168.10.0/24

CPU 410
IP: 192.168.10.10

ET 200SP IO RACK
IP: 192.168.10.11

LEGEND

- Pharma - Control Network
- Pharma - Safety Network
- Power - Control Network
- SAS Network
- System Network
- Terminal Network
- Operations Management Network
- DMZ Network
- Enterprise Network
- Wide Area Network
- Host Management Network

[SUPPLIER LOGO]		[CUSTOMER LOGO]			
Document Name:	**OT Cybersecurity Lab Architecture**				
Customer:	Ngee Ann Polytechnic (NP)	**Supplier:**	Siemens		
Doc No:	NP- ARCH- 001	**Version:**	1.0	**Date:**	13- Jul- 2026
Prepared By:				**Date:**	
Reviewed By:				**Date:**	
Approved By:				**Date:**	

CONFIDENTIAL — INTERNAL USE ONLY