

FIRE ALARM NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH PROJECT SPECIFICATION(S) & ALL OTHER CONTRACT DOCUMENTATION & DRAWINGS AS ISSUED BY THE ARCHITECT, STRUCTURAL ENGINEER & CONSULTING ENGINEERS.

2. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE STATED. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS INDICATIVE AND ILLUSTRATES DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DETAILED DESIGN AND COORDINATION WITH THE STRUCTURE AND OTHER SERVICES.

4. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.

5. ALL WORKS ARE TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT REGULATIONS, BUILDING REGULATIONS, IRISH STANDARDS, ACCEPTED CODES OF PRACTICE & TRADE ASSOCIATION REQUIREMENTS.

6. IT IS THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO LIAISE WITH THE MAIN CONTRACTOR & ALL OTHER TRADES TO ENSURE THE CO-ORDINATION OF WORKS TO SUIT PROGRAM CONTRACTS & AVOID CLASHES

7. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY SUPPORTS & MOUNTING ACCESSORIES.

8. ALL ELECTRICAL INSTALLATIONS SHALL COMPLY WITH THE CURRENT IS10101 WIRING REGULATIONS.

9. CONDUIT RUNS SHALL BE SIZES AND CONFIRMED BY THE ELECTRICAL CONTRACTOR IN ACCORDANCE WITH THE CURRENT IS 10101 WIRING REGULATIONS

10. CONTRACTOR TO CONFIRM THAT THE FIRE ALARM DESIGNS COMPLIES WITH IS 3215:2019

11. ALL HEIGHT AND LOCATIONS OFF ALL ELECTRICAL OUTLETS TO BE CONFIRMED WITH ARCHITECT PRIOR TO INSTALLATION.

12. ALL DRAWINGS TO COMPLY WITH PART M OF THE BUILDING REGULATIONS.

13. VOICE EVACUATION ALARM SYSTEM TO BE DESIGNED BY SPECIALIST PLEASE SEE PARTICULAR SCOPE OF WORKS AND SCHEMATICS FOR MORE DETAIL.

SECURITY & ACCESS CONTROL NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH PROJECT SPECIFICATION(S) & ALL OTHER CONTRACT DOCUMENTATION & DRAWINGS AS ISSUED BY THE ARCHITECT, STRUCTURAL ENGINEER & CONSULTING ENGINEERS.

2. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE STATED.

3. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS INDICATIVE AND ILLUSTRATES DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DETAILED DESIGN AND COORDINATION WITH THE STRUCTURE AND OTHER SERVICES.

4. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.

5. ALL WORKS ARE TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT REGULATIONS, BUILDING REGULATIONS, IRISH STANDARDS, ACCEPTED CODES OF PRACTICE & TRADE ASSOCIATION REQUIREMENTS.

6. IT IS THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO LIAISE WITH THE MAIN CONTRACTOR & ALL OTHER TRADES TO ENSURE THE CO-ORDINATION OF WORKS TO SUIT PROGRAM CONTRACTS & AVOID CLASHES

7. ANY DESIGN CHANGES OR DEVIATION FROM DESIGN MUST BE AGREED

LEGEND

IVO

INPUT OUTPUT DEVICES

DRCP

DISABLED REFUGE CALL POINT

IP65 EXTERNAL SOUNDER WITH BEACON

BREAK GLASS MANUAL CALL POINT

FLASHING BEACON

CO2 DETECTOR

CO2 DETECTOR CV COMPLETE WITH REMOTE INDICATOR

SMOKE DETECTOR

HEAT DETECTOR

SMOKE DETECTOR BEACON

SMOKE DETECTOR CV COMPLETE WITH REMOTE INDICATOR

HEAT DETECTOR CEILING VOID COMPLETE WITH REMOTE INDICATOR

SMOKE SOUNDER

HEAT DETECTOR SOUNDER

HEAT DETECTOR BEACON SOUNDER

SMOKE DETECTOR BEACON SOUNDER

SOUNDER FLASHING BEACON

FIRE ALARM REPEATER PANEL

FIRE ALARM PANEL

POWER SUPPLY UNIT

EMERGENCY KNOCK OFF BUTTON

GAS KNOCK OFF BUTTON

BEAM DETECTOR

DEAF ALTER TRANSMISSION

FIRE ALARM SOUNDER

GAS DETECTOR

GAS ALARM PANEL

DISABLE PULLCORD

DISABLE ALARM RESET

OVERDOOR INDICATOR LAMP

DISABLE TOILET ALARM

EMERGENCY POWER OFF

AOV CALL POINT

AOV PANEL

ASPIRATING SMOKE DETECTOR

FIRE SMOKE CURTAIN

STATIC DOME CCTV CAMERA

FIXED CCTV CAMERA

AUDIO INTERCOM SYSTEM

BA05

BA07

BA06

BA08

Rev	Date	Description	Orig	App
00	22.04.26	ISSUED FOR INFORMATION	RU	VU
01	08.05.26	ISSUED FOR TENDER	RU	VU

EDC

Cork Office

Tel: +353 (0)21 4280476

email: info@edcengineers.com

Dublin Office

Tel: +353 (0)1 5813993

email: info@edcengineers.com

London Office

Tel: +44 (0)20 3040092

email: info@edcengineers.com

www.edcengineers.com

THIS DRAWING IS THE PROPERTY OF E.D.C. AND SHALL NOT BE REPRODUCED OR DISCLOSED TO ANYONE WITHOUT THE PRIOR WRITTEN PERMISSION OF E.D.C. AND SHALL BE RETURNED UPON REQUEST

RIBA Work Stage

3,4

Status Code

S2

Current Revision

01

Scale @ A1

1 : 100

Model Manager

BOL

Project Manager

JR

Client

GLENVEAGH HOMES

Project

FORD SITE
CENTRE PARK ROAD CORK

Title

Block BA08 - Fire and Security Services Layout - Level 01

Drawing No

FRDBA08-EDC-65-01-DR-E-006501