

- FIRE ALARM NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH PROJECT SPECIFICATION(S) & ALL OTHER CONTRACT DOCUMENTATION & DRAWINGS AS ISSUED BY THE ARCHITECT, STRUCTURAL ENGINEER & CONSULTING ENGINEERS.

2. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE STATED.

3. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS INDICATIVE AND ILLUSTRATES DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DETAILED DESIGN AND COORDINATION WITH THE STRUCTURE AND OTHER SERVICES.

4. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.

5. ALL WORKS ARE TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT REGULATIONS, BUILDING REGULATIONS, IRISH STANDARDS, ACCEPTED CODES OF PRACTICE & TRADE ASSOCIATION REQUIREMENTS.

6. IT IS THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO LIAISE WITH THE MAIN CONTRACTOR & ALL OTHER TRADES TO ENSURE THE CO-ORDINATION OF WORKS TO SUIT PROGRAM CONTRACTS & AVOID CLASHES.

7. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY SUPPORTS & MOUNTING ACCESSORIES.

8. ALL ELECTRICAL INSTALLATIONS SHALL COMPLY WITH THE CURRENT IS10101 WIRING REGULATIONS.

9. CONDUIT RUNS SHALL BE SIZES AND CONFIRMED BY THE ELECTRICAL CONTRACTOR IN ACCORDANCE WITH THE CURRENT IS 10101 WIRING REGULATIONS.

10. CONTRACTOR TO CONFIRM THAT THE FIRE ALARM DESIGNS COMPLIES WITH IS 3218:2019.

11. ALL HEIGHT AND LOCATIONS OFF ALL ELECTRICAL OUTLETS TO BE CONFIRMED WITH ARCHITECT PRIOR TO INSTALLATION.

12. ALL DRAWINGS TO COMPLY WITH PART M OF THE BUILDING REGULATIONS.

13. VOICE EVACUATION ALARM SYSTEM TO BE DESIGNED BY SPECIALIST. PLEASE SEE PARTICULAR SCOPE OF WORKS AND SCHEMATICS FOR MORE DETAIL.
- SECURITY & ACCESS CONTROL NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH PROJECT SPECIFICATION(S) & ALL OTHER CONTRACT DOCUMENTATION & DRAWINGS AS ISSUED BY THE ARCHITECT, STRUCTURAL ENGINEER & CONSULTING ENGINEERS.

2. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE STATED.

3. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS INDICATIVE AND ILLUSTRATES DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DETAILED DESIGN AND COORDINATION WITH THE STRUCTURE AND OTHER SERVICES.

4. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.

5. ALL WORKS ARE TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT REGULATIONS, BUILDING REGULATIONS, IRISH STANDARDS, ACCEPTED CODES OF PRACTICE & TRADE ASSOCIATION REQUIREMENTS.

6. IT IS THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO LIAISE WITH THE MAIN CONTRACTOR & ALL OTHER TRADES TO ENSURE THE CO-ORDINATION OF WORKS TO SUIT PROGRAM CONTRACTS & AVOID CLASHES.

7. ANY DESIGN CHANGES OR DEVIATION FROM DESIGN MUST BE AGREED WITH THE CONSULTING ENGINEER.

8. ALL DIMENSIONS SHALL BE CHECKED ON SITE PRIOR TO FABRICATION ORDER OR DELIVERY.

9. FINAL DIMENSIONS SHALL BE CHECKED ON SITE PRIOR TO FABRICATION ORDER OR DELIVERY.

10. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION OF ALL SERVICES ON SITE.

11. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR PRODUCING A FULL SET OF COMBINED COORDINATED SERVICES DRAWINGS.

12. ALL DRAWINGS TO BE IN CONJUNCTION WITH ARCHITECTURAL DRAWINGS.

13. THE CONTRACTOR SHALL ALLOW FOR ALL NECESSARY SUPPORTS AND FITTINGS REQUIRED TO PROVIDE A FULLY FUNCTIONING INSTALLATION.

14. FINAL LOCATIONS OF ALL ACCESS CONTROL EQUIPMENT SUBJECT TO CONTRACTOR ARRANGING A SITE VISIT WITH SPECIALIST.

15. CCTV LOCATIONS SHOWN ARE INDICATIVE ONLY. CCTV SPECIALIST TO POSITION CAMERAS FOR BEST AREA COVERAGE BASED ON NUMBERS.

- LEGEND

IVO

INPUT OUTPUT DEVICES

DRCP

DISABLED REFUGE CALL POINT

IP65 EXTERNAL SOUNDER WITH BEACON

BREAK GLASS MANUAL CALL POINT

FLASHING BEACON

CO2 DETECTOR

CO2 DETECTOR CV COMPLETE WITH REMOTE INDICATOR

S

SMOKE DETECTOR

H

HEAT DETECTOR

S

SMOKE DETECTOR BEACON

S

SMOKE DETECTOR CV COMPLETE WITH REMOTE INDICATOR

H

HEAT DETECTOR CEILING VOID COMPLETE WITH REMOTE INDICATOR

S

SMOKE SOUNDER

H

HEAT DETECTOR SOUNDER

H

HEAT DETECTOR BEACON SOUNDER

S

SMOKE DETECTOR BEACON SOUNDER

SOUNDER FLASHING BEACON

FARP

FIRE ALARM REPEATER PANEL

FAP

FIRE ALARM PANEL

PSU

POWER SUPPLY UNIT

EMERGENCY KNOCK OFF BUTTON

GAS KNOCK OFF BUTTON

BD

BEAM DETECTOR

DA

DEAF ALTER TRANSMISSION

FIRE ALARM SOUNDER

G

GAS DETECTOR

GAP

GAS ALARM PANEL

DISABLE PULLCORD

R

DISABLE ALARM RESET

OVERDOOR INDICATOR LAMP

DTA

DISABLE TOILET ALARM

EPO

EMERGENCY POWER OFF

AOV CALL POINT

AOVP

AOV PANEL

ASD

ASPIRATING SMOKE DETECTOR

FSC

FIRE SMOKE CURTAIN

STATIC DOME CCTV CAMERA

FIXED CCTV CAMERA

AIS

AUDIO INTERCOM SYSTEM



BA05 BA07 BA06 BA08	<table><tr><th>Rev</th><th>Date</th><th>Description</th><th>Orig</th><th>App</th></tr><tr><td>00</td><td>22.04.26</td><td>ISSUED FOR INFORMATION</td><td>RU</td><td>VU</td></tr><tr><td>01</td><td>08.05.26</td><td>ISSUED FOR TENDER</td><td>RU</td><td>VU</td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr></table>	Rev	Date	Description	Orig	App	00	22.04.26	ISSUED FOR INFORMATION	RU	VU	01	08.05.26	ISSUED FOR TENDER	RU	VU																					Mechanical & Electrical Consulting Engineers Cork Office Tel: +353 (0)21 4280476 email: info@edcengineers.com Dublin Office Tel: +353 (0)1 5813993 email: info@edcengineers.com London Office Tel: +44 (0)20 6940292 email: info@edcengineers.com www.edcengineers.com	Client
	Rev	Date	Description	Orig	App																																	
	00	22.04.26	ISSUED FOR INFORMATION	RU	VU																																	
	01	08.05.26	ISSUED FOR TENDER	RU	VU																																	
EDC ISO 9001 BIM	Project																																					
RIBA Work Stage 3,4 Status Code S2 Current Revision 01	Title																																					
Scale @ A1 1 : 100 Model Manager BOL Project Manager JR	Drawing No																																					
		FRDBA08-EDC-65-07-DR-E-006501																																				
		Block BA08 - Fire and Security Services Layout - Level 07																																				

GLENVEAGH HOMES

FORD SITE
CENTRE PARK ROAD CORK

Block BA08 - Fire and Security Services Layout - Level 07