

FACULDADE DE ENGENHARIA DA UNIVERSIDADE DO PORTO

IEC 61499 Compliant Web-based IDE for Function Block Design

Pedro da Cunha Teixeira e Faro Beirão

WORKING VERSION



Mestrado em Engenharia Informática e Computação

Supervisor: Prof. Rui Pinto

January 31, 2026

Contents

1	Introduction	1
1.1	Context	1
1.2	Motivation	2
1.3	Problem	3
1.4	Research Questions	3
2	Literature Review	4
2.1	Methodology	4
2.1.1	Search and Selection	4
2.2	Related Work	5
3	State of the Art	6
3.1	Development Ecosystem	6
3.1.1	Open-Source	6
3.1.2	Commercial	6
3.2	Evolution of Web-Based Engineering Tools	7
3.2.1	Web-Based IDEs in Software Development	7
3.3	Gap Analysis	7
4	Proposed Solution	8
4.1	Approach	8
4.2	Methods	8
4.2.1	Introduction	8
4.3	Workplan	9
	References	10

List of Figures

1.1	IEC 61499 function block interface [4]	2
1.2	4diac IDE [1]	2
2.1	Example query on ScienceDirect with 136 results [10]	5
4.1	Gantt chart timeline for the proposed work	9

List of Tables

List of Acronyms

CPPS	Cyber-Physical Production Systems
FBD	Function Block Diagram
ICS	Industrial Control Systems
IDE	Integrated Development Environment
PLC	Programmable Logic Controller
RTE	Runtime Environment
SOA	Service-Oriented Architectures
UI	User Interface

Chapter 1

Introduction

1.1 Context

Cyber-Physical Production Systems (CPPS) [6] are complex systems that integrate physical processes with digital technologies to optimise production processes. Several software engineering approaches and technologies are utilised in the development and operation of CPPS. One of such approaches is Function Block Diagram (FBD) [2], which is a graphical programming language used in industrial automation and control systems. FBD uses graphical function blocks to represent the logic and control of a system. The function blocks are connected in a network to form a control program. One of the benefits of FBD is that it provides a visual representation of the control logic, which can be easier to understand and debug than traditional textual programming languages. FBD is also modular, which means that function blocks can be reused in multiple programs, reducing development time and improving code maintainability. Also, FBD is often used in conjunction with Programmable Logic Controllers (PLCs) to control machinery and processes in manufacturing and other industrial applications [7, 8]. FBD programs can be created and edited using specialised software tools that allow for the creation and manipulation of function blocks [16].

In industrial automation, it is common to use the IEC 61499 standard, which defines an event-driven FBD approach to designing control software [11]. Unlike traditional PLC programming languages, IEC 61499 emphasizes modularity, reusability, and explicit separation of events and data, allowing developers to design complex distributed systems in a scalable and maintainable way. Function blocks define both algorithms and interfaces for inputs, outputs, and events, making them ideal for CPPS development [3]. This approach is particularly suitable for distributed automation systems, where control logic must respond to events generated by multiple devices or sensors in real time. An example of such a function block interface is shown in Figure 2.1, highlighting the event inputs, outputs, and data connections that enable flexible interaction between system components.

While Runtime Environments (RTEs) enable the execution of function blocks compliant with the standard, Integrated Development Environments (IDEs) are used to design, create, and deploy




Figure 1.1: IEC 61499 function block interface [4]

function block pipelines to **CPPS**. These **IDEs** offer features and tools that facilitate the development, testing, and deployment of IEC 61499-compliant control systems. They are graphical editors, like shown in Figure 1.2, for creating function block diagrams with simulation capabilities and additional functionalities to streamline the development process.




Figure 1.2: 4diac IDE [1]

1.2 Motivation

The evolution of **CPPS** has increased the demand for flexible and intelligent control solutions capable of integrating physical processes with digital technologies. **FBD** and the IEC 61499 standard offer a structured, modular approach to building such distributed automation systems. To fully leverage these benefits, development tools must evolve alongside industrial needs, supporting more accessible, collaborative, and scalable workflows.

1.3 Problem

Existing IEC 61499 development environments are predominantly desktop-based and lack modern capabilities such as remote access, real-time collaboration, and seamless integration with cloud infrastructures. These limitations hinder efficient development, maintenance, and deployment of control applications within distributed CPPS. As a result, current tools fall short in supporting the flexibility, scalability required by certain modern industrial automation systems. Their complexity further complicates their usage for more basic needs.

1.4 Research Questions

This research seeks to investigate how modern web technologies can be leveraged to enhance the development, deployment, and operation of IEC 61499-compliant systems. This study is guided by the following main research question:

How can web-based IDEs enhance the development, deployment, and collaboration processes for IEC 61499 applications in distributed CPPS, addressing the limitations of traditional desktop-based environments?

To further refine the scope, the following sub-questions are proposed:

- What architectural and technological requirements must be considered when designing a web-based IDEs for IEC 61499?
- In what ways do web-based IDEs improve collaboration, accessibility, and scalability compared to existing desktop tools?

Chapter 2

Literature Review

This chapter reviews prior work related to IEC 61499-based development and the used IDEs. The goal is to better understand the landscape, which will then allow the critical review of the state of the art.

2.1 Methodology

A systematic literature review approach was adopted, the objective was to collect, screen, and analyze studies addressing IEC 61499 development tools, function blocks, CPPS, and development environments, to then critically reflect upon their findings to help the writing of this dissertation and the planning of the final product.

2.1.1 Search and Selection

The search was conducted in digital libraries **ScienceDirect**, **IEEE Xplore**, **ACM Digital Library**, among others, as well as research paper aggregators like **Semantic Scholar**, **Scopus** and **Web of Science** using combinations of the following terms:

- IEC 61499
- FBD
- IDE
- CPPS

Following the search, a manual review process was conducted to refine and validate the results. Titles and abstracts were first screened to understand the relevance of the articles with respect to this dissertation. The publications were then examined in greater detail through full-text review, the reference lists of selected papers were manually inspected to identify relevant works that may not have been captured by the initial keyword search.




Figure 2.1: Example query on **ScienceDirect** with 136 results [10]

Furthermore, terms related to the state of the art that were discovered mid search were also included in some queries. The objectives of doing this were to get a better personal understanding of the scene, as well as to find interesting references that could be included in this dissertation to backup the written claims. Some of the terms used were:

- PLC
- 4diac
- web-based

2.2 Related Work

It should be interesting to mention some papers that were used to get the knowledge used for writing this dissertation and which will be referenced throughout the whole document.

Monostori [6] write in-depth about **CPPS**, while Torres, Gonçalves, and Pinto [12] discuss how IEC 61499 can be leveraged for **CPPS** development. Zoitl et al. [16] demonstrated the use of the open-source **4DIAC** environment to develop modular and reusable IEC 61499 applications, highlighting the benefits of flexibility and adaptability in industrial settings. Similarly, Pinto et al. [8] presented an industrial case study showing that function blocks oriented approaches improve system modularity and reduce development effort compared to traditional procedural programming. Some more recent studies explore web-based execution of **FBD**, Rohat and Popescu [9] as well as Lyu et al. [5] propose the creation of a web platform for IEC 61499 development.

Chapter 3

State of the Art

This chapter provides a comprehensive analysis of the current landscape of development environments for **CPPS** and the IEC 61499 standard. It categorizes existing solutions into desktop-based and web-based development tools, while analyzing a possible gap in the ecosystem.

3.1 Development Ecosystem

Currently, the development ecosystem is dominated by desktop-based **IDEs**. These tools are typically monolithic applications installed locally on engineering workstations.

3.1.1 Open-Source

The most prominent open-source implementation is the **Eclipse 4diac** framework. It consists of the **4diac IDE** (based on the **Eclipse** framework) and the **4diac FORTE** (a run-time environment), although it can also use different **RTEs** like **DINASORE**. This **IDE** is very feature rich at the cost of significant system resources and increased complexity, resulting in a steep learning curve, which makes it more difficult to use [14].

An alternative is **Jetbrains FBME** which is a much simpler modeling environment which also relies on **4diac FORTE** as the **RTE** [11].

3.1.2 Commercial

The commercial side is dominated by **EcoStruxure Automation Expert**, **ISaGRAF Workbench** and other monolithic desktop based environments, usually with a built-in proprietary **RTE**. This makes them often very complete production ready tools, but they are not very flexible and not the best fit for many needs.

3.2 Evolution of Web-Based Engineering Tools

The software engineering domain has seen a massive shift from desktop **IDEs** to cloud-native environments. This trend is now influencing the domain of Industrial Control Systems (**ICS**), and while recent studies have proposed a Service-Oriented Architectures (**SOA**) to integrate IEC 61499 with cloud layers [12], the engineering tools themselves remain largely desktop-bound.

3.2.1 Web-Based IDEs in Software Development

In general software development, tools like **Visual Studio Code** have started offering web-based counterparts to their desktop applications [13] in search of a more flexible user experience. In fact, newer development environments like **Zed** make it a key goal of their products to have web platform support [15].

3.3 Gap Analysis

Current IEC 61499 tools face significant limitations that hinder modern **CPPS** development:

- **Platform Dependency:** Existing solutions are monolithic desktop applications, lacking the accessibility and portability of web-based environments.
- **Resource Intensity:** Current options are heavyweight and complex, creating a high barrier to entry compared modern development tools of other purposes.
- **Web Trends:** Despite industry trends, there is currently no mature, lightweight web interface for **FBD**, leaving **ICS** engineering behind the curve of cloud-native software development.

Chapter 4

Proposed Solution

4.1 Approach

4.2 Methods

4.2.1 Introduction

4.3 Workplan

Figure 4.1 outlines the planned work for this dissertation. The schedule is organized into three main phases: Experimentation, Code Development, and Deliveries. During the Experimentation phase, there will be a focus on studying the standard and running experiments to establish a solid technical foundation. The Code Development phase overlaps partially with Experimentation, ensuring that the software evolves in parallel with the experimental insights. Finally, the Deliveries phase spans the entire project duration and includes writing the dissertation and preparing the final presentation, ensuring that all outputs are documented and communicated effectively.




Figure 4.1: Gantt chart timeline for the proposed work

References

- [1] *4diac IDE Website*. URL: https://eclipse.dev/4diac/4diac_ide/.
- [2] Young-Jo Cho et al. “Function Block Diagram Approach for Manufacturing Process Control Programming”. en. In: *IFAC Proceedings Volumes* 26.2 (July 1993), pp. 461–464. ISSN: 14746670. DOI: 10.1016/S1474-6670(17)48510-7. URL: <https://linkinghub.elsevier.com/retrieve/pii/S1474667017485107> (visited on 01/28/2026).
- [3] Marcelo V. Garcia et al. “Engineering tool to develop CPPS based on IEC-61499 and OPC UA for oil&gas process”. en. In: *2017 IEEE 13th International Workshop on Factory Communication Systems (WFCS)*. Trondheim, Norway: IEEE, May 2017, pp. 1–9. ISBN: 978-1-5090-5788-7. DOI: 10.1109/WFCS.2017.7991969. URL: <http://ieeexplore.ieee.org/document/7991969/> (visited on 01/30/2026).
- [4] *IEC 61499 Wikipedia*. URL: https://en.wikipedia.org/wiki/IEC_61499.
- [5] Tuojian Lyu et al. “Towards Web Platform for Cloud-Based Virtual Commissioning of IEC 61499 Distributed Automation Systems”. en. In: *2024 IEEE 29th International Conference on Emerging Technologies and Factory Automation (ETFA)*. Padova, Italy: IEEE, Sept. 2024, pp. 1–4. ISBN: 979-8-3503-6123-0. DOI: 10.1109/ETFA61755.2024.10710351. URL: <https://ieeexplore.ieee.org/document/10710351/> (visited on 12/17/2025).
- [6] László Monostori. “Cyber-physical Production Systems: Roots, Expectations and R&D Challenges”. en. In: *Procedia CIRP* 17 (2014), pp. 9–13. ISSN: 22128271. DOI: 10.1016/j.procir.2014.03.115. URL: <https://linkinghub.elsevier.com/retrieve/pii/S2212827114003497> (visited on 01/28/2026).
- [7] Linna Pang et al. “Formal verification of function blocks applied to IEC 61131-3”. en. In: *Science of Computer Programming* 113 (Dec. 2015), pp. 149–190. ISSN: 01676423. DOI: 10.1016/j.scico.2015.10.005. URL: <https://linkinghub.elsevier.com/retrieve/pii/S0167642315002981> (visited on 01/29/2026).
- [8] Gonçalo Pinto et al. “Digital Factory: An Industrial Case Study for Function Block-Oriented Development”. en. In: *2023 IEEE 9th World Forum on Internet of Things (WF-IoT)*. Aveiro, Portugal: IEEE, Oct. 2023, pp. 01–06. ISBN: 979-8-3503-1161-7. DOI: 10.1109/WF-IoT58464.2023.10539486. URL: <https://ieeexplore.ieee.org/document/10539486/> (visited on 01/29/2026).
- [9] Oana Rohat and Dan Popescu. “Remote web-based execution of IEC 61499 function blocks”. en. In: *Proceedings of the 2014 6th International Conference on Electronics, Computers and Artificial Intelligence (ECAI)*. Bucharest, Romania: IEEE, Oct. 2014, pp. 33–38. ISBN: 978-1-4799-5478-0 978-1-4799-5479-7. DOI: 10.1109/ECAI.2014.7090220. URL: <http://ieeexplore.ieee.org/document/7090220/> (visited on 01/28/2026).

- [10] *ScienceDirect*. URL: <https://www.sciencedirect.com>.
- [11] Radimir Sorokin, Sandeep Patil, and Valeriy Vyatkin. “Novel development tool for IEC 61499 based on domain-specific languages”. en. In: *IFAC-PapersOnLine* 55.2 (2022), pp. 439–444. ISSN: 24058963. DOI: [10.1016/j.ifacol.2022.04.233](https://doi.org/10.1016/j.ifacol.2022.04.233). URL: <https://linkinghub.elsevier.com/retrieve/pii/S2405896322002348> (visited on 01/28/2026).
- [12] Tomás Torres, Gil Gonçalves, and Rui Pinto. “Literature Review on Cloud-Based Service-Oriented Architecture for IEC 61499 Distributed Control Systems.” en. In: *Proceedings of the 15th International Conference on Cloud Computing and Services Science*. Porto, Portugal: SCITEPRESS - Science and Technology Publications, 2025, pp. 174–181. ISBN: 978-989-758-747-4. DOI: [10.5220/0013293400003950](https://doi.org/10.5220/0013293400003950). URL: <https://www.scitepress.org/DigitalLibrary/Link.aspx?doi=10.5220/0013293400003950> (visited on 01/28/2026).
- [13] *VSCode Web*. URL: <https://code.visualstudio.com/docs/setup/vscode-web>.
- [14] Thomas Weber, Alois Zoitl, and Heinrich HuBmann. “Usability of Development Tools: A CASE-Study”. en. In: *2019 ACM/IEEE 22nd International Conference on Model Driven Engineering Languages and Systems Companion (MODELS-C)*. Munich, Germany: IEEE, Sept. 2019, pp. 228–235. ISBN: 978-1-7281-5125-0. DOI: [10.1109/MODELS-C.2019.00037](https://doi.org/10.1109/MODELS-C.2019.00037). URL: <https://ieeexplore.ieee.org/document/8904489/> (visited on 01/30/2026).
- [15] *Zed Roadmap*. URL: <https://zed.dev/roadmap>.
- [16] Alois Zoitl, Thomas Strasser, and Gerhard Ebenhofer. “Developing modular reusable IEC 61499 control applications with 4DIAC”. en. In: *2013 11th IEEE International Conference on Industrial Informatics (INDIN)*. Bochum, Germany: IEEE, July 2013, pp. 358–363. ISBN: 978-1-4799-0752-6. DOI: [10.1109/INDIN.2013.6622910](https://doi.org/10.1109/INDIN.2013.6622910). URL: <http://ieeexplore.ieee.org/document/6622910/> (visited on 01/29/2026).