BUI POWER AUTHORITY

ORDER TO OPERATE (PC 17)

Note:
- Orders to operate must be performed in the number sequence listed
- A group of operations listed under one sequence number may be performed by any sequence
- Apparatus must be in the position stated in "OPERATION" column

Purpose of Order: **To restore 54G1 governor system under PC14 #001105**

Sequence Number	Device	Remove tag no.	Operation	Place tag no.	initials
1.	1K1L		Check closed		
2.	Air drain valve		Check closed		
3.	1K8K		Check closed		
4.	1K6K		Open		
5.	1K3K		Open		
6.	1K1A		Open		
7.	1K1K		Check closed		
8.	1K2K		Open		
9.	Air supply valve selector switch		Turn to auto		
10.	Pump selector switch		Turn to auto		

Prepared By:	Checked By:	Ordered By:	Completed By:
Time:	Time:	Time:	Time:
Date:	Date:	Date:	Date:

Pinboard or Mimic board changed by:	
	PC 2 Serial Number: