

Partner: Lutron
Model: RadioRA 3
Device Type: Lighting



GENERAL INFORMATION

SIMPLWINDOWS NAME:	Lutron RadioRA 3 LED Control v1.1.1
CATEGORY:	Lighting
VERSION:	1.1.1
SUMMARY:	This module provides feedback monitoring capability for a LED component as part of a Lutron RadioRA 3 solution.
GENERAL NOTES:	This module supports up to 50 LEDs. If more than 50 LEDs need to be managed, additional modules can be added to support the number of LEDs required. This module requires one instance of the Lutron RadioRA 3 Command Processor module to register with.
CRESTRON HARDWARE REQUIRED:	Crestron 3-Series or 4-Series processor.
SETUP OF CRESTRON HARDWARE:	N/A
VENDOR FIRMWARE:	21.02.08f000
VENDOR SETUP:	Lutron RadioRA 3 Processor

Partner: Lutron
Model: RadioRA 3
Device Type: Lighting



PARAMETER:

Command_Processor_ID	Setting indicates the identifier of the Command Processor module this module registers with. A single program can contain multiple LED modules where multiple Lutron processors are involved.
LED_Href_ID[1]..LED_Href_ID[50]	Setting indicates the reference identifier for the LED the corresponding analog signal will trigger. Example: for LED href: /led/811, enter the value 811 in the parameter field.

Partner: Lutron
Model: RadioRA 3
Device Type: Lighting

**CONTROL:**

LED_Href_ID[1] .. LED_Href_ID[50]

A

Integer value indicates what the LED will be set to:

- 1 – LED On
- 2 – LED Off
- 3 – LED Normal Flash
- 4 – LED Rapid Flash
- 5 – Unknown

Partner: Lutron
Model: RadioRA 3
Device Type: Lighting

**FEEDBACK:**

Is_Initialized	D	High indicates the module is initialized. The module is initialized when all component state information has been updated in the module to reflect current component state.
LED_Href_ID[1]_Fb..LED_Href_ID[50]_Fb	A	Integer value indicates the current LED state: 1 – LED On 2 – LED Off 3 – LED Normal Flash 4 – LED Rapid Flash 5 – Unknown

Partner: Lutron
Model: RadioRA 3
Device Type: Lighting

**TESTING:**

OPS USED FOR TESTING:	CP3 1.603.4242.34642
	CP4 2.8000.00017
SIMPL WINDOWS USED FOR TESTING:	4.22
CRES DB USED FOR TESTING:	217.05
DEVICE DATABASE:	200.260
SYMBOL LIBRARY USED FOR TESTING:	1184
SAMPLE PROGRAM:	Lutron RadioRA 3 v1.1.1 Demo IP.smw
REVISION HISTORY:	v1.0 – Initial Release
	v1.1 – Corrected for errors when inputs are triggered before module is initialized