

Contents

NEC 70 2026 Tab Reference for Washington Telco Admin Exam 1

NEC 70 2026 Tab Reference for Washington Telco Admin Exam

This table is organized as a practical tabbing checklist for a telecommunications administrator exam code book. Washington publishes telecommunications administrator exam information through L&I, and the exam is open-book with approved references and permanent tabs/highlighting rules, so fast lookup points matter.

NEC section / table	Location (page – official title)	Topic / question to find there
Table 250.122	70-157 – Minimum Size Equipment Grounding Conductors (EGC) for Grounding Raceway and Equipment	EGC size by breaker or fuse size; “What size copper EGC is required for a 20A circuit breaker?”
250.66	70-148 – 250.66 Size of Alternating-Current(ac) Grounding Electrode Conductor	GEC sizing to electrodes; “How large does the copper grounding electrode conductor need to be?”
250.50-250.53	TBD – Grounding Electrode System and Electrode Installation	Ground rods, concrete-encased electrodes, bonding to electrodes; “What qualifies as the grounding electrode system?”
Article 250	TBD – Grounding and Bonding	General grounding and bonding lookups, definitions, and cross-references
110.26	TBD – Spaces About Electrical Equipment	Working-space depth, width, and height; “What is the minimum clear width in front of equipment?”
Article 100	TBD – Definitions	Fast lookup for defined terms that appear in answer choices

NEC section / table	Location (page – official title)	Topic / question to find there
300.5	TBD – Underground Installations	Burial depth questions; “How deep must UF cable or conduit be buried?”
Table 300.5	TBD – Minimum Cover Requirements	Direct-buried cable and raceway cover requirements by condition
300.4	TBD – Protection Against Physical Damage	Nail plates, bored holes, protection of cables and raceways
310.16	310.16 Ampacities of Insulated Conductors	Conductor ampacity by size, insulation, and temperature rating
314.16	TBD – Number of Conductors in Outlet, Device, and Junction Boxes, and Conduit Bodies	Box fill; “How many cubic inches per 14 AWG conductor?”
Article 770	TBD – Optical Fiber Cables and Raceways	Fiber cable rules that can overlap with telco/communications work
Article 800 / 805	TBD – Communications Circuits / Communications Cables	Communications cable installation, separation, listing, and use rules
Article 810	TBD – Radio and Television Equipment	Antenna and mast grounding/bonding, conductor routing, clearances
Article 820	TBD – Community Antenna Television and Radio Distribution Systems	Coax/CATV grounding, bonding, and installation questions
Article 830	TBD – Network-Powered Broadband Communications Systems	Network-powered broadband circuits and related installation rules
Chapter 9 Table 1	TBD – Percent of Cross Section of Conduit and Tubing for Conductors	Conduit fill percentages; “What is max fill with exactly two conductors?”

NEC section / table	Location (page – official title)	Topic / question to find there
Annex C	TBD – Conduit and Tubing Fill Tables	Fast raceway fill lookups by raceway type and conductor size
Article 220 / 120.41 (if applicable)	TBD – Load Calculations / Unit Loads	General lighting load and service/feeder calculation questions
Article 430	TBD – Motors, Motor Circuits, and Controllers	Motor conductor sizing and OCPD questions; “Continuous-duty motor conductors must be sized at what percent?”
406.4(D)	TBD – Replacements	Replacing nongrounding receptacles; GFCI/no equipment ground questions
210.52(D)	TBD – Bathrooms	Required receptacle location near sink basin in dwelling bathrooms
210.52(A)	TBD – Dwelling Unit Receptacle Outlets	6/12 rule style spacing questions in bedrooms and living areas
225.18 / 230.24	TBD – Overhead Conductor Clearances	Over-driveway and over-street service-drop or overhead conductor clearance questions
680.22	TBD – Receptacle Locations at Pools	Minimum distance from pool wall for required receptacles
410.16	TBD – Luminaires in Clothes Closets	Minimum clearance from storage space for closet luminaires
334.30	TBD – Securing and Supporting Nonmetallic-Sheathed Cable	“At what intervals must NM cable be secured?”
240.6(A)	TBD – Standard Ampere Ratings	
Standard breaker and fuse size questions		

100: 70-25–70-66 110: 70-66–70-78 250: 70-137–70-162 300-398: 70-199–70-320
500-516: 70-440–70-528 705-780: 70-709–70-771 800-830: 70-772–70-779