REVIVE 2024 Report

Resilience and ADORB Summary

Chicago-MDW_IECC_Elec

1 Introduction

Some regular text and some*italic text.*
Also some crazy characters: $&#{}

1.1 Math that is incorrect

$$2 * 3 = 9$$

2 Tables

Tables for thermal resilience and ADORB Costs

2.1 Resilience Single Point Metrics

Metric	Result	Unit
Heating SET Hours	368.93	°F hr
Hours Below 2°C	20.78	hr
Caution (> 26.7, < 32.2°C)	71.75	hr
Extreme Caution (> 32.2, < 39.4°C)	50.25	hr
Danger (> 39.4, < 51.7°C)	0.0	hr
Extreme Danger (> 51.7°C)	0.0	hr
Heating Battery Size	6.946577471025454	kWh
Cooling Battery Size	4.696743169494214	kWh

2.2 Adorb Single Point Metrics

Metric	Result	Unit
Energy Use Intensity	25.66	kBtu/ sf yr
Peak Electrical Load	12254.33	W
First Year Electric Cost	1906.6632555442247	$
First Cost	11417.922	$
Total ADORB Cost	133449.65034037747	$

3 Graph Results

Some regular text and some

3.1 Resilience Graph Results

3.2 Adorb Graph Results

Chicago-MDW_IECC_Elec_Heating Outage Resilience



Chicago-MDW_IECC_Elec_Cooling Outage Resilience




Morphed III_Chicago-MDW_IECC_Elec_ADORB COST
pv_dirEn
pv_dirMR
pv_opCO2
pv_emCO2
pv_eTrans
Cummulative Present Value [$]
Years
0
20000
40000
60000
80000
100000
120000
140000
0
10
20
30
40
50
60
70


Total Lifecycle ADORB Cost
Direct Energy
Direct Maintenance
Operational CO2
Embodied CO2
Energy Transition
Proposed
Base Case
71497.2
22896.6
10003.2
3322.61
25730
108138
11922
15364.4
2295
41306.2
Cost [$]
0
25000
50000
75000
100000
125000
150000
175000