DIRECTORATE OF FIRE & EMERGENCY SERVICES

STATE DISASTER MANAGEMENT AUTHORITY — COMPLIANCE DIVISION

Certificate No: MH/NAG/FIRE/2025/1129 **Date of Issue: 2025-01-05**

FIRE SAFETY & CLEARANCE CERTIFICATE (NOC)

This is to certify that the premises of Sunrise Technical Campus, situated at Revenue Survey No: Plot 44, was inspected by the designated Fire Officer. The fire prevention and life safety measures as mandated under Section 13 of the Fire Prevention and Life Safety Measures Act have been duly verified and found compliant.

1. Maximum Building Height: 14.8 Meters (Ground + 3 Floors)
2. Total Instructional Built-up Area: 8,420 Sq. Meters
3. Fire Sprinkler & Hose Reel Systems: Installed and Functional
4. Emergency Evacuation Staircases: 2 Adequate Exits Available

This No Objection Certificate is valid strictly up to: 2027-01-05

Subject to periodic maintenance and mock drills conducted bi-annually.

FIRE NOC RECORD

GOVERNMENT VERIFIED
FIRE DIVISION
SEAL & SIGNATURE

Digitally Authorized by:
Chief Fire Officer, Fire Headquarters
Sign-Hash: sha256:907625fcfb706189

Scan to Verify at State Portal