

Dear Tania Hannaford

As you are aware, Design Matters National recently carried out a QA Assessment Review on your project file for 6 Fictitious Avenue, Ringwood VIC 3134. I am pleased to advise that your QA Review has now been completed and your energy rating assessment demonstrates acceptable competency with a score of 98.8%. Please take note of the feedback below which is provided to help improve your future assessments.

Comments References

- Eave vertical offset: Eave 7 should be approximately 2640mm rather than 2395mm.
- Garage door weather-stripping and insect screens: W04 should not include weather-stripping.
- Downlight diameter and clearance: All downlights were specified as IC-4 rated, so ensure the clearance should be 0mm.

The NatHERS Administrator has recently confirmed that sealed exhaust fans (except for rangehood exhausts) should not include a 50mm clearance.

Please also refer to state requirements for additional details to those supplied above.

When your follow up review is due, particular attention will be taken to the points outlined above.

NatHERS Technical Note, Clause 10.3. NatHERS Technical Note,

Clause 8.1 and Table 3. NatHERS Technical Note,

Clause 9.4 to 9.8.