



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
AIR QUALITY DIVISION



PHILLIP D. ROOS
DIRECTOR

September 9, 2026

VIA EMAIL

Jim Krzywiecki
Director, Facilities Management
Ascension St. John Hospital
22101 Moross Road
Detroit, MI 48236-2148

SRN: M1812, Wayne County

Dear Jim Krzywiecki:

VIOLATION NOTICE

On July 8, 2026, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) conducted an inspection of Ascension St. John Hospital (Company) located at 22101 Moross Road, Detroit, Michigan. The purpose of this inspection was to determine the Company's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (NREPA), MCL 324.5501 *et seq*; the Air Pollution Control Rules, Mich Admin Code, R 336.1101 *et seq*; and the conditions of Permit to Install (PTI) No. 313-06 v1.0.

Violations:

During the inspection, the following violations were observed:

Process Description	Permit/Rule Violated	Comments
Emergency generators installed at the Company (FGFACILITY)	PTI, FGFACILITY, SC 3.4	Monitoring/Recordkeeping - Company failed to provide hours of operations records for each emergency generator within FGFACILITY.

VIOLATION NOTICE

Jim Krzywiecki

Ascension St. John Hospital

Page 2

September 9, 2026

Process Description	Permit/Rule Violated	Comments
Emergency engines 9 and 10 (FGENGINES)	PTI, FGENGINES, SC 1.5, 1.6, 1.7	Monitoring/Recordkeeping - Company failed to provide records regarding oxides of nitrogen (NOx) emissions, sulfur content of their fuel oil, and hours of operation relating to FGENGINES.
Emergency generators, boilers, and all other equipment at the Company (FGFACILITY)	PTI, FGFACILITY, SC 3.2, 3.3	Monitoring/Recordkeeping - Company failed to provide records regarding NOx emissions and fuel usage records for FGFACILITY.

During this inspection, the Company was unable to produce records. The conditions of the PTI require a written log of the monthly hours of operation of each emergency generator at the Company (FGFACILITY). This is a violation of the recordkeeping in FGFACILITY, SC 3.4 of the PTI.

In addition, the conditions of the PTI require monthly and 12-month NOx emissions records, the sulfur content for each fuel oil shipment, and a written log of the monthly hours of operation for emergency engines 9 and 10 (FGENGINES). This is a violation of the recordkeeping specified in FGENGINES, SC 1.5, 1.6, 1.7, respectively, of the PTI.

Finally, the conditions of the PTI require monthly and 12-month NOx emissions records, as well as monthly and 12-month natural gas and fuel oil usage records for emergency generators, boilers, and all other equipment, collectively, at the Company (FGFACILITY). This is a violation of the recordkeeping specified in FGFACILITY, SC 3.2 and 3.3 of the PTI.

Next Steps:

A written response should be submitted through [MiEnviro Portal](#) by **September 30, 2026**, and include all of the following:

VIOLATION NOTICE

Jim Krzywiecki

Ascension St. John Hospital

Page 3

September 9, 2026

- the dates the violations occurred;
- an explanation of the causes and duration of the violations;
- whether the violations are ongoing;
- a summary of the actions that have been taken and are proposed to be taken to correct the violations and
- the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If the Company believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, provide appropriate information to explain your position in your response to this letter.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my inspection. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

Savannah Pigman

Sav Pigman,
Environmental Quality Analyst
Air Quality Division
313-439-3690

cc: Crystal Rogers, City of Detroit BSEED

Annette Switzer, EGLE

Christopher Ethridge, EGLE

Brad Myott, EGLE

Jenine Camilleri, EGLE

Dr. April Wendling, EGLE

Jeff Korniski, EGLE