



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
AIR QUALITY DIVISION



PHILLIP D. ROOS
DIRECTOR

August 7, 2026

VIA EMAIL

Byeongbu An, Senior EHS Manager
LGESMI Lansing
7111 Davis Highway
Lansing, Michigan 48917

SRN: P1269, Eaton County

Dear Byeongbu An:

VIOLATION NOTICE

On July 7, 2026, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) received an Air Quality Test Submittal from LGESMI Lansing (Company) located at 7111 Davis Highway, Lansing, Michigan. The purpose of this record submittal was to determine the Company's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended, MCL 324.5501 *et seq*; the Air Pollution Control Rules, Mich Admin Code, R 336.1101 *et seq*; and the conditions of Permit to Install (PTI) No. 139-22A v3.0.

Violations:

During the records review, the following violations were observed:

Process Description	Permit/Rule Violated	Comments
Hot oil, steam, and hot water boilers with low NOx burners. [HOB-100-1003]	PTI No. 139-22A v3.0, FG-BOILERS, SC I.1; 40 CFR 52.21(c) and (d)	The test results show that flexible group emissions exceed an hourly permit limit.

The test report shows that the emissions of NOx from the single representative unit tested are 0.37 pounds per hour (pph), and the emissions of NOx from FG-BOILERS (containing seven units) are calculated to be 2.59 pph. This emission rate exceeds the permit emission limit of 1.91 pph on NOx found in PTI 139-22A v3.0, FG-BOILERS, SC I.1, and is a violation of that condition.

VIOLATION NOTICE

Byeongbu An, Senior EHS Manager

LGESMI Lansing

Page 2

August 7, 2026

Next Steps:

A written response should be submitted through [MiEnviro Portal](#) by **August 28, 2026**, and include all of the following:

- the dates the violation occurred;
- an explanation of the causes and duration of the violation;
- whether the violation is ongoing;
- a summary of the actions that have been taken and are proposed to be taken to correct the violation and
- the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If the Company believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, provide appropriate information to explain your position in your response to this letter.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Loren Hicks

Environmental Quality Analyst

Air Quality Division

517-897-0604

cc: Annette Switzer, EGLE
Christopher Ethridge, EGLE
Brad Myott, EGLE
Jenine Camilleri, EGLE
Robert Byrnes, EGLE