

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 275/2025

Dated: 19/6/2025

It is certified that an inspection team headed by Jose Jacob... Health Inspector...

(Name of Officers with designation) from PHC Thidanadu..... PHED

inspected the Carmel Rani Public School, Vazhyanthadu, Chettuthodu P.O.

(Name & Address of the school) on 13/05/2025.. (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. PH 1291/Pala/06/2025 dated 17.6.2025

of Quality Control Sub-dist. Lab. KWA (PHED Lab) certified that the

Carmel Rani Public School..... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 12/06/2025

Signature with Seal:

Name : Jose Jacob

Designation : H.I.

Name & Address of the Office / Department :

To Carmel Rani Public School
Vazhyanthadu, Chettuthodu P.O.
(Name & Address of the Institution)

HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
THIDANADU



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



QUALITY CONTROL SUB DISTRICT LABORATORY

KERALA WATER AUTHORITY,
PALA, KOTTAYAM

Telephone No. 04822 200675, Email: qcsdlpala@gmail.com

TEST REPORT

Report No: PL1291/PALA/06/2025		Date: 17.06.2025	
Customer Name & Address		1. Date of Receipt	
CARMEL RANI PUBLIC SCHOOL ALAMMA MATHEW VARIYANIKKADU CHETTUTHODU P.O KOTTAYAM , 686508		13.06.2025	
		2. Sampling done by	
		CUSTOMER	
		3. Sample Code	
		2025/QCSDL/PALA/PL 3304	
		4. Source of Sample	
		DRINKING WATER	
5. Sample Quantity			
100 ML			
6. Sample conditions			
ACCEPTABLE			
7. Test performing dates: 13.06.2025 TO 16.06.2025			

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per - IS 10500:2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016	ABSENT
2	E.coli	Shall not be detected/100ml	IS 15185:2016	ABSENT

Test method


Coliforms: Membrane Filtration Method

E. coli: Membrane Filtration Method

Remarks-

NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

*Samples will be retained only for 7 days after completion of analysis
*Sampling is not done by the Lab



Authorized By

Shahana Sherief

(Bacteriologist)