

# Numerical analysis of the influence of magnetic field waveforms on the performance of active magnetic regenerators

Fábio P. Fortkamp · Gusttav B. Lang · Jaime A.

Lozano · Jader R. Barbosa Jr.

**Abstract** Magnetic cooling is an alternative to vapor compression that does not rely on the use of hazardous substances. The refrigerant is a solid material which reacts to oscillations in magnetic field by changing its temperature (the magnetocaloric effect). In active magnetic regenerators, the magnetocaloric material arranged as a porous medium is subjected to an oscillating fluid flow to allow heat transfer from a cold source to a hot sink in a thermodynamic cooling cycle. Although the literature is abundant with studies on the influence of the fluid flow waveform on magnetic refrigeration devices, the influence of the magnetic field waveform has been much less investigated. In this work, we make use of an active magnetic regenerator numerical model with different mathematically-defined waveforms to determine which operating parameters yield the highest values of cooling capacity and coefficient of

---

An abridged version of this manuscript was presented at the ABCM International Congress of Mechanical Engineering (COBEM **Completar... cidade etc** ).

Fábio P. Fortkamp

E-mail: fabio@polo.ufsc.br

Gusttav B. Lang · Jaime A. Lozano · Jader R. Barbosa Jr.

POLO — Research Laboratories for Emerging Technologies in Cooling and Thermophysics, Department of Mechanical Engineering, Federal University of Santa Catarina, Florianópolis, SC, 88040-900, Brazil

performance for a specific set of operating conditions. The results show that the best performance is achieved when the magnetic field is kept constant for the same time duration of the fluid flow through the magnetized material, and that the transition times between the high and low levels of the magnetic field should be as short as possible.

**Keywords** magnetic refrigeration · active magnetic regenerator · numerical modeling · magnetocaloric effect

## List of symbols

### Variables

$A_{sf}$	contact surface area between solid and fluid phases in the regenerator [ $m^2$ ]
$A_t$	amplitude of the pressure gradient waveform in the fluid momentum equation [ $m/s$ ]
$c$	specific heat [ $J/(kg\ K)$ ]
$c_E$	Ergun constant of the porous medium
COP	coefficient of performance
$D_{ld}$	dispersion term in the AMR model [ $m/s^2$ ]
$f$	cycle frequency [Hz]
$F_M$	magnetization fraction
$g(t)$	dimensional waveform of the pressure gradient term in the fluid momentum equation
$\hbar$	heat transfer coefficient [ $W/(m^2\ K)$ ]
$K$	permeability of the porous medium [ $m$ ]
$k^{eff}$	effective thermal conductivity [ $W/(m\ K)$ ]
$\dot{m}_f$	mass flow rate [ $kg/s$ ]
$M$	magnetization field [ $A/m$ ]

---

$m$	mass [kg]
$N_D$	demagnetization tensor
$N_r$	number of regenerators
$N_v$	number of valves
$\Delta P$	pressure drop across one region [Pa]
$P$	pressure [Pa]
$\dot{q}_{\text{csg}}$	volumetric casing losses in the AMR model [W/m <sup>3</sup> ]
$T$	temperature [K]
$t$	time [s]
$V$	velocity [m/s]
$\dot{W}_{\text{relay},n}$	nominal power consumption of one relay [W]
$\dot{W}_{\text{valve}}$	valve power [W]
$\dot{W}_{\text{valve},n}$	nominal power consumption of one valve [W]
$\dot{W}_{\text{mag}}$	magnetic power [W]
$\dot{W}_{\text{pump}}$	pumping power [W]
$z$	axial coordinate [m]
$\theta_R$	ramp rate in the magnetic ramp profile
$\tau_M$	magnetization period in the magnetic ramp profile [s]
$\tau_R$	ramp period in the magnetic ramp profile [s]

### Greek symbols

$\beta$	surface area density [m/m <sup>3</sup> ]
$\varepsilon$	porosity
$\Phi$	utilization factor
$\Phi$	utilization
$\rho$	density [kg/m <sup>3</sup> ]

$\Delta T_{\text{ad}}$     adiabatic temperature variation [K]

$\tau$         time period [s]

$\tau_{\text{B}}$        blow duration [s]

$\mu$         dynamic viscosity [Pa s]

### **Subscripts and Superscripts**

air        air layer between magnets and regenerators

csg        regenerator casing

f        fluid phase

s        solid phase

sf        relative to the heat transfer between solid and fluid phases in the regenerator

### **Abbreviations**

C        cold source

CC       cold cycle

CE       cold end

H        hot source

HB       hot blow

HC       hot cycle

IT        instantaneous magnetic profile

AMR    Active Magnetic Regenerator

MCE    Magnetocaloric Effect

MCM    Magnetocaloric Material

MR       Magnetic (or Magnetocaloric) Refrigeration

RC       rectified cosine magnetic profile

RM       rectified cosine magnetic profile

## 1 Introduction

Although mechanical vapor compression has been the dominant cooling technology for the past century [1], it still faces a number of challenges related to its environmental footprint. For instance, the phase-out of refrigerants with ozone depleting and global warming potentials brought about a more widespread use of flammable substances, which pose a new set of concerns, restrictions and new technological challenges for consumer applications [2, 3].

Magnetic refrigeration (MR) is an emerging cooling technology which does not rely on hazardous fluids. In MR, the temperature of a *magnetocaloric material* (MCM) changes as a result of cyclical changes in the applied magnetic field due to the so-called *magnetocaloric effect* (MCE). The magnitude of the MCE depends on material properties, magnetic field variation and temperature, and it is maximum at the Curie temperature of the material [4, 5]. Applications of the MCE at near room-temperature are not restricted to cooling applications; it can also be applied to the development of thermomagnetic motors [? ].

For operating temperatures typical of household cooling applications, the MCE is of the order of 2-5 K/T. To amplify this temperature change, heat regeneration is usually employed [5]. Active magnetic regenerators (AMR) are thermal devices in which the magnetocaloric material is packed as a porous matrix subjected to periodic flow of an aqueous heat transfer fluid. The flow is put in sync with successive magnetization and demagnetization steps of the MCM in the porous bed to produce a refrigerating effect. Thus, the AMR is essentially a cascade of infinitesimal “layers” of MCM that are activated simultaneously to build up a longitudinal temperature profile in the matrix. The layers can be made of the same material, resulting in a homogeneous regenerator. However, given the dependence of the MCE on temperature, it is desirable to build *multilayer* regenerators, where each adjacent layer

has a slightly different composition that will function around its own Curie temperature, maximizing the magnetocaloric effect of each portion.

A typical AMR cycle is comprised of the following steps: (i) The magnetic circuit magnetizes the MCM, thereby increasing its temperature due to the MCE; (ii) During the *cold blow*, cold fluid previously in thermal contact with the low-temperature source flows through the warm bed, absorbs its energy and releases it as heat to the high-temperature sink through the hot heat exchanger; (iii) The MCM is demagnetized and cools down as a result; (iv) As the fluid flow is reversed (*hot blow*), it releases energy to the bed, decreases its temperature so it can absorb the thermal load at the cold heat exchanger in contact with the low-temperature source. Different cycles can be devised by changing the duration and synchronization between the two cycle *characteristic waveforms*:

1. The *applied magnetic field profile*, which describes the oscillating magnetic field over one regenerator;
2. The *fluid flow profile*, which describes the time-variation of flow rate through one bed.

Fluid flow profiles can be more easily investigated experimentally, as no changes in the fluid flow hardware are required. In particular, the effect of the *duration* of the fluid blows has been extensively investigated [6, 7, 8]. There appears to be a consensus in the literature that the cooling capacity of magnetic refrigerators can be increased by displacing the fluid during periods where the magnetic field is at its extreme values.

In contrast, because of the complexities involved in designing and fabricating magnetic circuits, the applied magnetic field profiles (or simply the magnetic waveforms) are much less studied. Magnetic waveforms are usually investigated in terms of their synchronization with the fluid flow profile [9, 10]. **acho q cabe explicar brevemente o que os trabalhos de [9] e [10] fizeram...** Trevizoli et al. [11] carried out a numerical comparison of the square wave (step change), si-

nusoidal and rectified cosine magnetic profiles. However, no systematic assessment of the effect of amplitude was performed nor did they investigate different geometries .

Fabio, acho que revisao bibliografica tem que ser expandida, trazendo trabalhos mais recentes em refrigeracao magnetica.

Tambem tem que trazer aqui para a revisao os nossos artigos que mediram/testaram/modelaram as valvulas.

The present work bridges the gaps left in previous studies by investigating the performance of a magnetic refrigerator under different magnetic profile waveforms. These waveforms are mathematically modeled, and the cooling capacity and coefficient of performance are calculated based on the profiles parameters, while also investigated how the AMR geometry affect the performance in combinations with the magnetic profile. The fluid flow profile is assumed fixed in shape, although its parameters are also varied. To emulate constraints on an operating point of actual magnetic refrigeration devices, the temperature span is set fixed, and hence few comments are made on second-law efficiency.

## 2 Materials and methods

As previously explained, we performed numerical simulations using a previously developed AMR model, varying the profile-specific and geometric parameters. We also implemented a model to calculate the power consumption of a novel fluid management system, which is a topic not yet extensively studied in the literature. The output variables from this integrated model are the cooling capacity, the several power contributions ( specify ) and the coefficient of performance (COP).

## 2.1 AMR model

### 2.1.1 Governing equations

Simulations were performed using a one-dimensional AMR mathematical model, implemented using the Finite Volume Method [11]. The model solves momentum and energy balance equations for the solid and fluid phases, represented by indices ‘s’ and ‘f’, respectively. The model geometry is shown in Figure 1, and assumes that the regenerator is composed of monodisperse packed spheres with porosity  $\varepsilon$ .




Fig. 1: AMR model geometry

The momentum equation for the fluid domain is given by:

$$\frac{\rho_f}{\varepsilon} \frac{\partial V_z}{\partial t} = -\frac{\partial P}{\partial z} - \frac{\mu_f}{K} V_z - \frac{c_E \rho_f}{K^{1/2}} |V_z| V_z \quad (1)$$

and is solved for the time-dependent uniform fluid velocity  $V_z$  through the bed.

The energy equation for the fluid phase can be written as:



$$\begin{aligned}
\rho_f c_{p,f} \left( \varepsilon \frac{\partial T_f}{\partial t} + V_z \frac{\partial T_f}{\partial z} \right) = & -\dot{h}_{sf} \beta (T_f - T_s) \\
& + \left| V_z \frac{\partial P}{\partial z} \right|_f \\
& + \varepsilon \left( k_f^{\text{eff}} + \rho_f c_{p,f} D_{ld} \right) \frac{\partial^2 T_f}{\partial z^2} \\
& + \dot{q}_{csg}
\end{aligned} \tag{2}$$

while the energy equation for the solid phase is written as:

$$\rho_s c_s (1 - \varepsilon) \frac{\partial T_s}{\partial t} = \dot{h}_{sf} \beta (T_f - T_s) + (1 - \varepsilon) k_s^{\text{eff}} \frac{\partial^2 T_s}{\partial z^2} \tag{3}$$

Fabio, talvez valha a pena explicar quem eh quem nos termos das equacoes da Q movimento e energias...

Initial and boundary conditions, closure relations for the porous media terms, solution methods and convergence criteria and analyses are discussed in detail in [11]. This AMR model solves the above equations for one regenerator operating between given sources temperatures (assuming ideal heat exchangers in contact with the thermal reservoirs), during one full cycle (hot and cold blows and magnetization and demagnetization periods), given specified operating conditions (to be discussed later).

The casing heat transfer term  $\dot{q}_{csg}$  in Equation 2 is calculated solving the heat conduction equation in the regenerator casing [11]. It can be neglected in some circumstances if an insulating casing material is assumed, which greatly simplifies the analysis.

### 2.1.2 Fluid flow profile modeling

The pressure gradient in Equation 1 is modeled as:

$$-\frac{\partial P}{\partial z} = \rho_f A_t g(t) \tag{4}$$

where  $g(t)$  is a dimensionless function that expresses the mathematical waveform of the pressure gradient, and  $A_l$  is its amplitude, adjusted in a convergence loop. In this loop, the mass flow rate calculated in term of the Darcy velocity from Equation 1 is compared with the input mass flow rate until convergence is obtained.

The canonical fluid flow profile considered in this work is the square wave or *instantaneous profile*, because of the instantaneous change in flow rate, as shown in Figure 2.




Fig. 2: Instantaneous fluid flow profile

The instantaneous mass flow rate,  $\dot{m}_f(t)$ , is defined over a cycle with a period  $\tau$ , and represents the fluid flow through a given regenerator bed. The so-called *hot cycle*, during which the MCM is magnetized, occupies the time interval  $0 \leq t < \tau/2$ , while the *cold cycle* lies between  $\tau/2 \leq t \leq \tau$ . The flow profile oscillates between two plateaus of equal magnitude  $\dot{m}_{f,max}$  and opposite directions, which are centered in each half-cycle. During the hot cycle,

the cold blow period is  $\tau_{CB}$ , and during the cold cycle the hot blow period is  $\tau_{HB}$ . If balanced flow exists, then  $\tau_{CB} = \tau_{HB}$ .

During each half cycle, there are periods without fluid flow defined as:

$$\tau_{0,HC} = \frac{\tau/2 - \tau_{CB}}{2} \quad (5)$$

$$\tau_{0,CC} = \frac{\tau/2 - \tau_{HB}}{2} \quad (6)$$

where HC and CC stand for hot cycle and cold cycle, respectively.

The profile can be mathematically defined as:

$$\dot{m}_f(t) = \begin{cases} 0, & 0 \leq t < \tau_{0,HC} \\ \dot{m}_{f,max}, & \tau_{0,HC} \leq t \leq \tau/2 - \tau_{0,HC} \\ 0, & \tau/2 - \tau_{0,HC} < t < \tau/2 + \tau_{0,CC} \\ -\dot{m}_{f,max}, & \tau/2 + \tau_{0,CC} \leq t \leq \tau - \tau_{0,CC} \\ 0, & \tau - \tau_{0,CC} < t < \tau \end{cases} \quad (7)$$

When the blows have different time durations, the AMR cycle is considered unbalanced, and that is known to have a negative effect on performance [12, 7]. In this work, the blows are always balanced, hence the blow fraction, i.e., the ratio of blow durations to cycle period [7], can be evaluated as:

$$F_B = \frac{2\tau_B}{\tau} \quad (8)$$

where  $\tau_B$  is the duration of one blow.

### 2.1.3 Magnetic profile modeling

The magnetic profile is modeled by a waveform of magnetic field strength,  $H(t)$ , applied perpendicular to the regenerators, as shown in Figure 1. The magnetic field is assumed uniform throughout the beds. The applied field is corrected from demagnetization effects to yield the effective field inside the regenerators:

$$H^{\text{eff}} = H - N_D M \quad (9)$$

where  $M$  is the magnetization field of the material, and  $N_D$  is a demagnetization factor.

The magnetocaloric effect is implemented in the so-called discrete approach [13]; every time the magnetic field changes, based on the input magnetic profile, the solid temperature is calculated according to:

$$T_s(t + \Delta t) = T_s(t) + \Delta T_{\text{ad}} \left( T_s(t), H^{\text{eff}}(t), H^{\text{eff}}(t + \Delta t) \right) \quad (10)$$

where the adiabatic temperature variation,  $\Delta T_{\text{ad}}$ , a standard measure of the MCE, is calculated from tabulated experimental data for magnetocaloric materials as function of temperature and effective field. [11].

The magnetic profiles considered in this work are presented in terms of the flux density  $B = \mu_0 H$ , where  $\mu_0$  is the permeability of free space; the magnetic field  $H$  is used in the evaluation of the magnetocaloric effect (cf. Sec. 2.1.3).

The instantaneous (square wave) profile (represented by the subscript “IT”) and the rectified cosine profile (represented by “RC”) are defined solely in terms of the extreme values  $B_{\text{min}}$  and  $B_{\text{max}}$ , and are shown in Figure 3.

$$B_{IT}(t) = \begin{cases} B_{\max}, & 0 \leq t < \tau/2 \\ B_{\min}, & \tau/2 \leq t < \tau \end{cases} \quad (11)$$

$$B_{RC}(t) = B_{\min} + (B_{\max} - B_{\min}) \left| \cos \left( \frac{\pi}{\tau} \left( t - \frac{\tau}{4} \right) \right) \right| \quad (12)$$




Fig. 3: Instantaneous ("IT") and rectified cosine ("RC") magnetic profiles

A suitable approximation of the instantaneous profile is the *magnetic ramp profile*, shown in Figure 4, with finite transition times between the levels of constant magnetization. The magnetic profile oscillates between a low value  $B_{\min}$  and a high value  $B_{\max}$ , and remains at each plateau for a period of  $\tau_M$ . The plateaus are balanced and centered at each half-cycle.

The *ramp period*  $\tau_R$  is defined as:

$$\tau_R = \frac{1}{4}(\tau - 2\tau_M) \quad (13)$$

such that there are four ramp periods in one full cycle. The ramp rate,  $\theta_R$ , is:

$$\tan \theta_R = \frac{(B_{\max} - B_{\min})}{2\tau_R} \quad (14)$$




Fig. 4: Magnetic ramp profile

The magnetization fraction,  $F_M$ , is the fraction of the cycle during which the magnetocaloric material is subjected to a constant magnetic field:

$$F_M = \frac{2\tau_M}{\tau} \quad (15)$$

The ramp profile (“RM”) can be mathematically defined as:

$$B_{RM}(t) = \begin{cases} (B_{\max} + B_{\min})/2 + t \tan \theta_R, & 0 \leq t < \tau_R \\ B_{\max}, & \tau_R \leq t < \tau/2 - \tau_R \\ B_{\max} - (t - (\tau/2 - \tau_R)) \tan \theta_R, & \tau/2 - \tau_R \leq t < \tau/2 + \tau_R \\ B_{\min}, & \tau/2 + \tau_R \leq t < \tau - \tau_R \\ B_{\min} + (t - (\tau - \tau_R)) \tan \theta_R, & \tau - \tau_R \leq t \leq \tau \end{cases} \quad (16)$$

Additionally, the average values of the magnetic field during each half-AMR cycle are considered for comparison between profiles. The average magnetic profile during the hot cycle ( $0 \leq t < \tau/2$ ) is denoted by  $\bar{B}_{\text{high}}$  and the average during the cold cycle ( $\tau/2 \leq t < \tau$ ) is denoted by  $\bar{B}_{\text{low}}$ . For the instantaneous waveform, these average values are identical to the extreme values.

#### 2.1.4 Evaluation of solid and fluid properties

The fluid properties are considered constant in the momentum equation to decouple the solution procedures to determine the velocity and temperature fields. The properties are computed at the average temperature between the hot and cold sources, and are evaluated from interpolation of tables imported from the EES software [14]. In all simulations shown in this work, the heat transfer fluid is a 80/20 % vol. mixture of water/ethylene-glycol. For the energy equations, the fluid properties are also calculated from tabulated data, but the temperature dependence is considered.

Both single- and multilayer regenerators are considered in this study. Single-layer regenerators are composed of gadolinium, a benchmark material with a Curie temperature of 290 K. For simplicity, the solid density is assumed constant at  $\rho_s = 7900 \text{ kg/m}^3$  and the solid thermal conductivity is set to  $k_s = 10.5 \text{ W/(mK)}$ . The specific heat capacity of Gd is calculated as a function of temperature and magnetic field based on experimental data, using a bi-linear interpolation scheme; more details on the experimental dataset are available in [11].

For the multilayer simulations, alloys of gadolinium and yttrium are used in the form  $\text{Gd}_{1-x}\text{Y}_x$ , where  $x$  is the yttrium fraction. This fraction reduces the Curie temperature of the alloy relative to that of pure gadolinium. Due to the lack of experimental data on the magnetocaloric properties of  $\text{Gd}_{1-x}\text{Y}_x$  alloys at the time this analysis was made, a simpler approach was used in which the [dependence of magnetization, specific heat capacity and entropy with respect to the magnetic field for](#) alloys with a low yttrium fraction are identical to those of pure gadolinium, [but are shifted to a lower](#) Curie temperature (corresponding to the yttrium fraction).

Fabio, veja se o texto acima estah ok...

### 2.1.5 Performance metrics

The AMR model is solved for only one bed, but assumes that the  $N_r$  identical beds experience the same cycle. Thus, the extensive performance parameters are multiplied by that factor.

The cooling capacity is calculated as [11]:

$$\dot{Q}_C = N_r \frac{1}{\tau} \int_{\tau_{HB}} \dot{m}_f(t) c_{p,f} (T_C - T_{f,CE}) dt \quad (17)$$

As pointed out in [citar o paper da ATE - Design trade-offs](#), since external sources of irreversibility (e.g., heat transfer with a finite temperature difference in the heat exchangers) are ignored and no eddy currents and hysteresis losses are present, the magnetic power required to magnetize the solid refrigerant and produce the MCE in the AMR cycle is given by the product of the Carnot efficiency and the cooling capacity as follows:

$$\dot{W}_{\text{mag}} = \dot{Q}_C \frac{T_H - T_C}{T_C} \quad (18)$$

Irreversibility due to fluid friction is accounted for in the calculation of the pumping power:

$$\dot{W}_{\text{pump}} = N_r \frac{1}{\tau} \int_0^\tau \frac{\dot{m}_f}{\rho_f} \Delta P dt \quad (19)$$

where  $\Delta P$  is the total pressure drop through the regenerator.

## 2.2 Hydraulic system and fluid flow profile model

The hydraulic system designed to modulate the fluid flow through different regenerators at different time instants is composed of a pump and a set of electronic valves which can be



precisely controlled to yield the desired blow durations. The electrical power consumed by the valve array is computed separately from other work contributions. An application of electronic valves in AMR devices has been presented by [15].

Fabio, a ultima frase do paragrafo acima nao cabe aqui... quero dizer que a aplicacao deveria ter sido discutida na revisao bibliografica...

In the present analysis, two types of valves are considered. In the first approach, called *Type B valves*, the model proposed in Ref. [16] is used, assuming that the individual consumption of each valve is independent of frequency and blow fraction. The valve power  $\dot{W}_{\text{valve}}$  can be computed as:

da mesma forma, o trabalho [16] tem que constar da revisao bibliografica...

fica estranho o **primeiro** approach ser Type B e o **segundo** ser Type A...

$$\dot{W}_{\text{valve}} = N_v F_B \left( \dot{W}_{\text{valve},n} + \frac{1}{2} \dot{W}_{\text{relay},n} \right) \quad (20)$$

where  $N_v$  is the number of valves,  $\dot{W}_{\text{valve},n}$  is the measured average nominal power for one normally-closed electronic valve and  $\dot{W}_{\text{relay},n}$  is the nominal power for one controlling relay. The factor  $1/2$  is due to two valves being controlled by one relay.

In the second approach, *Type A valves* are used, with nominal power lower in magnitude but which depends on frequency and blow fraction. For these valves, the valve power was experimentally correlated as:

$$\dot{W}_{\text{valve}} [\text{W}] = N_v (0.927f [\text{Hz}] + 1.023F_B + 0.226f [\text{Hz}]F_B - 0.037) \quad (21)$$

A equacao acima precisa ser melhor contextualizada. Talvez os revisores pecam para dar uma descricao minima do experimento. Uma

Equation (21) was correlated for blow fractions of 50 and 100 % and frequencies in the range of 0.2–1.6 Hz, with an uncertainty on the order of 0.4 W for a single valve. The use of different valve types will be discussed among the presented results.

Independent of the valve type used, it is also assumed that each valve system can produce the fluid flow profile shown in Figure 2, where the displaced fluid mass during one blow in one regenerator bed is  $\dot{m}_{f,\max} F_B \tau / 2$ . The *utilization factor* can then be calculated as:

$$\Phi = \frac{\dot{m}_{f,\max} F_B c_s}{2 f m_s c_s} \quad (22)$$

and in all results shown in this work, the number of valves is calculated as:

$$N_v = 2N_r \quad (23)$$

### 2.3 Calculation of the coefficient of performance

The coefficient of performance takes the cooling capacity as the main output parameter from the AMR model, in addition to all previously cited power contributions:

$$\text{COP} = \frac{\dot{Q}_C}{\dot{W}_{\text{pump}} + \dot{W}_{\text{mag}} + \dot{W}_{\text{valve}}} \quad (24)$$

## 3 Results and Discussions

The analysis of magnetic profiles was performed at two different stages. Initially, the instantaneous (square-wave) and the rectified cosine profiles are compared using a simpler approach (i.e., neglecting casing losses). Later, based on the selection of the most promising magnetic profile, a more in-depth analysis is carried out to determine the optimal geometric and operating parameters of the AMR system.

### 3.1 Comparison of instantaneous and rectified cosine profiles using a simplified model

At the first stage of the present analysis, the instantaneous and rectified cosine profiles are compared considering a single-layer regenerator without casing losses, using Type B valves. The parameters used in all simulations are presented in Table 1.

Table 1: AMR parameters kept fixed in the simulations with different magnetic profiles

Fabio, acho que as variaveis nao foram apresentadas na lista de simbolos

Parameter	Value
$D_p$	0.5 mm
$H_r$	20 mm
$W_r$	25 mm
$L_r$	100 mm
$N_r$	11
$N_v$	22
$T_H$	298 K
$T_C$	278 K
$\dot{W}_{NV}$	4 W
$\dot{W}_R$	0.36 W

When comparing the performances resulting from the application of the different magnetic profiles, the same average magnetic field during the hot cycle will be considered; this implies a higher peak for the rectified cosine. For the cold cycle, the minimum values for both profiles are the same, as shown in Figure 5. For reference, in all simulations, the minimum value for the rectified cosine was fixed at  $B_{\min} = 0.1$  T.

Simulations were carried out for various values of blow fraction. The rectified cosine profile can benefit from a smaller blow fractions that concentrate the flow during the periods




Fig. 5: Configuration of average and extreme values of the instantaneous and rectified cosine profiles

of very high and very low fields. In this section, all results use the critical value of blow fraction that maximized the cooling capacity: fluid flowing during the entire period for the instantaneous profile, and only during 60 % of the period (the smallest blow fraction tested) for the cosine profile; this latter case is shown in Figure 6.




Fig. 6: Rectified cosine magnetic profile and the instantaneous flow profile with blow fraction of 60 %

Figure 7 shows the cooling capacity attained by the device at a frequency of 1 Hz and different utilizations. The horizontal axis shows the average field value during the high field

region. The instantaneous profile almost always yields a higher performance, and since the average field during the hot cycle (high field stage) is the same, the main difference is due to the low magnetic field levels. For the “same minimum” comparison, the instantaneous profile is capable of keeping a low magnetic field over the entire half-cycle, which is beneficial for performance; for  $\Phi = 1.0$  and  $B_{\text{high}} = 1.40\text{ T}$ , the cooling capacity for the instantaneous profile is 196.3% higher than for the cosine profile. As demonstrated by [17], a higher average magnetic field during the low-field stage increases the solid temperature and consequently results in warmer fluid entering the cold heat exchanger, representing a thermal loss.




Fig. 7: Cooling capacity as a function of the average high magnetic field, for different utilizations. “IT”: instantaneous (blow fraction of 100 %); “RC”: rectified cosine (blow fraction of 60 %).

The only exception in this comparison is observed for the lowest utilization of  $\Phi = 0.2$ , where the performance is slightly better for the RC profile. Since the blow fraction for the cosine is smaller, the mass flow rate is higher in the latter for the same utilization (cf.

Eq. (12)). This increases the heat transfer rate, as previously explained — outweighing the effects of the magnetic field.

The same analysis, but in terms of the coefficient of performance, is shown in Figure 8, where the instantaneous profile yields better results for medium to high levels of utilization. This is explained by the behavior of the magnetic, valve and pumping power shown in Figure 9 for a fixed utilization of 0.6. As can be seen, the magnetic power only differs between the profiles due to changes in cooling capacity. Also, the valve power is higher for the instantaneous profile since the valves must remain open for longer periods. However, the proportional increase in pumping power, due to larger flow rates, is even higher (than the change in valve power).




Fig. 8: Coefficient of performance as a function of the average high magnetic field, for different values of utilization. “IT”: instantaneous (blow fraction of 100 %); “RC”: rectified cosine (blow fraction of 60 %).

In general, considering target values for the cooling capacity, AMRs operating with the instantaneous magnetic profile lead to better performance results. As can be seen in Fig. 7, an instantaneous profile with the lowest possible value of  $B_{\text{min}}$  and the highest possible value




Fig. 9: Power contributions as functions of the average high magnetic field, for a utilization of 0.6. “IT”: instantaneous (blow fraction of 100 %); “RC”: rectified cosine (blow fraction of 60 %).

of  $B_{\text{max}}$ , with a flow profile occupying the whole cycle with average values of utilization, results in the highest values of cooling capacity among all simulations.

The rectified cosine profile, found in compact systems using Halbach arrays, can surely benefit from reducing the blow fraction, both in terms of cooling capacity and temperature span. However, for the typical parameters evaluated in this paper, even if the blow fraction is optimized for the “RC” profile, the “IT” profile still gives better results.

### 3.1.1 Analysis of the instantaneous profile

As shown in the previous section, the instantaneous profile generally yields the highest values of cooling capacity. Therefore, in this section, a more detailed analysis of this profile is carried out, where the maximum field is varied, but the minimum value is kept at 0.05 T. Figure 10 shows the cooling capacity as a function of the utilization, for several levels of the maximum magnetic field and two different operating frequencies. Because of the conflict

between a low heat transfer rate for flow rates that are too low and losses in regenerator effectiveness in flow rates that are too high, there are critical values of utilization that maximize the cooling capacity, and these critical values increase with the magnetic field. For higher magnetic fields, the increase in the MCE surpasses the loss of effectiveness, and one can go to higher flow rates without losing performance. It can also be seen in Fig. 10 that at higher frequencies the values of cooling power are higher, and also the critical values of utilization are lower. However, this is usually achieved at the expense of a higher power consumption in AMR devices at higher frequencies [18, 19].





(a)  $f = 1 \text{ Hz}$ (b)  $f = 2 \text{ Hz}$ 

Fig. 10: Cooling capacity as a function of utilization, for various values of the high magnetic field for the instantaneous profile





(a) Cooling capacity



(b) Coefficient of performance

Fig. 11: Performance metrics as a function of the regenerator height (all other parameters were set as in Table 1, for utilization factor of 0.4) for various values of the high magnetic field of the instantaneous profile

The geometric parameters in Table 1 were chosen from preliminary simulations, so they are not optimal. To understand the impact of the regenerator geometry on the system performance with the instantaneous profile, the regenerator height was varied in Fig. 11, and all other parameters from Table 1 were kept fixed and with  $\phi = 0.4$ . As expected, higher

magnetic fields allow for smaller regenerators (hence more compact systems) to achieve a desired cooling capacity. For instance, to achieve a capacity of 100 W, increasing the field from 1.0 to 1.2 T results in regenerators that are 36 % smaller. Comparing the results for the cooling capacity and coefficient of performance, the trends are largely the same, as the former is more sensitive to variations in the magnetic field and regenerator height than the components of power.

### 3.2 In-depth analysis of the magnetic ramp profile

Based on the better performance of the instantaneous profile, the ramp profile is a naturally suitable target profile for the design of magnetic refrigerators, and will be analyzed in this section, representing the second stage in the analysis of magnetic profiles.

Moving towards a more realistic model, casing losses are included, using the model from [11]. The bed is enclosed in a solid casing of thickness  $h_{\text{csg}}$ , and two air layers of thickness  $h_{\text{air}}$  separate the AMR and its casing from the inner and outer magnet cylinders, as shown in Figure 12. The optimal design of such magnetic cylinders aiming at a particular magnetic profile will be the subject of future publications.




Fig. 12: Model for the casing losses in regenerators

Preliminary analyses carried out by [20] showed that a stainless steel casing with a thickness of  $h_{\text{csg}} = 0.5 \text{ mm}$  is thick enough to ensure mechanical integrity and easy manufacturing, while being thin enough to accommodate the material with a low thermal conductivity.

In addition, in the present study, an air gap clearance thickness was set at  $h_{\text{air}} = 1 \text{ mm}$ . This value gave rise to a peak in cooling capacity due to the compromise between minimizing losses and maximizing the magnetocaloric mass. The thermophysical properties of stainless steel and air were also obtained with interpolation of tables exported by the EES software [14].

The simulations in this section also use multilayer regenerators. A summary of all parameters adopted in this section, including the Curie temperatures and volumetric fractions (relative to the length of the bed) of each layer is presented in Table 2.

Figure 13 shows the two profiles that will be used in this section and how they are synchronized. Regarding the magnetic profile, the magnitude of the high value will be varied to investigate the performance of the AMR system, while the minimum will be kept at  $B_{\text{min}} = 0.05 \text{ T}$ .




Fig. 13: Comparison between the magnetic ramp profile (solid line) and the instantaneous fluid flow profile (dashed line)

Parameter	Value
$R_o$	40 mm
$W_r$	30 mm
$L_r$	85 mm
$N_r$	8
$N_v$	16
$f$	1 Hz
$T_H$	305.5 K = 32.5 °C
$T_C$	270.5 K = -2.5 °C
$D_p$	350 $\mu$ m
$h_{csg}$	0.5 mm
$h_{air}$	1 mm
Casing material	Stainless steel
Number of layers	3
Curie temperatures of each layer	273, 283, 290 K
Length fractions of each layer	20, 20, 60 %

Table 2: Fixed parameters for the AMR simulations used in this chapter

### 3.2.1 Performance curves for variable blow and magnetization fractions

Figure 14 shows the cooling capacity and coefficient of performance of the AMR system for a fixed utilization factor of 0.4 and for a magnetic profile with a maximum at 1.3 T, for variable blow and magnetization fractions. To facilitate the analysis, the results are plotted in terms of the ratio  $F_M/F_B$ , with curves for different values of  $F_B$ . It is clear that both the cooling capacity and the coefficient of performance exhibit a peak at  $F_M = F_B$ . Moreover, to the right of the peak, i.e., for higher values of  $F_M$ , the reduction of both performance metrics is slower, meaning it is better to have a magnetization plateau that is wider than the fluid flow plateau.

The reduction in performance for  $F_M > F_B$  can be explained by an increase in heat leakage through the casing, as the solid begins to lose energy to the environment when the fluid is not flowing. For  $F_M < F_B$ , the fluid begins to flow when the solid is not totally warmed up, losing effectiveness.




Fig. 14: Performance of the AMR system for various blow and magnetization fractions, utilization of 0.4 and and high magnetic field of 1.3 T

The influence of the utilization is demonstrated in Figure 15, where the cooling capacity is plotted for different utilization factors. For increasing  $\Phi$  in this range, not only do the overall values of cooling capacity increase, but also the importance of choosing the blow fraction becomes clearer. In these ranges of utilization and blow fraction, the cooling capacity increases because the higher transfer rate associated with higher flow rates dominates over the loss of regenerator effectiveness.

The above results can be evaluated from another point of view with Figure 16, where the coefficient of performance is plotted as contour levels. This type of map is useful because, since  $B_{\min}$  and  $\tau$  are fixed, each point in this graph completely characterizes a magnetic ramp profile, and each subplot with fixed  $\Phi$  and  $F_B$  characterizes the fluid flow profile.




Fig. 15: Influence of utilization on the cooling capacity of the AMR system for various blow and magnetization fractions, with high magnetic field of 1.3 T

As expected, the performance increases for the higher values both  $B_{\max}$  and  $F_M$ , where the magnetic ramp profile tends to the instantaneous magnetic profile with a large amplitude. Confirming the previous trends, the results are less sensitive to the magnetization fraction when  $F_M \geq F_B$ .

### 3.2.2 Geometric analysis of the regenerators using the magnetic ramp profile

All previous results assumed a fixed regenerator geometry, with the goal of identifying the optimal fluid and magnetic profile parameters. It became clear that the magnetization fraction should be as large as possible, but that raises some challenges in realizing abrupt changes in the magnetic field. The value of  $F_M = 70\%$  is then chosen as a compromise, with a corresponding  $F_B = F_M$ . The mean value of the utilization factor of  $\Phi = 0.4$  is also chosen as reference in the next results.

Figure 17 shows the cooling capacity, coefficient of performance and second-law efficiency for varying magnetic field and regenerator height. As expected, larger regenerators can produce the desired performance with lower magnetic fields. It can also be seen that




Fig. 16: Influence of utilization and blow fraction on the coefficient of performance of the AMR system for varying high magnetic field and magnetization fraction

this configuration for an AMR system can achieve values of  $\eta_{2nd}$  compatible with conventional vapor compression systems [21, 22], although these numerical results do not include mechanical losses.

#### 4 Conclusions

To the authors' knowledge, this is the first study where magnetic profiles for AMR model are mathematically modeled and the model parameters are changed in a systematic way. The instantaneous (square wave), rectified cosine and ramp magnetic profiles were implemented in an AMR model, and the profile parameters were varied simultaneously with the regenera-




Fig. 17: Performance of the AMR with varying regenerator height and high magnetic field, with fixed  $F_M = F_B = 70\%$  and  $\Phi = 0.4$

tor geometric parameters. These waveforms can be found in existing MR devices published in the literature.

Using a simplified model, the instantaneous profile resulted in a higher cooling capacity, even by reducing the blow fraction on rectified cosine, at least up to levels achieved by pumping and valving systems; further reductions of the blow fraction is mainly restricted by valve opening times. This means that, even if sinusoidal profiles can be obtained with more compact magnetic circuit systems, the performance of magnetic refrigeration systems can be maximized by using instantaneous variations of the magnetic field, and then optimizing the regenerator height and blow duration. Fabio, tive dificuldade em entender o que voce quis concluir neste paragrafo... talvez seja uma boa t

The ramp profile is a feasible approximation for the instantaneous profile without abrupt changes in the magnetic field plateaus. This waveform can be optimized for increasing cooling capacity, in particular by synchronizing the plateau durations between fluid and magnetic profiles. Fabio, acho que seria bom trazer alguns dados quantitativos para ca, tipo ganhos percentuais etc.



## Conflict of Interest Statement

There is no actual or potential conflict of interest including any financial, personal or other relationships with other people or organizations that could inappropriately influence, or be perceived to influence, the present work.

**Acknowledgements** This work was funded by the Brazilian Federal Government (CAPES PTI program, Process no. 88887.194773/2018-00, CNPq Grant no. 443696/2014-4 and EMBRAPPI) and by the State of Santa Catarina (FAPESC/INCT). The authors acknowledge the continuous support from Embraco.

## References

1. Pradeep Bansal, Edward Vineyard, and Omar Abdelaziz. Status of not-in-kind refrigeration technologies for household space conditioning, water heating and food refrigeration. *International Journal of Sustainable Built Environment*, 1:85–101, 2012.
2. IIR. 36th informatory note on refrigeration technologies: Flammable refrigerants. Available at [http://www.iifir.org/userfiles/file/publications/notes/NoteTech\\_36\\_EN\\_nkyix2fcj7.pdf](http://www.iifir.org/userfiles/file/publications/notes/NoteTech_36_EN_nkyix2fcj7.pdf), 2017. Accessed on October 30th, 2018.
3. S. Lionte, M. Risser, C. Vasile, L. Elouad, and C. Muller. Adapting an active magnetic regenerator to a continuous fluid flow application. *International Journal of Refrigeration*, 85:303–313, 2018. doi: 10.1016/j.ijrefrig.2017.10.009.
4. Anders Smith, Christian R. H. Bahl, Rasmus Bjørk, Kurt Engelbrecht, Karpar K. Nielsen, and Nini Pryds. Materials challenges for high performance magnetocaloric refrigeration devices. *Advanced Energy Materials*, 2:1288–1318, 2012.
5. A. Kitanovski, U. Plaznik, J. Tušek, and A. Poredoš. New thermodynamic cycles for magnetic refrigeration. *International Journal of Refrigeration*, 37:28–35, 2014.
6. R. Teyber, P. V. Trevizoli, I. Niknia, T. V. Christiaanse, P. Govindappa, and A. Rowe. Experimental performance investigation of an active magnetic regenerator subject to different fluid flow waveforms. *International Journal of Refrigeration*, 74:38–46, 2017.

7. Alan T. D. Nakashima, Sergio L. Dutra, Paulo V. Trevizoli, and Jader R. Barbosa, Jr. Influence of the flow rate waveform and mass imbalance on the performance of active magnetic regenerators. part I: Experimental analysis. *International Journal of Refrigeration*, 93:236–248, 2018.
8. F. P. Fortkamp, D. Eriksen, K. Engelbrecht, C. R. H. Bahl, J. A. Lozano, and J. R. Barbosa, Jr. Experimental investigation of different fluid flow profiles in a rotary multi-bed active magnetic regenerator device. *International Journal of Refrigeration*, 91:46–54, 2018. doi: 10.1016/j.ijrefrig.2018.04.019.
9. Jaka Tušek, Andrej Kitanovski, Ivan Prebil, and Alojz Poredoš. Dynamic operation of an active magnetic regenerator (AMR): Numerical optimization of a packed-bed AMR. *International Journal of Refrigeration*, 34(6):1507 – 1517, 2011. doi: 10.1016/j.ijrefrig.2011.04.007.
10. R. Bjørk and K. Engelbrecht. The influence of the magnetic field on the performance of an active magnetic regenerator (AMR). *International Journal of Refrigeration*, 34:192–203, 2011. doi: 10.1016/j.ijrefrig.2010.07.004.
11. Paulo V. Trevizoli, Alan T. Nakashima, and Jader R. Barbosa, Jr. Performance evaluation of an active magnetic regenerator for cooling applications – part II: Mathematical modeling and thermal losses. *International Journal of Refrigeration*, 72(206-217), 2016.
12. D. Eriksen, K. Engelbrecht, C. R. H. Bahl, R. Bjørk, and K. K. Nielsen. Effects of flow balancing on active magnetic regenerator performance. *Applied Thermal Engineering*, 103:1–8, 2016.
13. K. K. Nielsen, J. Tusek, K. Engelbrecht, S. Schopfer, A. Kitanovski, C. R. H. Bahl, A. Smith, N. Pryds, and A. Poredos. Review on numerical modeling of active magnetic regenerators for room-temperature applications. *International Journal of Refrigeration*, 34:603–616, 2011.
14. S. A. Klein. EES — Engineering Equation Solver, Professional Version v9.339. F-Chart Software, 2013. Available at <http://fchart.com>.
15. Alan T. D. Nakashima, Sergio L. Dutra, Gislaine Hoffmann, Jaime A. Lozano, and Jader R. Barbosa, Jr. Performance assessment of solenoid valves as flow distributors for an active magnetic regenerator. In *Proceedings of the 8th International Conference on Caloric Cooling (Thermag VIII)*, Darmstadt, Germany, 2018.
16. Pedro Oliveira Cardoso, Mário Cesar Destro, Manoel Guidi Alvarez, Jaime Andrés Lozano, Jader Riso Barbosa, Jr., and Victor Juliano de Negri. Transient model and energy assessment of a digital solenoid valve system for a magnetic refrigerator. In *Proceedings of the 16th Brazilian Congress of Thermal Sciences and Engineering*, Vitória, 2016.

17. Paulo V. Trevizoli, Jader R. Barbosa, Jr., Armando Tura, Daniel Arnold, and Andrew Rowe. Modeling of thermomagnetic phenomena in active magnetocaloric regenerators. *Journal of Thermal Science and Engineering Applications*, 6, 2014.
18. Tian Lei, Kurt Engelbrecht, Kaspar K. Nielsen, and Christian T. Veje. Study of geometries of active magnetic regenerators for room temperature magnetocaloric refrigeration. *Applied Thermal Engineering*, 111:1232–1243, 2017.
19. I. Niknia, O. Campbell, T. V. Christiaanse, P. Govindappa, R. Teyber, P. V. Trevizoli, and A. Rowe. Impacts of configuration losses on active magnetic regenerator device performance. *Applied Thermal Engineering*, 106:601 – 612, 2016. doi: 10.1016/j.applthermaleng.2016.06.039.
20. G. F. Peixer, J. A. Lozano, and J. R. Barbosa, Jr. Performance evaluation of AMRs using different casings. Book of Abstracts for the Danish Days on Caloric Materials and Devices, 2017.
21. Christian J. L. Hermes and Cláudio Melo. A first-principles simulation model for the start-up and cycling transients of household refrigerators. *International Journal of Refrigeration*, 31(8):1341 – 1357, 2008. doi: 10.1016/j.ijrefrig.2008.04.003,.
22. Cezar O. R. Negrão and Christian J. L. Hermes. Energy and cost savings in household refrigerating appliances: A simulation-based design approach. *Applied Energy*, 88(9):3051 – 3060, 2011. doi: 10.1016/j.apenergy.2011.03.013.