



**Job No.:** Hayden Ryan - 2**Address:** 345 Perth RD, Okato, New Zealand**Date:** 25/09/2024**Latitude:** -39.152386**Longitude:** 173.866923**Elevation:** 37.5 m**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5.7 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	41.95 m/s
Wind Pressure	1.06 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Gable Enclosed

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 5.7 m  $C_{p,e} = -0.9$   $p_e = -0.86$  KPa  $p_{net} = -0.86$  KPa

For roof  $C_{p,e}$  from 5.7 m To 11.41 m  $C_{p,e} = -0.5$   $p_e = -0.48$  KPa  $p_{net} = -0.48$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 12 m  $C_{p,e} = 0.7$   $p_e = 0.67$  KPa  $p_{net} = 0.99$  KPa

For side wall  $C_{p,e}$  from 0 m To 5.7 m  $C_{p,e} =$   $p_e = -0.62$  KPa  $p_{net} = -0.62$  KPa

Maximum Upward pressure used in roof member Design = 0.86 KPa

Maximum Downward pressure used in roof member Design = 0.51 KPa

Maximum Wall pressure used in Design = 0.99 KPa

Maximum Racking pressure used in Design = 0.96 KPa

**Design Summary****Girt Design Front and Back**

Girt's Spacing = 0 mm

Girt's Span = 4800 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.75 S1 Downward = 11.27 S1 Upward = 18.41

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	2.79 Kn-m	Passing Percentage	Infinity %
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	16.08 Kn	Passing Percentage	Infinity %

**Deflections**

Pole Shed App Ver 01 2022

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.00 mm

Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Sag during installation = 32.19 mm

**Reactions**

Maximum = 0.00 kn

**Girt Design Sides**

Girt's Spacing = 0 mm

Girt's Span = 3000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.64   S1 Downward =11.27   S1 Upward =20.58

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>Wind+Snow</sub>	0.00 Kn-m	Capacity	2.40 Kn-m	Passing Percentage	<b>Infinity %</b>
V <sub>0.9D-WnUp</sub>	0.00 Kn	Capacity	16.08 Kn	Passing Percentage	<b>Infinity %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.00 mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =4.91 mm

**Reactions**

Maximum = 0.00 kn

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	5550 mm
Area	35448 mm <sup>2</sup>	As	26585.7421875 mm <sup>2</sup>
I <sub>x</sub>	100042702 mm <sup>4</sup>	Z <sub>x</sub>	941578 mm <sup>3</sup>
I <sub>y</sub>	100042702 mm <sup>4</sup>	Z <sub>y</sub>	941578 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 14.4 m<sup>2</sup>

Dead	3.60 Kn	Live	3.60 Kn
Wind Down	7.34 Kn	Snow	0.00 Kn
Moment Wind	9.33 Kn-m		
Phi	0.8	K8	0.42

K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

**Capacities**

PhiNcx Wind	216.55 Kn	PhiMnx Wind	11.60 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	129.93 Kn	PhiMnx Dead	6.96 Kn-m	PhiVnx Dead	37.77 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.87 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.71 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 45.89 \text{ mm} < 56.86 \text{ mm}$$

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	4275 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

$$\text{Total Area over Pole} = 14.4 \text{ m}^2$$

Moment Wind =	9.33 Kn-m
Shear Wind =	2.18 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	4.31 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.60 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

$$\text{Applied Forces/Capacities} = 0.88 < 1 \text{ OK}$$

**Drained Lateral Strength of End pile in cohesionless soils Free Head short pile****Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

**Geometry For End Bay Pole**

Ds =	0.6 mm	Pile Diameter
------	--------	---------------

Pole Shed App Ver 01 2022

L =	1400 mm	Pile embedment length
f1 =	4275 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	9.33 Kn-m
Shear Wind =	2.18 Kn

**Pile Properties**

Safety Factor	0.55	
Hu =	4.31 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.60 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities =  $0.88 < 1$  OK

**Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1900) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1900)

Skin Friction = 29.16 Kn

Weight of Pile + Pile Skin Friction = 32.97 Kn

Uplift on one Pile = 18.29 Kn

Uplift is ok