

**Job No.:** Taupo Motor Sport Park - 1      **Address:** 463 Broadlands Road, Taupo, New Zealand      **Date:** 16/01/2024  
**Latitude:** -38.6608      **Longitude:** 176.144612      **Elevation:** 453 m

### General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	39.49 m/s
Wind Pressure	0.94 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

### Pressure Coefficients and Pressures

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6496$

For roof  $C_{p,e}$  from 0 m To 3.50 m  $C_{p,e} = -0.90$   $p_e = -0.58$  KPa  $p_{net} = -1.08$  KPa

For roof  $C_{p,e}$  from 3.50 m To 7.0 m  $C_{p,e} = -0.5$   $p_e = -0.32$  KPa  $p_{net} = -0.82$  KPa

For wall Windward  $C_{p,i} = 0.6496$  side Wall  $C_{p,i} = -0.2568$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 10 m  $C_{p,e} = 0.7$   $p_e = 0.59$  KPa  $p_{net} = 1.09$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.50 m  $C_{p,e} =$   $p_e = -0.55$  KPa  $p_{net} = -0.05$  KPa

Maximum Upward pressure used in roof member Design = 1.08 KPa

Maximum Downward pressure used in roof member Design = 0.69 KPa

Maximum Wall pressure used in Design = 1.09 KPa

Maximum Racking pressure used in Design = 1.01 KPa

### Design Summary

#### Intermediate Design Sides

Intermediate Spacing = 3333.3333333333335 mm      Intermediate Span = 3725 mm      Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 11.27    S1 Upward = 0.73

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

$M_{Wind+Snow}$	3.15 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	<b>236.83 %</b>
$V_{0.9D-WnUp}$	3.38 Kn-m	Capacity	32.16 Kn-m	Passing Percentage	<b>951.48 %</b>

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.295 mm

Limit by Woolcock et al, 1999 Span/100 = 37.25 mm

**Reactions**

Maximum = 3.38 kn

**Girt Design Front and Back**

Girt's Spacing = 600 mm

Girt's Span = 2000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.92    S1 Downward =9.63    S1 Upward =14.36

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	0.33 Kn-m	Capacity	1.94 Kn-m	Passing Percentage	<b>587.88 %</b>
$V_{0.9D-WnUp}$	0.65 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	<b>1855.38 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 1.45 mm

Limit by Woolcock et al, 1999 Span/100 = 20.00 mm

Sag during installation = 0.97 mm

**Reactions**

Maximum = 0.65 kn

**Girt Design Sides**

Girt's Spacing = 900 mm

Girt's Span = 3333 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.74    S1 Downward =9.63    S1 Upward =18.54

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

$M_{Wind+Snow}$	1.36 Kn-m	Capacity	1.56 Kn-m	Passing Percentage	<b>114.71 %</b>
$V_{0.9D-WnUp}$	1.64 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	<b>735.37 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 16.74 mm

Limit by Woolcock et al. 1999 Span/100 = 33.33 mm

Sag during installation = 7.49 mm

#### **Reactions**

Maximum = 1.64 kn

#### **Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil (18) x Height of Pile (1550) x Ks (1.5) x 0.5 x tan(30) x Pi x Dia of Pile (0.6) x Height of Pile (1550)

Skin Friction = 19.40 Kn

Weight of Pile + Pile Skin Friction = 23.43 Kn

Uplift on one Pile = 17.10 Kn

Uplift is ok