<u>Pole Shed App Ver 01 2022</u>

Job No.: 608670	**Address:** Lot 3 Waikare Rd, Kawakawa, New Zealand	**Date:** 10/5/2023
Latitude: -35.364086	**Longitude:** 174.091933	**Elevation:** 10.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ1	Terrain Category	2.0	Design Wind Speed	40.67 m/s
Wind Pressure	0.99 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Open

For roof Cp,i = 0.6577

For roof CP,e from 0 m To 3.40 m Cpe = -0.9 pe = -0.78 KPa pnet = -1.47 KPa

For roof CP,e from 3.40 m To 6.80 m Cpe = -0.5 pe = -0.43 KPa pnet = -1.12 KPa

For wall Windward Cp,i = 0.6577 side Wall Cp,i = -0.5715

For wall Windward and Leeward CP,e from 0 m To 7.20 m Cpe = 0.7 pe = 0.63 KPa pnet = 1.16 KPa

For side wall CP,e from 0 m To 3.40 m Cpe = pe = -0.58 KPa pnet = -0.05 KPa

Maximum Upward pressure used in roof member Design = 1.47 KPa

Maximum Downward pressure used in roof member Design = 0.71 KPa

Maximum Wall pressure used in Design = 1.16 KPa

Maximum Racking pressure used in Design = 1.08 KPa

Design Summary

Purlin Design

Purlin Spacing = 700 mm	Purlin Span = 4650 mm	Try Purlin 300x50 SG8 Dry

Pole Shed App Ver 01 2022

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.94

K8 Upward =0.30 S1 Downward =13.93 S1 Upward =31.50

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.64 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	**737.50 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.91 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	**329.84 %**
$M_{0.9D-WnUp}$	-2.36 Kn-m	Capacity	-2.48 Kn-m	Passing Percentage	**105.08 %**
$V_{1.35D}$	0.55 Kn	Capacity	14.47 Kn	Passing Percentage	**2630.91 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.64 Kn	Capacity	19.30 Kn	Passing Percentage	**1176.83 %**
$V_{0.9D-WnUp}$	-2.03 Kn	Capacity	-24.12 Kn	Passing Percentage	**1188.18 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 3.25 mm	Limit by Woolcock et al, 1999 Span/240 = 19.17 mm
Deflection under Dead and Service Wind = 4.63 mm	Limit by Woolcock et al, 1999 Span/100 = 46.00 mm

Reactions

Maximum downward =1.64 kn Maximum upward = -2.03 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4800 mm Internal Rafter Span = 7050 mm Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =8.40 S1 Upward =8.40

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Second page

$M_{1.35D}$	10.06 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	**431.81 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	30.12 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	**192.30 %**
$M_{0.9D-WnUp}$	-37.13 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	**195.04 %**
$V_{1.35D}$	5.71 Kn	Capacity	55.22 Kn	Passing Percentage	**967.08 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	17.09 Kn	Capacity	73.64 Kn	Passing Percentage	**430.90 %**
$V_{0.9D-WnUp}$	-21.07 Kn	Capacity	-92.04 Kn	Passing Percentage	**436.83 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 11.78 mm Limit by Woolcock et al, 1999 Span/240 = 30.00 mm
Deflection under Dead and Service Wind = 18.655 mm Limit by Woolcock et al, 1999 Span/100 = 72.00 mm

Reactions

Maximum downward =17.09 kn Maximum upward = -21.07 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -21.07 Kn

Rafter Design External

External Rafter Load Width = 2400 mm External Rafter Span = 7011 mm Try Rafter 360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.81

K8 Upward =0.81 S1 Downward =17.01 S1 Upward =17.01

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	4.98 Kn-m	Capacity	17.70 Kn-m	Passing Percentage	**355.42 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	14.89 Kn-m	Capacity	23.60 Kn-m	Passing Percentage	**158.50 %**
$M_{0.9D-WnUp}$	-18.36 Kn-m	Capacity	-29.50 Kn-m	Passing Percentage	**160.68 %**
$V_{1.35D}$	2.84 Kn	Capacity	27.61 Kn	Passing Percentage	**972.18 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	8.50 Kn	Capacity	36.82 Kn	Passing Percentage	**433.18 %**
$V_{0.9D-WnUp}$	-10.47 Kn	Capacity	-46.02 Kn	Passing Percentage	**439.54 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 13.09 mm	Limit by Woolcock et al, 1999 Span/240= 30.00 mm
Deflection under Dead and Service Wind = 18.65 mm	Limit by Woolcock et al, 1999 Span/100 = 72.00 mm

Reactions

Maximum downward =8.50 kn Maximum upward = -10.47 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -50.09 kn > -10.47 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -10.47 Kn

Intermediate Design Sides

Intermediate Spacing = 3600 mm   Intermediate Span = 3250 mm   Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =11.27   S1 Upward =0.68

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.76 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	**270.29 %**
$V_{0.9D-WnUp}$	3.39 Kn-m	Capacity	32.16 Kn-m	Passing Percentage	**948.67 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 29.925 mm   Limit by Woolcock et al, 1999 Span/100 = 32.50 mm

Reactions

Maximum = 3.39 kn

Girt Design Front and Back

Girt's Spacing = 800 mm   Girt's Span = 4800 mm   Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.75   S1 Downward =11.27   S1 Upward =18.41

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.67 Kn-m	Capacity	2.79 Kn-m	Passing Percentage	**104.49 %**

$V_{0.9D\text{-}WnUp}$	2.23 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	**721.08 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 44.32 mm Limit by Woolcock et al, 1999 Span/100 = 48.00 mm
Sag during installation = 32.19 mm

Reactions

Maximum = 2.23 kn

Girt Design Sides

Girt's Spacing = 1200 mm Girt's Span = 3600 mm Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.55 S1 Downward =11.27 S1 Upward =22.54

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	2.26 Kn-m	Capacity	2.06 Kn-m	Passing Percentage	**91.15 %**
$V_{0.9D\text{-}WnUp}$	2.51 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	**640.64 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 21.03 mm Limit by Woolcock et al. 1999 Span/100 = 36.00 mm
Sag during installation =10.18 mm

Reactions

Maximum = 2.51 kn

Middle Pole Design

Geometry

Pole Shed App Ver 01 2022

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3240 mm
Area	35448 mm2	As	26585.7421875 mm2
Ix	100042702 mm4	Zx	941578 mm3
Iy	100042702 mm4	Zx	941578 mm3
Lateral Restraint	3400 mm c/c		

Loads

Total Area over Pole = 17.28 m2

Dead	4.32 Kn	Live	4.32 Kn
Wind Down	12.27 Kn	Snow	10.89 Kn
Moment wind	12.57 Kn-m	Moment snow	3.88 Kn-m
Phi	0.8	K8	0.86
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	438.78 Kn	PhiMnx Wind	23.50 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	263.27 Kn	PhiMnx Dead	14.10 Kn-m	PhiVnx Dead	37.77 Kn
PhiNcx Snow	351.02 Kn	PhiMnx Snow	18.80 Kn-m	PhiVnx Snow	50.36 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.59 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.34 < 1 OK

Deflection at top under service lateral loads = 22.24 mm < 32.40 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3

K0 =	(1-sin(30)) / (1+sin(30))
Kp =	(1+sin(30)) / (1-sin(30))

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	12.57 Kn-m	Moment Snow =	Kn-m
Shear Wind =	4.65 Kn	Shear Snow =	3.88 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.96 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.63 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 1.31 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3240 mm
Area	35448 mm2	As	26585.7421875 mm2
Ix	100042702 mm4	Zx	941578 mm3
Iy	100042702 mm4	Zx	941578 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 17.28 m2

Dead	4.32 Kn	Live	4.32 Kn
Wind Down	12.27 Kn	Snow	10.89 Kn
Moment Wind	6.28 Kn-m	Moment snow	1.94 Kn-m

Pole Shed App Ver 01 2022

Phi	0.8	K8	0.89
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	454.61 Kn	PhiMnx Wind	24.35 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	272.77 Kn	PhiMnx Dead	14.61 Kn-m	PhiVnx Dead	37.77 Kn
PhiNcx Snow	363.69 Kn	PhiMnx Snow	19.48 Kn-m	PhiVnx Snow	50.36 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.31 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.12 < 1 OK

Deflection at top under service lateral loads = 12.32 mm < 35.91 mm

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 17.28 m2

Moment Wind =	6.28 Kn-m	Moment Snow =	1.94 Kn-m
Shear Wind =	2.33 Kn	Shear Snow =	1.94 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.96 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.63 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.65 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2700 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	6.28 Kn-m	Moment Snow =	1.94 Kn-m
Shear Wind =	2.33 Kn	Shear Snow =	1.94 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.96 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.63 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.65 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.47 Kn

Uplift on one Pile = 21.51 Kn

Uplift is ok

Last Page