



Pole Shed App Ver 01 2022

**Job No.:** 446-276266

**Address:** Lot 1 DP 401501, Wards Road, Charing  
Cross, New Zealand

**Date:** 3/4/2025

**Latitude:** -43.537451

**Longitude:** 172.144285

**Elevation:** 156.5 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	0.92 KPa	Roof Snow Load	0.65 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.2 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	38.22 m/s
Wind Pressure	0.88 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6543$

For roof  $C_{p,e}$  from 0 m To 3.95 m  $C_{p,e} = -0.9$   $p_e = -0.55$  KPa  $p_{net} = -1.03$  KPa

For roof  $C_{p,e}$  from 3.95 m To 7.90 m  $C_{p,e} = -0.5$   $p_e = -0.31$  KPa  $p_{net} = -0.79$  KPa

For wall Windward  $C_{p,i} = 0.6543$  side Wall  $C_{p,i} = -0.5651$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 13.59 m  $C_{p,e} = 0.7$   $p_e = 0.55$  KPa  $p_{net} = 1.09$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.95 m  $C_{p,e} =$   $p_e = -0.51$  KPa  $p_{net} = 0.03$  KPa

Maximum Upward pressure used in roof member Design = 1.03 KPa

Maximum Downward pressure used in roof member Design = 0.70 KPa

Maximum Wall pressure used in Design = 1.09 KPa

Maximum Racking pressure used in Design = 0.94 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 800 mm

Purlin Span = 4380 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

### Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 0.79    S1 Downward = 11.27    S1 Upward = 17.48

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	0.65 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	<b>343.08 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	2.38 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	<b>124.79 %</b>
M <sub>0.9D-WnUp</sub>	-1.54 Kn-m	Capacity	-2.96 Kn-m	Passing Percentage	<b>192.21 %</b>
V <sub>1.35D</sub>	0.59 Kn	Capacity	9.65 Kn	Passing Percentage	<b>1635.59 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	1.75 Kn	Capacity	12.86 Kn	Passing Percentage	<b>734.86 %</b>
V <sub>0.9D-WnUp</sub>	-1.41 Kn	Capacity	-16.08 Kn	Passing Percentage	<b>1140.43 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 16.53 mm    Limit by Woolcock et al, 1999 Span/240 = 18.04 mm

Deflection under Dead and Service Wind = 13.94 mm    Limit by Woolcock et al, 1999 Span/100 = 43.30 mm

#### **Reactions**

Maximum downward = 1.75 kn    Maximum upward = -1.41 kn

Number of Blocking = 1    if 0 then no blocking required, if 1 then one midspan blocking required

#### **Rafter Design Internal**

Internal Rafter Load Width = 4530 mm    Internal Rafter Span = 8850 mm    Try Rafter 2x360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 5.90    S1 Upward = 5.90

Shear Capacity of timber = 5.3 MPa    Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	14.97 Kn-m	Capacity	60.82 Kn-m	Passing Percentage	<b>406.28 %</b>
M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	44.35 Kn-m	Capacity	81.1 Kn-m	Passing Percentage	<b>182.86 %</b>

Pole Shed App Ver 01 2022

M <sub>0.9D-WnUp</sub>	-35.70 Kn-m	Capacity	-101.38 Kn-m	Passing Percentage	<b>283.98 %</b>
V <sub>1.35D</sub>	6.77 Kn	Capacity	77.32 Kn	Passing Percentage	<b>1142.10 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	20.05 Kn	Capacity	103.08 Kn	Passing Percentage	<b>514.11 %</b>
V <sub>0.9D-WnUp</sub>	-16.14 Kn	Capacity	-128.86 Kn	Passing Percentage	<b>798.39 %</b>

**Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 19.39 mm      Limit by Woolcock et al, 1999 Span/240 = 37.50 mm

Deflection under Dead and Service Wind = 30.52 mm      Limit by Woolcock et al, 1999 Span/100 = 90.00 mm

**Reactions**

Maximum downward = 20.05 kn    Maximum upward = -16.14 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -16.14 Kn

**Rafter Design External**

External Rafter Load Width = 2265 mm      External Rafter Span = 2805 mm      Try Rafter 360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K<sub>1</sub> Short term = 1    K<sub>1</sub> Medium term = 0.8    K<sub>1</sub> Long term = 0.6    K<sub>4</sub> = 1    K<sub>5</sub> = 1    K<sub>8</sub> Downward = 0.98

Pole Shed App Ver 01 2022

K8 Upward =0.98    S1 Downward =12.10    S1 Upward =12.10

Shear Capacity of timber =5.3 MPa    Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>1.35D</sub>	0.75 Kn-m	Capacity	29.91 Kn-m	Passing Percentage	<b>3988.00 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	2.23 Kn-m	Capacity	39.88 Kn-m	Passing Percentage	<b>1788.34 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-1.79 Kn-m	Capacity	-49.85 Kn-m	Passing Percentage	<b>2784.92 %</b>
V <sub>1.35D</sub>	1.07 Kn	Capacity	38.66 Kn	Passing Percentage	<b>3613.08 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	3.18 Kn	Capacity	51.54 Kn	Passing Percentage	<b>1620.75 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-2.56 Kn	Capacity	-64.43 Kn	Passing Percentage	<b>2516.80 %</b>

**Deflections**

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 0.27 mm      Limit by Woolcock et al, 1999 Span/240= 12.50 mm

Deflection under Dead and Service Wind = 0.38 mm      Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

**Reactions**

Maximum downward =3.18 kn    Maximum upward = -2.56 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 12.6 f<sub>pj</sub> = 22.7 Mpa for Rafter with effective thickness = 63 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 f<sub>cj</sub> = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k<sub>1</sub> x k<sub>4</sub> x k<sub>5</sub> x f<sub>s</sub> x b x d<sub>s</sub> ..... (Eq 4.12) = -70.12 kn > -2.56 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -2.56 Kn

### Intermediate Design Front and Back

Intermediate Spacing = 2265 mm      Intermediate Span = 3550 mm      Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1      K4 = 1      K5 = 1      K8 Downward = 1.00

K8 Upward = 1.00      S1 Downward = 11.27      S1 Upward = 0.71

Shear Capacity of timber = 3 MPa      Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>Wind+Snow</sub>	3.89 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	<b>191.77 %</b>
V <sub>0.9D-WnUp</sub>	4.38 Kn	Capacity	-32.16 Kn	Passing Percentage	<b>734.25 %</b>

#### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 26.15 mm      Limit by Woolcock et al, 1999 Span/100 = 35.50 mm

#### Reactions

Maximum = 4.38 kn

### Girt Design Front and Back

Girt's Spacing = 1300 mm      Girt's Span = 2265 mm      Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1      K4 = 1      K5 = 1      K8 Downward = 1.00

K8 Upward = 0.89      S1 Downward = 9.63      S1 Upward = 15.28

Shear Capacity of timber = 3 MPa      Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>Wind+Snow</sub>	0.91 Kn-m	Capacity	1.87 Kn-m	Passing Percentage	<b>205.49 %</b>
V <sub>0.9D-WnUp</sub>	1.60 Kn	Capacity	12.06 Kn	Passing Percentage	<b>753.75 %</b>

#### Deflections

### Pole Shed App Ver 01 2022

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.23 mm Limit by Woolcock et al, 1999 Span/100 = 22.65 mm

Sag during installation = 1.60 mm

#### **Reactions**

Maximum = 1.60 kn

#### **Girt Design Sides**

Girt's Spacing = 1300 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.79 S1 Downward = 9.63 S1 Upward = 17.59

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>Wind+Snow</sub>	1.59 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	<b>103.77 %</b>
V <sub>0.9D-WnUp</sub>	2.13 Kn	Capacity	12.06 Kn	Passing Percentage	<b>566.20 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.32 mm Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation = 4.91 mm

#### **Reactions**

Maximum = 2.13 kn

#### **Middle Pole Design**

##### **Geometry**

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3900 mm
Area	35448 mm <sup>2</sup>	As	26585.7421875 mm <sup>2</sup>
I <sub>x</sub>	100042702 mm <sup>4</sup>	Z <sub>x</sub>	941578 mm <sup>3</sup>

Pole Shed App Ver 01 2022

Iy 100042702 mm<sup>4</sup> Zx 941578 mm<sup>3</sup>  
Lateral Restraint 1300 mm c/c

**Loads**

Total Area over Pole = 20.385 m<sup>2</sup>

Dead	5.10 Kn	Live	5.10 Kn
Wind Down	14.27 Kn	Snow	13.25 Kn
Moment wind	14.05 Kn-m	Moment snow	4.37 Kn-m
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

**Capacities**

PhiNcx Wind	510.45 Kn	PhiMnx Wind	27.34 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	306.27 Kn	PhiMnx Dead	16.41 Kn-m	PhiVnx Dead	37.77 Kn
PhiNcx Snow	408.36 Kn	PhiMnx Snow	21.87 Kn-m	PhiVnx Snow	50.36 Kn

**Checks**

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.57 < 1$  OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.32 < 1$  OK

Deflection at top under service lateral loads = 34.91 mm < 39.00 mm

**Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma 18 Kn/m<sup>3</sup> Friction angle 30 deg Cohesion 0 Kn/m<sup>3</sup>  
K0 =  $(1 - \sin(30)) / (1 + \sin(30))$   
Kp =  $(1 + \sin(30)) / (1 - \sin(30))$

**Geometry For Middle Bay Pole**



Pole Shed App Ver 01 2022

Ds =	0.6 mm	Pile Diameter
L =	1700 mm	Pile embedment length
f1 =	3150 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	14.05 Kn-m	Moment Snow =	Kn-m
Shear Wind =	4.46 Kn	Shear Snow =	4.37 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	9.03 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	17.07 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities = 0.82 < 1 OK

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3840 mm
Area	27598 mm <sup>2</sup>	As	20698.2421875 mm <sup>2</sup>
Ix	60639381 mm <sup>4</sup>	Zx	646820 mm <sup>3</sup>
Iy	60639381 mm <sup>4</sup>	Zx	646820 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 6.795 m<sup>2</sup>

Dead	1.70 Kn	Live	1.70 Kn
Wind Down	4.76 Kn	Snow	4.42 Kn
Moment Wind	3.51 Kn-m	Moment snow	1.09 Kn-m
Phi	0.8	K8	0.65
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

**Material**

Pole Shed App Ver 01 2022

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

**Capacities**

PhiNcx Wind	257.07 Kn	PhiMnx Wind	12.15 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	154.24 Kn	PhiMnx Dead	7.29 Kn-m	PhiVnx Dead	29.41 Kn
PhiNcx Snow	205.65 Kn	PhiMnx Snow	9.72 Kn-m	PhiVnx Snow	39.21 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.32 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.12 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 15.47 \text{ mm} < 41.90 \text{ mm}$$

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	3150 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

$$\text{Total Area over Pole} = 6.795 \text{ m}^2$$

Moment Wind =	3.51 Kn-m	Moment Snow =	1.09 Kn-m
Shear Wind =	1.11 Kn	Shear Snow =	1.09 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	5.37 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.97 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

$$\text{Applied Forces/Capacities} = 0.35 < 1 \text{ OK}$$

**Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Pole Shed App Ver 01 2022

Gamma 18 Kn/m<sup>3</sup> Friction angle 30 deg Cohesion 0 Kn/m<sup>3</sup>  
 $K_0 = (1 - \sin(30)) / (1 + \sin(30))$   
 $K_p = (1 + \sin(30)) / (1 - \sin(30))$

**Geometry For End Bay Pole**

Ds = 0.6 mm Pile Diameter  
L = 1400 mm Pile embedment length  
f1 = 3150 mm Distance at which the shear force is applied  
f2 = 0 mm Distance of top soil at rest pressure

**Loads**

Moment Wind = 3.51 Kn-m Moment Snow = 1.09 Kn-m  
Shear Wind = 1.11 Kn Shear Snow = 1.09 Kn

**Pile Properties**

Safety Factor 0.55  
Hu = 5.37 Kn Ultimate Lateral Strength of the Pile, Short pile  
Mu = 9.97 Kn-m Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities = 0.35 < 1 OK

**Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast in place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1700) x Ks(1.5) x  $0.5 \times \tan(30)$  x Pi x Dia of Pile(0.6) x Height of Pile(1700)

Skin Friction = 23.34 Kn

Weight of Pile + Pile Skin Friction = 27.76 Kn

Uplift on one Pile = 16.41 Kn

Uplift is ok

