First Page

Job No.: 2405053 - 2   **Address:** 270 Mt Heslington Road, Brightwater, New Zealand   **Date:** 22/07/2024

Latitude: -41.403304   **Longitude:** 173.101144   **Elevation:** 82 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	40.91 m/s
Wind Pressure	1 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof $C_{p,i}$ = -0.3

For roof $C_{P,e}$ from 0 m To 2.67 m Cpe = -0.9272   pe = -0.84 KPa   pnet = -0.84 KPa

For roof $C_{P,e}$ from 2.67 m To 5.34 m Cpe = -0.8864   pe = -0.80 KPa   pnet = -0.80 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward $C_{P,e}$ from 0 m To 19.6 m Cpe = 0.7 pe = 0.63 KPa   pnet = 0.63 KPa

For side wall $C_{P,e}$ from 0 m To 5.34 m Cpe =   pe = -0.59 KPa   pnet = -0.59 KPa

Maximum Upward pressure used in roof member Design = 0.84 KPa

Maximum Downward pressure used in roof member Design = 0.28 KPa

Maximum Wall pressure used in Design = 0.63 KPa

Maximum Racking pressure used in Design = 0.91 KPa

Design Summary

Purlin Design

 Purlin Spacing = 700 mm   Purlin Span = 4990 mm   Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.42   S1 Downward =11.27   S1 Upward =26.41

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.74 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	**301.35 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.03 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	**146.31 %**
$M_{0.9D-WnUp}$	-1.34 Kn-m	Capacity	-1.55 Kn-m	Passing Percentage	**115.67 %**
$V_{1.35D}$	0.59 Kn	Capacity	9.65 Kn	Passing Percentage	**1635.59 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.18 Kn	Capacity	12.86 Kn	Passing Percentage	**1089.83 %**
$V_{0.9D-WnUp}$	-1.07 Kn	Capacity	-16.08 Kn	Passing Percentage	**1502.80 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 14.58 mm   Limit by Woolcock et al, 1999 Span/240 = 20.58 mm

Deflection under Dead and Service Wind = 15.56 mm   Limit by Woolcock et al, 1999 Span/100 = 49.40 mm

Reactions

Maximum downward =1.18 kn   Maximum upward = -1.07 kn

Number of Blocking = 0   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 5140 mm   Internal Rafter Span = 5650.017755156393 mm   Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =6.81   S1 Upward =6.81

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	6.92 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	**145.66 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	13.84 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	**97.11 %**
$M_{0.9D-WnUp}$	-12.61 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	**133.23 %**
$V_{1.35D}$	4.90 Kn	Capacity	28.94 Kn	Passing Percentage	**590.61 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	9.80 Kn	Capacity	38.6 Kn	Passing Percentage	**393.88 %**
$V_{0.9D-WnUp}$	-8.93 Kn	Capacity	-48.24 Kn	Passing Percentage	**540.20 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 16.83 mm   Limit by Woolcock et al, 1999 Span/240 = 24.17 mm

Deflection under Dead and Service Wind = 19.95 mm   Limit by Woolcock et al, 1999 Span/100 = 58.00 mm

Reactions

Maximum downward =9.80 kn   Maximum upward = -8.93 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K11 = 14.9$ fpj = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

$K11 = 2.0$ fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 21.67 Kn > -8.93 Kn

Rafter Design External

External Rafter Load Width = 2570 mm   External Rafter Span = 5815 mm   Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.94

K8 Upward =0.94   S1 Downward =13.93   S1 Upward =13.93

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.67 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	**128.61 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	7.33 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	**85.95 %**
$M_{0.9D-WnUp}$	-6.68 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	**117.81 %**
$V_{1.35D}$	2.52 Kn	Capacity	14.47 Kn	Passing Percentage	**574.21 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	5.04 Kn	Capacity	19.30 Kn	Passing Percentage	**382.94 %**
$V_{0.9D-WnUp}$	-4.60 Kn	Capacity	-24.12 Kn	Passing Percentage	**524.35 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 18.70 mm   Limit by Woolcock et al, 1999 Span/240= 24.17 mm
Deflection under Dead and Service Wind = 19.95 mm   Limit by Woolcock et al, 1999 Span/100 = 58.00 mm

Reactions

Maximum downward =5.04 kn   Maximum upward = -4.60 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K11 = 14.9$ fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

$K11 = 2.0$ fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

$V = phi \times k1 \times k4 \times k5 \times fs \times b \times ds$ .... (Eq 4.12) = -25.20 kn > -4.60 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -4.60 Kn

Intermediate Design Front and Back

Intermediate Spacing = 2570 mm   Intermediate Span = 754 mm   Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =9.63   S1 Upward =0.28

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.12 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	**3500.00 %**
$V_{0.9D-WnUp}$	0.61 Kn	Capacity	-24.12 Kn	Passing Percentage	**3954.10 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.045 mm   Limit byWoolcock et al, 1999 Span/100 = 7.54 mm

Reactions

Maximum = 0.61 kn

Intermediate Design Sides

Intermediate Spacing = 2900.008877578197 mm   Intermediate Span = 2776 mm   Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =9.63   S1 Upward =0.53

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.88 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	**477.27 %**
$V_{0.9D-WnUp}$	1.27 Kn	Capacity	24.12 Kn	Passing Percentage	**1899.21 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.305 mm   Limit by Woolcock et al, 1999 Span/100 = 27.76 mm

Reactions

Maximum = 1.27 kn

Girt Design Front and Back

Girt's Spacing = 1300 mm   Girt's Span = 2570 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.85   S1 Downward =9.63   S1 Upward =16.28

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.68 Kn-m	Capacity	1.78 Kn-m	Passing Percentage	**261.76 %**
$V_{0.9D-WnUp}$	1.05 Kn	Capacity	12.06 Kn	Passing Percentage	**1148.57 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 4.94 mm   Limit by Woolcock et al, 1999 Span/100 = 25.70 mm
Sag during installation = 2.65 mm

Reactions

Maximum = 1.05 kn

Girt Design Sides

Girt's Spacing = 1300 mm   Girt's Span = 2900 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.80   S1 Downward =9.63   S1 Upward =17.29

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.86 Kn-m	Capacity	1.68 Kn-m	Passing Percentage	**195.35 %**
$V_{0.9D-WnUp}$	1.19 Kn	Capacity	12.06 Kn	Passing Percentage	**1013.45 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.01 mm   Limit by Woolcock et al. 1999 Span/100 = 29.00 mm
Sag during installation =4.29 mm

Reactions

Maximum = 1.19 kn

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 24.34 Kn

Uplift on one Pile = 18.33 Kn

Uplift is ok

Last Page