



Pole Shed App Ver 01 2022

**Job No.:** Helen Costley - 2      **Address:** 8969 Wairau Valley Highway, St Arnaud, New Zealand      **Date:** 19/06/2025  
**Latitude:** -41.800439      **Longitude:** 172.880806      **Elevation:** 790.5 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N3	Ground Snow Load	1.92 KPa	Roof Snow Load	1.11 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5.4 m
Wind Region	NZ2	Terrain Category	2.5	Design Wind Speed	45.45 m/s
Wind Pressure	1.24 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Gable Enclosed

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 4.20 m  $C_{p,e} = -0.9$   $p_e = -1.00$  KPa  $p_{net} = -1.00$  KPa

For roof  $C_{p,e}$  from 4.20 m To 8.40 m  $C_{p,e} = -0.5$   $p_e = -0.56$  KPa  $p_{net} = -0.56$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 12 m  $C_{p,e} = 0.7$   $p_e = 0.78$  KPa  $p_{net} = 1.15$  KPa

For side wall  $C_{p,e}$  from 0 m To 4.20 m  $C_{p,e} =$   $p_e = -0.73$  KPa  $p_{net} = -0.73$  KPa

Maximum Upward pressure used in roof member Design = 1.00 KPa

Maximum Downward pressure used in roof member Design = 0.48 KPa

Maximum Wall pressure used in Design = 1.15 KPa

Maximum Racking pressure used in Design = 1.32 KPa

**Design Summary**

**Intermediate Design Sides**

Intermediate Spacing = 2500 mm      Intermediate Span = 4693 mm      Try Intermediate 2x290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

Pole Shed App Ver 01 2022

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =0.89

K8 Upward =1.00    S1 Downward =15.23    S1 Upward =1.10

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>Wind+Snow</sub>	6.61 Kn-m	Capacity	14.12 Kn-m	Passing Percentage	<b>213.62 %</b>
V <sub>0.9D-WnUp</sub>	5.63 Kn	Capacity	41.96 Kn	Passing Percentage	<b>745.29 %</b>

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 49.075 mm    Limit by Woolcock et al, 1999 Span/100 = 46.93 mm

**Reactions**

Maximum = 5.63 kn

**Girt Design Front and Back**

Girt's Spacing = 0 mm

Girt's Span = 4000 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =NaN

K8 Upward =NaN    S1 Downward =NaN    S1 Upward =NaN

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>Wind+Snow</sub>	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	<b>NaN %</b>
V <sub>0.9D-WnUp</sub>	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	<b>NaN %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm    Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

Sag during installation = NaN mm

**Reactions**

Maximum = 0.00 kn

## Girt Design Sides

Girt's Spacing = 0 mm

Girt's Span = 2500 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =NaN

K8 Upward =NaN    S1 Downward =NaN    S1 Upward =NaN

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

## Capacity Checks

M <sub>Wind+Snow</sub>	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	NaN %
V <sub>0.9D-WnUp</sub>	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	NaN %

## Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm    Limit by Woolcock et al. 1999 Span/100 = 25.00 mm  
Sag during installation =NaN mm

## Reactions

Maximum = 0.00 kn

## Uplift Check

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.47 Kn

Uplift on one Pile = 15.50 Kn

Uplift is ok