

Pole Shed App Ver 01 2022

Job No.: 1063 -Turitea road **Address:** 203 Turitea Road, Fitzherbert, New Zealand **Date:** 3/10/2025
Latitude: -40.403519 **Longitude:** 175.649261 **Elevation:** 58.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.8 m
Wind Region	NZ2	Terrain Category	3.0	Design Wind Speed	34.86 m/s
Wind Pressure	0.73 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Medium	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 3.30 m $C_{p,e} = -0.9119$ $p_e = -0.60$ KPa $p_{net} = -0.60$ KPa

For roof $C_{p,e}$ from 3.30 m To 6.60 m $C_{p,e} = -0.5118$ $p_e = -0.34$ KPa $p_{net} = -0.34$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 6.6 m $C_{p,e} = 0.7$ $p_e = 0.46$ KPa $p_{net} = 0.68$ KPa

For side wall $C_{p,e}$ from 0 m To 3.50 m $C_{p,e} =$ $p_e = -0.43$ KPa $p_{net} = -0.43$ KPa

Maximum Upward pressure used in roof member Design = 0.60 KPa

Maximum Downward pressure used in roof member Design = 0.29 KPa

Maximum Wall pressure used in Design = 0.68 KPa

Maximum Racking pressure used in Design = 0.66 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm Purlin Span = 3050 mm Try Purlin 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.79 S1 Downward = 9.63 S1 Upward = 17.59

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.35 Kn-m	Capacity	1.26 Kn-m	Passing Percentage	360.00 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	1.57 Kn-m	Capacity	1.68 Kn-m	Passing Percentage	107.01 %
M _{0.9D-WnUp}	-0.39 Kn-m	Capacity	-1.65 Kn-m	Passing Percentage	423.08 %
V _{1.35D}	0.46 Kn	Capacity	7.24 Kn	Passing Percentage	1573.91 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	0.93 Kn	Capacity	9.65 Kn	Passing Percentage	1037.63 %
V _{0.9D-WnUp}	-0.51 Kn	Capacity	-12.06 Kn	Passing Percentage	2364.71 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 11.60 mm Limit by Woolcock et al, 1999 Span/240 = 12.50 mm

Deflection under Dead and Service Wind = 6.50 mm Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Reactions

Maximum downward = 0.93 kn Maximum upward = -0.51 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 3200 mm Internal Rafter Span = 6450 mm Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 6.81 S1 Upward = 6.81

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	5.62 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	179.36 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	11.23 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	119.68 %

Pole Shed App Ver 01 2022

M _{0.9D-WnUp}	-6.24 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	269.23 %
V _{1.35D}	3.48 Kn	Capacity	28.94 Kn	Passing Percentage	831.61 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	6.97 Kn	Capacity	38.6 Kn	Passing Percentage	553.80 %
V _{0.9D-WnUp}	-3.87 Kn	Capacity	-48.24 Kn	Passing Percentage	1246.51 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 17.57 mm Limit by Woolcock et al, 1999 Span/240 = 27.50 mm

Deflection under Dead and Service Wind = 20.985 mm Limit by Woolcock et al, 1999 Span/100 = 66.00 mm

Reactions

Maximum downward = 6.97 kn Maximum upward = -3.87 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 32.51 Kn > -3.87 Kn

Rafter Design External

External Rafter Load Width = 1600 mm External Rafter Span = 3154 mm Try Rafter 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 0.97

Pole Shed App Ver 01 2022

K8 Upward =0.97 S1 Downward =12.68 S1 Upward =12.68

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.67 Kn-m	Capacity	3.40 Kn-m	Passing Percentage	507.46 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.46 Kn-m	Capacity	4.53 Kn-m	Passing Percentage	310.27 %
M _{0.9D-W_nUp}	-0.75 Kn-m	Capacity	-5.67 Kn-m	Passing Percentage	756.00 %
V _{1.35D}	0.85 Kn	Capacity	12.06 Kn	Passing Percentage	1418.82 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.70 Kn	Capacity	16.08 Kn	Passing Percentage	945.88 %
V _{0.9D-W_nUp}	-0.95 Kn	Capacity	-20.10 Kn	Passing Percentage	2115.79 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 2.11 mm Limit by Woolcock et al, 1999 Span/240= 13.75 mm

Deflection under Dead and Service Wind = 2.27 mm Limit by Woolcock et al, 1999 Span/100 = 33.00 mm

Reactions

Maximum downward =1.70 kn Maximum upward = -0.95 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k₁ x k₄ x k₅ x f_s x b x d_s (Eq 4.12) = -19.95 kn > -0.95 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -0.95 Kn

Girt Design Front and Back

Girt's Spacing = 900 mm

Girt's Span = 3200 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.76 S1 Downward =9.63 S1 Upward =18.16

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.78 Kn-m	Capacity	1.60 Kn-m	Passing Percentage	205.13 %
V _{0.9D-WnUp}	0.98 Kn	Capacity	12.06 Kn	Passing Percentage	1230.61 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.87 mm Limit by Woolcock et al, 1999 Span/100 = 32.00 mm

Sag during installation = 6.36 mm

Reactions

Maximum = 0.98 kn

Girt Design Sides

Girt's Spacing = 900 mm

Girt's Span = 3300 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.75 S1 Downward =9.63 S1 Upward =18.44

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.83 Kn-m	Capacity	1.57 Kn-m	Passing Percentage	189.16 %
V _{0.9D-WnUp}	1.01 Kn	Capacity	12.06 Kn	Passing Percentage	1194.06 %

Pole Shed App Ver 01 2022

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 10.03 mm Limit by Woolcock et al. 1999 Span/100 = 33.00 mm

Sag during installation = 7.19 mm

Reactions

Maximum = 1.01 kn

Middle Pole Design

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3500 mm
Area	20729 mm ²	As	15546.6796875 mm ²
Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zy	421056 mm ³
Lateral Restraint	3500 mm c/c		

Loads

Total Area over Pole = 10.56 m²

Dead	2.64 Kn	Live	2.64 Kn
Wind Down	3.06 Kn	Snow	0.00 Kn
Moment wind	5.70 Kn-m		
Phi	0.8	K8	0.60
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	177.99 Kn	PhiMnx Wind	7.29 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	106.79 Kn	PhiMnx Dead	4.37 Kn-m	PhiVnx Dead	22.09 Kn

Checks

$$(M_x/\phi M_{nx}) + (N/\phi N_{cx}) = 0.83 < 1 \text{ OK}$$

$$(M_x/\phi M_{nx})^2 + (N/\phi N_{cx}) = 0.66 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 33.66 \text{ mm} < 35.00 \text{ mm}$$

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m³ Friction angle 30 deg Cohesion 0 Kn/m³

$$K_0 = (1 - \sin(30)) / (1 + \sin(30))$$

$$K_p = (1 + \sin(30)) / (1 - \sin(30))$$

Geometry For Middle Bay Pole

Ds = 0.6 mm Pile Diameter
L = 1500 mm Pile embedment length
f1 = 2850 mm Distance at which the shear force is applied
f2 = 0 mm Distance of top soil at rest pressure

Loads

Moment Wind = 5.70 Kn-m
Shear Wind = 2.00 Kn

Pile Properties

Safety Factory 0.55
Hu = 6.91 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 11.80 Kn-m Ultimate Moment Capacity of Pile

Checks

$$\text{Applied Forces/Capacities} = 0.48 < 1 \text{ OK}$$

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level) Dry Use Height 3550 mm

Pole Shed App Ver 01 2022

Area	20729 mm ²	As	15546.6796875 mm ²
Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zy	421056 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 5.28 m²

Dead	1.32 Kn	Live	1.32 Kn
Wind Down	1.53 Kn	Snow	0.00 Kn
Moment Wind	1.90 Kn-m		
Phi	0.8	K8	0.58
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	173.85 Kn	PhiMnx Wind	7.12 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	104.31 Kn	PhiMnx Dead	4.27 Kn-m	PhiVnx Dead	22.09 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.29 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.10 < 1$ OK

Deflection at top under service lateral loads = 12.15 mm < 37.90 mm

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	2850 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 5.28 m²

Pole Shed App Ver 01 2022

Moment Wind = 1.90 Kn-m
Shear Wind = 0.67 Kn

Pile Properties

Safety Factory 0.55
Hu = 6.91 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 11.80 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.16 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma 18 Kn/m³ Friction angle 30 deg Cohesion 0 Kn/m³
K0 = $(1 - \sin(30)) / (1 + \sin(30))$
Kp = $(1 + \sin(30)) / (1 - \sin(30))$

Geometry For End Bay Pole

Ds = 0.6 mm Pile Diameter
L = 1500 mm Pile embedment length
f1 = 2850 mm Distance at which the shear force is applied
f2 = 0 mm Distance of top soil at rest pressure

Loads

Moment Wind = 1.90 Kn-m
Shear Wind = 0.67 Kn

Pile Properties

Safety Factory 0.55
Hu = 6.91 Kn Ultimate Lateral Strength of the Pile, Short pile
Mu = 11.80 Kn-m Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.16 < 1 OK

Uplift Check

Pole Shed App Ver 01 2022

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1500) x Ks(1.5) x $0.5 \times \tan(30) \times \pi \times \text{Dia of Pile}(0.6) \times \text{Height of Pile}(1500)$

Skin Friction = 18.17 Kn

Weight of Pile + Pile Skin Friction = 23.08 Kn

Uplift on one Pile = 3.96 Kn

Uplift is ok