



**Job No.:** Shane Atkinson - 1

**Address:** 1708 Te Kopia Road, Waikite Valley, Rotorua, New Zealand

**Date:** 3/2/2025

**Latitude:** -38.492781

**Longitude:** 176.193031

**Elevation:** 355.5 m

### General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4 m
Wind Region	NZ2	Terrain Category	2.66	Design Wind Speed	38.29 m/s
Wind Pressure	0.88 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

### Pressure Coefficients and Pressures

Shed Type = Mono Open

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 1.85 m  $C_{p,e} = -0.9933$   $p_e = -0.79$  KPa  $p_{net} = -0.79$  KPa

For roof  $C_{p,e}$  from 1.85 m To 3.70 m  $C_{p,e} = -0.8533$   $p_e = -0.68$  KPa  $p_{net} = -0.68$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 6 m  $C_{p,e} = 0.7$   $p_e = 0.55$  KPa  $p_{net} = 0.81$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.70 m  $C_{p,e} =$   $p_e = -0.51$  KPa  $p_{net} = -0.51$  KPa

Maximum Upward pressure used in roof member Design = 0.79 KPa

Maximum Downward pressure used in roof member Design = 0.41 KPa

Maximum Wall pressure used in Design = 0.81 KPa

Maximum Racking pressure used in Design = 0.95 KPa

### Design Summary

#### Girt Design Front and Back

Girt's Spacing = 1300 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

$M_{Wind+Snow}$	1.18 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	<b>139.83 %</b>
$V_{0.9D-WnUp}$	1.58 Kn	Capacity	12.06 Kn	Passing Percentage	<b>763.29 %</b>

### Deflections

Second page

### Pole Shed App Ver 01 2022

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 11.79 mm

Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Sag during installation = 4.91 mm

#### Reactions

Maximum = 1.58 kn

#### Girt Design Sides

Girt's Spacing = 0 mm

Girt's Span = 3000 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =NaN

K8 Upward =NaN    S1 Downward =NaN    S1 Upward =NaN

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	NaN %
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	NaN %

#### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =NaN mm

#### Reactions

Maximum = 0.00 kn

#### Middle Pole Design

##### Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3760 mm
Area	27598 mm <sup>2</sup>	As	20698.2421875 mm <sup>2</sup>
I <sub>x</sub>	60639381 mm <sup>4</sup>	Z <sub>x</sub>	646820 mm <sup>3</sup>
I <sub>y</sub>	60639381 mm <sup>4</sup>	Z <sub>y</sub>	646820 mm <sup>3</sup>
Lateral Restraint	1300 mm c/c		

##### Loads

Total Area over Pole = 9 m<sup>2</sup>

Dead	2.25 Kn	Live	2.25 Kn
Wind Down	3.69 Kn	Snow	0.00 Kn
Moment wind	8.53 Kn-m		
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

**Capacities**

PhiNcx Wind	397.41 Kn	PhiMnx Wind	18.78 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	238.44 Kn	PhiMnx Dead	11.27 Kn-m	PhiVnx Dead	29.41 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.47 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.23 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 32.11 \text{ mm} < 37.60 \text{ mm}$$

**Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

**Geometry For Middle Bay Pole**

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	8.53 Kn-m
Shear Wind =	2.84 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	6.68 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.94 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

$$\text{Applied Forces/Capacities} = 0.71 < 1 \text{ OK}$$

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

Pole Shed App Ver 01 2022

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3850 mm
Area	20729 mm <sup>2</sup>	As	15546.6796875 mm <sup>2</sup>
I <sub>x</sub>	34210793 mm <sup>4</sup>	Z <sub>x</sub>	421056 mm <sup>3</sup>
I <sub>y</sub>	34210793 mm <sup>4</sup>	Z <sub>y</sub>	421056 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 9 m<sup>2</sup>

Dead	2.25 Kn	Live	2.25 Kn
Wind Down	3.69 Kn	Snow	0.00 Kn
Moment Wind	4.26 Kn-m		
Phi	0.8	K <sub>8</sub>	0.50
K <sub>1</sub> snow	0.8	K <sub>1</sub> Dead	0.6
K <sub>1</sub> wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
f <sub>b</sub> =	36.3 MPa	f <sub>s</sub> =	2.96 MPa
f <sub>c</sub> =	18 MPa	f <sub>p</sub> =	7.2 MPa
f <sub>t</sub> =	22 MPa	E =	9257 MPa

**Capacities**

PhiN <sub>cx</sub> Wind	150.69 Kn	PhiM <sub>nx</sub> Wind	6.17 Kn-m	PhiV <sub>nx</sub> Wind	36.81 Kn
PhiN <sub>cx</sub> Dead	90.41 Kn	PhiM <sub>nx</sub> Dead	3.70 Kn-m	PhiV <sub>nx</sub> Dead	22.09 Kn

**Checks**

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.75 < 1$  OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.53 < 1$  OK

Deflection at top under service lateral loads = 30.20 mm < 39.90 mm

D <sub>s</sub> =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f <sub>1</sub> =	3000 mm	Distance at which the shear force is applied
f <sub>2</sub> =	0 mm	Distance of top soil at rest pressure

**Loads**

Total Area over Pole = 9 m<sup>2</sup>

Moment Wind =	4.26 Kn-m
Shear Wind =	1.42 Kn

**Pile Properties**

Safety Factor	0.55	
H <sub>u</sub> =	6.68 Kn	Ultimate Lateral Strength of the Pile, Short pile
M <sub>u</sub> =	11.94 Kn-m	Ultimate Moment Capacity of Pile

#### Checks

Applied Forces/Capacities =  $0.36 < 1$  OK

### Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

#### Assumed Soil Properties

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

#### Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3000 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

#### Loads

Moment Wind =	4.26 Kn-m
Shear Wind =	1.42 Kn

#### Pile Properties

Safety Factory	0.55	
Hu =	6.68 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.94 Kn-m	Ultimate Moment Capacity of Pile

#### Checks

Applied Forces/Capacities =  $0.36 < 1$  OK

### Uplift Check

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1500) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1500)

Skin Friction = 18.17 Kn

Weight of Pile + Pile Skin Friction = 22.56 Kn

Uplift on one Pile = 5.09 Kn

Uplift is ok