Pole Shed App Ver 01 2022

Job No.: Apiti Shed - 2 **Address:** 101 Table Flat Rd, Apiti, New Zealand **Date:** 11/22/2023
Latitude: -39.948308 **Longitude:** 175.912963 **Elevation:** 558 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N1	Ground Snow Load	0.74 KPa	Roof Snow Load	0.5 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	2.8 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	45.14 m/s
Wind Pressure	1.22 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable Enclosed

For roof Cp,i = -0.3

For roof CP,e from 0 m To 6.20 m Cpe = -0.9 pe = -0.99 KPa pnet = -0.99 KPa

For roof CP,e from 6.20 m To 12.40 m Cpe = -0.5 pe = -0.55 KPa pnet = -0.55 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 28.8 m Cpe = 0.7 pe = 0.77 KPa pnet = 1.14 KPa

For side wall CP,e from 0 m To 6.20 m Cpe = pe = -0.72 KPa pnet = -0.72 KPa

Maximum Upward pressure used in roof member Design = 0.99 KPa

Maximum Downward pressure used in roof member Design = 0.59 KPa

Maximum Wall pressure used in Design = 1.14 KPa

Maximum Racking pressure used in Design = 1.1 KPa

Design Summary

Girt Design Front and Back

Girt's Spacing = 600 mm Girt's Span = 4800 mm Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.36 S1 Downward =12.23 S1 Upward =28.24

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.97 Kn-m	Capacity	1.11 Kn-m	Passing Percentage	**56.35 %**
$V_{0.9D-WnUp}$	1.64 Kn-m	Capacity	13.75 Kn-m	Passing Percentage	**838.41 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 39.47 mm Limit by Woolcock et al, 1999 Span/100 = 48.00 mm
Sag during installation = 39.74 mm

Reactions

Maximum = 1.64 kn

Girt Design Sides

Girt's Spacing = 1300 mm Girt's Span = 2000 mm Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.76 S1 Downward =12.23 S1 Upward =18.23

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.74 Kn-m	Capacity	2.30 Kn-m	Passing Percentage	**310.81 %**
$V_{0.9D-WnUp}$	1.48 Kn-m	Capacity	13.75 Kn-m	Passing Percentage	**929.05 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 2.58 mm Limit by Woolcock et al. 1999 Span/100 = 20.00 mm

Second page

Sag during installation =1.20 mm

Reactions

Maximum = 1.48 kn

End Pole Design

Geometry For End Bay Pole

Geometry

125x125 SG8 Dry	Dry Use	Height	2650 mm
Area	15625 mm2	As	11718.75 mm2
Ix	20345052 mm4	Zx	325521 mm3
Iy	20345052 mm4	Zx	325521 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 4.8 m2

Dead	1.20 Kn	Live	1.20 Kn
Wind Down	2.83 Kn	Snow	2.40 Kn
Moment Wind	0.91 Kn-m	Moment snow	0.29 Kn-m
Phi	0.8	K8	0.61
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Shaving	Steaming	Normal	Dry Use
fb =	14 MPa	fs =	3 MPa
fc =	18 MPa	fp =	8.9 MPa
ft =	6 MPa	E =	8000 MPa

Capacities

PhiNcx Wind	137.79 Kn	PhiMnx Wind	2.23 Kn-m	PhiVnx Wind	28.13 Kn
PhiNcx Dead	82.67 Kn	PhiMnx Dead	1.34 Kn-m	PhiVnx Dead	16.88 Kn
PhiNcx Snow	110.23 Kn	PhiMnx Snow	1.79 Kn-m	PhiVnx Snow	22.50 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.45 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.21 < 1 OK

Deflection at top under service lateral loads = 6.15 mm < 27.93 mm

Ds =	0.6 mm	Pile Diameter
L =	600 mm	Pile embedment length
f1 =	2100 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 4.8 m2

Moment Wind =	0.91 Kn-m	Moment Snow =	0.29 Kn-m
Shear Wind =	0.43 Kn	Shear Snow =	0.29 Kn

Pile Properties

Safety Factory	0.55	
Hu =	0.71 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	0.86 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 1.07 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	600 mm	Pile embedment length
f1 =	2100 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	0.91 Kn-m	Moment Snow =	0.29 Kn-m
Shear Wind =	0.43 Kn	Shear Snow =	0.29 Kn

Pile Properties

Safety Factory	0.55	
Hu =	0.71 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	0.86 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 1.07 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(800) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(800)

Skin Friction = 5.17 Kn

Weight of Pile + Pile Skin Friction = 8.57 Kn

Uplift on one Pile = 7.34 Kn

Uplift is ok