<u>Pole Shed App Ver 01 2022</u>

Pole Shed App Ver 01 2022

Job No.: Steve Maley-Canopy **Address:** 48 Morven Lane, Fairhall, New Zealand **Date:** 3/11/2025
Latitude: -41.547677 **Longitude:** 173.886444 **Elevation:** 49.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N3	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	2.4 m
Wind Region	NZ2	Terrain Category	2.57	Design Wind Speed	39.18 m/s
Wind Pressure	0.92 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Open

For roof Cp,i = 0.49

For roof CP,e from 0 m To 1.2 m Cpe = -1.3 pe = -1.03 KPa pnet = -1.46 KPa

For roof CP,e from 1.20 m To 1.50 m Cpe = -0.7 pe = -0.55 KPa pnet = -0.98 KPa

For wall Windward Cp,i = 0.49 side Wall Cp,i = -0.65

For wall Windward and Leeward CP,e from 0 m To 3.50 m Cpe = 0.7 pe = 0.57 KPa pnet = 1.16 KPa

For side wall CP,e from 0 m To 2.40 m Cpe = pe = -0.53 KPa pnet = 0.06 KPa

Maximum Upward pressure used in roof member Design = 1.46 KPa

Maximum Downward pressure used in roof member Design = 0.50 KPa

Maximum Wall pressure used in Design = 1.16 KPa

Maximum Racking pressure used in Design = 0.99 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm Purlin Span = 3350 mm Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.52 S1 Downward =12.23 S1 Upward =23.41

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.43 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	**416.28 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.76 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	**135.23 %**
$M_{0.9D-WnUp}$	-1.56 Kn-m	Capacity	-1.56 Kn-m	Passing Percentage	**100.00 %**
$V_{1.35D}$	0.51 Kn	Capacity	8.25 Kn	Passing Percentage	**1617.65 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.21 Kn	Capacity	11.00 Kn	Passing Percentage	**909.09 %**
$V_{0.9D-WnUp}$	-1.86 Kn	Capacity	-13.75 Kn	Passing Percentage	**739.25 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 8.81 mm	Limit by Woolcock et al, 1999 Span/240 = 13.75 mm
Deflection under Dead and Service Wind = 6.05 mm	Limit by Woolcock et al, 1999 Span/100 = 33.00 mm

Reactions

Maximum downward =1.21 kn Maximum upward = -1.86 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design External

External Rafter Load Width = 1750 mm External Rafter Span = 1313 mm Try Rafter 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.98

K8 Upward =0.98 S1 Downward =12.23 S1 Upward =12.23

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.13 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	**1376.92 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	0.47 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	**506.38 %**

$M_{0.9D\text{-}WnUp}$	-0.47 Kn-m	Capacity	-2.98 Kn-m	Passing Percentage	**634.04 %**
$V_{1.35D}$	0.39 Kn	Capacity	8.25 Kn	Passing Percentage	**2115.38 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	0.92 Kn	Capacity	11.00 Kn	Passing Percentage	**1195.65 %**
$V_{0.9D\text{-}WnUp}$	-1.42 Kn	Capacity	-13.75 Kn	Passing Percentage	**968.31 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 0.25 mm	Limit by Woolcock et al, 1999 Span/240= 6.25 mm
Deflection under Dead and Service Wind = 0.31 mm	Limit by Woolcock et al, 1999 Span/100 = 15.00 mm

Reactions

Maximum downward =0.92 kn   Maximum upward = -1.42 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 1

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -12.28 kn > -1.42 Kn

Single Shear Capacity under short term loads = -4.88 Kn > -1.42 Kn

Girt Design Front and Back

Girt's Spacing = 0 mm	Girt's Span = 3500 mm	Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =NaN

K8 Upward =NaN   S1 Downward =NaN   S1 Upward =NaN

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm   Limit by Woolcock et al, 1999 Span/100 = 35.00 mm
Sag during installation = NaN mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm   Girt's Span = 1500 mm   Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =NaN

K8 Upward =NaN   S1 Downward =NaN   S1 Upward =NaN

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm   Limit by Woolcock et al. 1999 Span/100 = 15.00 mm
Sag during installation =NaN mm

Reactions

Maximum = 0.00 kn

End Pole Design

Geometry For End Bay Pole

Geometry

100x100 SG8 Dry	Dry Use	Height	2200 mm
Area	10000 mm2	As	7500 mm2
Ix	8333333 mm4	Zx	166667 mm3
Iy	8333333 mm4	Zx	166667 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 2.625 m2

Dead	0.66 Kn	Live	0.66 Kn
Wind Down	1.31 Kn	Snow	0.00 Kn
Moment Wind	1.87 Kn-m		
Phi	0.8	K8	0.58
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Shaving	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	82.87 Kn	PhiMnx Wind	2.79 Kn-m	PhiVnx Wind	17.76 Kn
PhiNcx Dead	49.72 Kn	PhiMnx Dead	1.67 Kn-m	PhiVnx Dead	10.66 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.70 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.48 < 1 OK

Deflection at top under service lateral loads = 19.53 mm < 23.94 mm

Ds =	0.6 mm	Pile Diameter
L =	850 mm	Pile embedment length
f1 =	1800 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 2.625 m2

Moment Wind =	1.87 Kn-m
Shear Wind =	1.04 Kn

Pile Properties

Safety Factory	0.55	
Hu =	2.06 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	2.20 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.85 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	850 mm	Pile embedment length
f1 =	1800 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	1.87 Kn-m
Shear Wind =	1.04 Kn

Pile Properties

Safety Factory	0.55	
Hu =	2.06 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	2.20 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.85 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 20.41 Kn

Uplift on one Pile = 3.24 Kn

Uplift is ok