Pole Shed App Ver 01 2022

First Page

**Job No.:** 483-220993C - 1    **Address:** 1035 TE MATAI RD, Te Puke, New Zealand    **Date:** 13/06/2025

**Latitude:** -37.875046    **Longitude:** 176.303203    **Elevation:** 237.5 m

## General Input

| | | | | | |
|---|---|---|---|---|---|
| Roof Live Load | 0.25 KPa | Roof Dead Load | 0.25 KPa | Roof Live Point Load | 1.1 Kn |
| Snow Zone | N0 | Ground Snow Load | 0 KPa | Roof Snow Load | 0 KPa |
| Earthquake Zone | 2 | Subsoil Category | D | Exposure Zone | B |
| Importance Level | 1 | Ultimate wind & Earthquake ARI | 100 Years | Max Height | 3.333 m |
| Wind Region | NZ1 | Terrain Category | 2.33 | Design Wind Speed | 41.42 m/s |
| Wind Pressure | 1.03 KPa | Lee Zone | NO | Ultimate Snow ARI | 50 Years |
| Wind Category | High | Earthquake ARI | 100 | | |

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

## Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof $C_{p,i}$ = -0.3

For roof  $C_{P,e}$  from 0 m  To 2.83 m   $C_{pe}$ = -0.9   pe = -0.83 KPa   pnet = -0.83 KPa

For roof  $C_{P,e}$  from 2.83 m  To 5.66 m   $C_{pe}$ = -0.5   pe = -0.46 KPa   pnet = -0.46 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward   $C_{P,e}$   from 0 m  To 9.024 m   $C_{pe}$ = 0.7   pe = 0.65 KPa   pnet = 0.96 KPa

For side wall  $C_{P,e}$   from 0 m  To 2.83 m   $C_{pe}$ =   pe = -0.60 KPa   pnet = -0.60 KPa

Maximum Upward pressure used in roof member Design = 0.83 KPa

Maximum Downward pressure used in roof member Design = 0.50 KPa

Maximum Wall pressure used in Design = 0.96 KPa

Maximum Racking pressure used in Design = 1.11 KPa

## Design Summary

## Rafter Design External

External Rafter Load Width = 1299.5 mm    External Rafter Span = 4545 mm    Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 =1    K5 =1    K8 Downward =0.89

K8 Upward =0.89    S1 Downward =15.23    S1 Upward =15.23

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | | |
|---|---|---|---|---|---|---|
| $M_{1.35D}$ | 1.13 Kn-m | Capacity | 3.78 Kn-m | Passing Percentage | **334.51 %** |
| $M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 2.68 Kn-m | Capacity | 5.04 Kn-m | Passing Percentage | **188.06 %** |
| $M_{0.9D-WnUp}$ | -2.03 Kn-m | Capacity | -6.29 Kn-m | Passing Percentage | **309.85 %** |
| $V_{1.35D}$ | 1.00 Kn | Capacity | 12.59 Kn | Passing Percentage | **1259.00 %** |
| $V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 2.36 Kn | Capacity | 16.79 Kn | Passing Percentage | **711.44 %** |
| $V_{0.9D-WnUp}$ | -1.79 Kn | Capacity | -20.98 Kn | Passing Percentage | **1172.07 %** |

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 3.51 mm    Limit by Woolcock et al, 1999 Span/240= 17.92 mm
Deflection under Dead and Service Wind = 4.39 mm    Limit by Woolcock et al, 1999 Span/100 = 43.00 mm

**Reactions**

Maximum downward =2.36 kn   Maximum upward = -1.79 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds ........... (Eq 4.12) = -21.73 kn > -1.79 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -1.79 Kn

## Intermediate Design Sides

Intermediate Spacing = 2150 mm        Intermediate Span = 3183 mm        Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =1.00    S1 Downward =10.36    S1 Upward =0.62

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 1.31 Kn-m | Capacity | 3.3 Kn-m | Passing Percentage | **251.91 %** |
| $V_{0.9D-WnUp}$ | 1.64 Kn | Capacity | 20.26 Kn | Passing Percentage | **1235.37 %** |

### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 24.825 mm    Limit by Woolcock et al, 1999 Span/100 = 31.83 mm

### Reactions

Maximum = 1.64 kn

## Girt Design Front and Back

Girt's Spacing = 800 mm                Girt's Span = 2599 mm                Try Girt 140x45 SG6

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.79    S1 Downward =10.36    S1 Upward =17.61

Shear Capacity of timber =3 MPa    Bending Capacity of timber =10 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 0.65 Kn-m | Capacity | 0.93 Kn-m | Passing Percentage | **143.08 %** |
| $V_{0.9D-WnUp}$ | 1.00 Kn | Capacity | 10.13 Kn | Passing Percentage | **1013.00 %** |

**Deflections**

Modulus of Elasticity = 5000 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.87 mm     Limit by Woolcock et al, 1999 Span/100 = 25.99 mm
Sag during installation = 4.58 mm

**Reactions**

Maximum = 1.00 kn

## Girt Design Sides

Girt's Spacing = 800 mm                    Girt's Span = 2150 mm                    Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.86    S1 Downward =10.36    S1 Upward =16.02

Shear Capacity of timber =3 MPa     Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 0.44 Kn-m | Capacity | 1.41 Kn-m | Passing Percentage | **320.45 %** |
| $V_{0.9D-WnUp}$ | 0.83 Kn | Capacity | 10.13 Kn | Passing Percentage | **1220.48 %** |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 3.10 mm     Limit by Woolcock et al. 1999 Span/100 = 21.50 mm
Sag during installation =1.60 mm

**Reactions**

Maximum = 0.83 kn

# Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.92 Kn

Uplift on one Pile = 3.38 Kn

Uplift is ok

Last Page