



Pole Shed App Ver 01 2022

**Job No.:** Colin Patterson Pole Shed      **Address:** 1251 Kakaramea Road Ngahinapouri New Zealand, Ngahinapouri, New Zealand      **Date:** 3/10/2025  
**Latitude:** -37.892841      **Longitude:** 175.204441      **Elevation:** 31.5 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.35 m
Wind Region	NZ1	Terrain Category	2.32	Design Wind Speed	35.87 m/s
Wind Pressure	0.77 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Medium	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6885$

For roof  $C_{p,e}$  from 0 m To 1.59 m  $C_{p,e} = -1.008$   $p_e = -0.70$  KPa  $p_{net} = -1.28$  KPa

For roof  $C_{p,e}$  from 1.59 m To 3.18 m  $C_{p,e} = -0.846$   $p_e = -0.59$  KPa  $p_{net} = -1.17$  KPa

For wall Windward  $C_{p,i} = 0.6885$  side Wall  $C_{p,i} = -0.6286$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 6 m  $C_{p,e} = 0.7$   $p_e = 0.49$  KPa  $p_{net} = 1.02$  KPa

For side wall  $C_{p,e}$  from 0 m To 3.18 m  $C_{p,e} =$   $p_e = -0.45$  KPa  $p_{net} = 0.08$  KPa

Maximum Upward pressure used in roof member Design = 1.28 KPa

Maximum Downward pressure used in roof member Design = 0.52 KPa

Maximum Wall pressure used in Design = 1.02 KPa

Maximum Racking pressure used in Design = 0.84 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 700 mm

Purlin Span = 5850 mm

Try Purlin 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

### Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.94

K8 Upward = 0.79    S1 Downward = 13.82    S1 Upward = 17.54

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	1.01 Kn-m	Capacity	2.73 Kn-m	Passing Percentage	<b>270.30 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	3.31 Kn-m	Capacity	3.64 Kn-m	Passing Percentage	<b>109.97 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-3.16 Kn-m	Capacity	-3.82 Kn-m	Passing Percentage	<b>120.89 %</b>
V <sub>1.35D</sub>	0.69 Kn	Capacity	10.42 Kn	Passing Percentage	<b>1510.14 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	1.68 Kn	Capacity	13.89 Kn	Passing Percentage	<b>826.79 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-2.16 Kn	Capacity	-17.37 Kn	Passing Percentage	<b>804.17 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 27.72 mm    Limit by Woolcock et al, 1999 Span/240 = 24.17 mm

Deflection under Dead and Service Wind = 22.57 mm    Limit by Woolcock et al, 1999 Span/100 = 58.00 mm

#### **Reactions**

Maximum downward = 1.68 kn    Maximum upward = -2.16 kn

Number of Blocking = 3    if 0 then no blocking required, if 1 then one midspan blocking required

#### **Intermediate Design Front and Back**

Intermediate Spacing = 3000 mm    Intermediate Span = 2849 mm    Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 10.36    S1 Upward = 0.58

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>Wind+S<sub>n</sub>ow</sub>	3.11 Kn-m	Capacity	3.3 Kn-m	Passing Percentage	<b>106.11 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	4.36 Kn	Capacity	-20.26 Kn	Passing Percentage	<b>464.68 %</b>

### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 23.635 mm Limit by Woolcock et al, 1999 Span/100 = 28.49 mm

### Reactions

Maximum = 4.36 kn

### Intermediate Design Sides

Intermediate Spacing = 2500 mm Intermediate Span = 3025 mm Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 10.36 S1 Upward = 0.60

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

$M_{Wind+Snow}$	1.46 Kn-m	Capacity	3.3 Kn-m	Passing Percentage	<b>226.03 %</b>
$V_{0.9D-WnUp}$	1.93 Kn	Capacity	20.26 Kn	Passing Percentage	<b>1049.74 %</b>

### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.01 mm Limit by Woolcock et al, 1999 Span/100 = 30.25 mm

### Reactions

Maximum = 1.93 kn

### Girt Design Front and Back

Girt's Spacing = 900 mm Girt's Span = 3000 mm Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 = 1 K5 = 1 K8 Downward = 1.00

Pole Shed App Ver 01 2022

K8 Upward =0.72    S1 Downward =10.36    S1 Upward =18.92

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>Wind+Snow</sub>	1.03 Kn-m	Capacity	1.19 Kn-m	Passing Percentage	<b>115.53 %</b>
V <sub>0.9D-WnUp</sub>	1.38 Kn	Capacity	10.13 Kn	Passing Percentage	<b>734.06 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 14.04 mm    Limit by Woolcock et al, 1999 Span/100 = 30.00 mm  
Sag during installation = 6.06 mm

**Reactions**

Maximum = 1.38 kn

**Girt Design Sides**

Girt's Spacing = 1300 mm                      Girt's Span = 2500 mm                      Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.80    S1 Downward =10.36    S1 Upward =17.27

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

M <sub>Wind+Snow</sub>	1.04 Kn-m	Capacity	1.32 Kn-m	Passing Percentage	<b>126.92 %</b>
V <sub>0.9D-WnUp</sub>	1.66 Kn	Capacity	10.13 Kn	Passing Percentage	<b>610.24 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 9.78 mm    Limit by Woolcock et al. 1999 Span/100 = 25.00 mm  
Sag during installation =2.92 mm

**Reactions**

Maximum = 1.66 kn

## End Pole Design

### Geometry For End Bay Pole

#### Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	3150 mm
Area	20729 mm <sup>2</sup>	As	15546.6796875 mm <sup>2</sup>
Ix	34210793 mm <sup>4</sup>	Zx	421056 mm <sup>3</sup>
Iy	34210793 mm <sup>4</sup>	Zy	421056 mm <sup>3</sup>
Lateral Restraint	mm c/c		

#### Loads

Total Area over Pole = 15 m<sup>2</sup>

Dead	3.75 Kn	Live	3.75 Kn
Wind Down	7.80 Kn	Snow	0.00 Kn
Moment Wind	5.29 Kn-m		
Phi	0.8	K8	0.70
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

#### Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

#### Capacities

PhiNcx Wind	209.10 Kn	PhiMnx Wind	8.57 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	125.46 Kn	PhiMnx Dead	5.14 Kn-m	PhiVnx Dead	22.09 Kn

#### Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.69 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.45 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 26.27 \text{ mm} < 33.42 \text{ mm}$$

Pole Shed App Ver 01 2022

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2513 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Total Area over Pole = 15 m<sup>2</sup>

Moment Wind =	5.29 Kn-m
Shear Wind =	2.11 Kn

**Pile Properties**

Safety Factor	0.55	
Hu =	6.25 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.46 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities = 0.56 < 1 OK

**Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

**Geometry For End Bay Pole**

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2513 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	5.29 Kn-m
Shear Wind =	2.11 Kn

**Pile Properties**

Pole Shed App Ver 01 2022

Safety Factor	0.55	
Hu =	6.25 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.46 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities =  $0.56 < 1$  OK

**Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x  $0.5 \times \tan(30) \times \pi \times \text{Dia of Pile}(0.6) \times \text{Height of Pile}(1400)$

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 20.41 Kn

Uplift on one Pile = 15.82 Kn

Uplift is ok