

Job No.: Guadagin - 1
Latitude: -40.060608

Address: 59 Arapata Road, Waituna West 4779, New Zealand
Longitude: 175.59898

Date: 15/02/2024
Elevation: 254.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5 m
Wind Region	NZ2	Terrain Category	2.28	Design Wind Speed	40.37 m/s
Wind Pressure	0.98 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Enclosed

For roof $C_{p,i} = -0.5832$

For roof $C_{p,e}$ from 0 m To 1.65 m $C_{p,e} = -1.028$ $p_e = -0.91$ KPa $p_{net} = -1.37$ KPa

For roof $C_{p,e}$ from 1.65 m To 3.30 m $C_{p,e} = -0.836$ $p_e = -0.74$ KPa $p_{net} = -1.20$ KPa

For wall Windward $C_{p,i} = 0.4645$ side Wall $C_{p,i} = -0.5823$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 10 m $C_{p,e} = 0.7$ $p_e = 0.62$ KPa $p_{net} = 1.19$ KPa

For side wall $C_{p,e}$ from 0 m To 3.30 m $C_{p,e} =$ $p_e = -0.58$ KPa $p_{net} = -0.01$ KPa

Maximum Upward pressure used in roof member Design = 1.37 KPa

Maximum Downward pressure used in roof member Design = 0.75 KPa

Maximum Wall pressure used in Design = 1.19 KPa

Maximum Racking pressure used in Design = 1.06 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm

Purlin Span = 3183 mm

Try Purlin 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.77 S1 Downward = 9.63 S1 Upward = 17.97

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.38 Kn-m	Capacity	1.26 Kn-m	Passing Percentage	331.58 %
$M_{1.2D+1.5L 1.2D+S_n 1.2D+W_nDn}$	1.22 Kn-m	Capacity	1.68 Kn-m	Passing Percentage	137.70 %
$M_{0.9D-W_nUp}$	-1.31 Kn-m	Capacity	-1.62 Kn-m	Passing Percentage	123.66 %

Pole Shed App Ver 01 2022

V _{1.35D}	0.48 Kn	Capacity	7.24 Kn	Passing Percentage	1508.33 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.50 Kn	Capacity	9.65 Kn	Passing Percentage	643.33 %
V _{0.9D-W_nUp}	-1.64 Kn	Capacity	-12.06 Kn	Passing Percentage	735.37 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 7.19 mm

Limit by Woolcock et al, 1999 Span/240 = 13.05 mm

Deflection under Dead and Service Wind = 10.49 mm

Limit by Woolcock et al, 1999 Span/100 = 31.33 mm

Reactions

Maximum downward = 1.50 kn Maximum upward = -1.64 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 3333 mm

Internal Rafter Span = 11850 mm

Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 6.81 S₁ Upward = 6.81

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	19.74 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	51.06 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	61.43 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	21.88 %
M _{0.9D-W_nUp}	-66.99 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	25.08 %
V _{1.35D}	6.66 Kn	Capacity	28.94 Kn	Passing Percentage	434.53 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	20.74 Kn	Capacity	38.6 Kn	Passing Percentage	186.11 %
V _{0.9D-W_nUp}	-22.61 Kn	Capacity	-48.24 Kn	Passing Percentage	213.36 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 199.98 mm

Limit by Woolcock et al, 1999 Span/240 = 50.00 mm

Deflection under Dead and Service Wind = 324.04 mm

Limit by Woolcock et al, 1999 Span/100 = 120.00 mm

Reactions

Maximum downward = 20.74 kn Maximum upward = -22.61 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Second page

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 14.9$ $f_{pj} = 12.9$ Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

$K_{11} = 2.0$ $f_{cj} = 36.1$ Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 21.67 Kn > -22.61 Kn

Rafter Design External

External Rafter Load Width = 1666.5 mm

External Rafter Span = 6728 mm

Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.94

K_8 Upward = 0.94 S_1 Downward = 13.93 S_1 Upward = 13.93

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.18 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	148.43 %
$M_{1.2D+1.5L\ 1.2D+S_n\ 1.2D+W_nD_n}$	9.90 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	63.64 %
$M_{0.9D-W_nUp}$	-10.80 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	72.87 %
$V_{1.35D}$	1.89 Kn	Capacity	14.47 Kn	Passing Percentage	765.61 %
$V_{1.2D+1.5L\ 1.2D+S_n\ 1.2D+W_nD_n}$	5.89 Kn	Capacity	19.30 Kn	Passing Percentage	327.67 %
$V_{0.9D-W_nUp}$	-6.42 Kn	Capacity	-24.12 Kn	Passing Percentage	375.70 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 13.89 mm

Limit by Woolcock et al, 1999 Span/240 = 25.00 mm

Deflection under Dead and Service Wind = 20.25 mm

Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

Reactions

Maximum downward = 5.89 kn Maximum upward = -6.42 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 14.9 \text{ fpj} = 12.9 \text{ Mpa}$ for Rafter with effective thickness = 50 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ fcj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$ (Eq 4.12) = -25.20 kn > -6.42 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -6.42 Kn

Intermediate Design Sides

Intermediate Spacing = 3000 mm Intermediate Span = 3118 mm Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 1.00 S_1 Downward = 9.63 S_1 Upward = 0.57

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	2.17 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	193.55 %
$V_{0.9D-WnUp}$	2.78 Kn-m	Capacity	24.12 Kn-m	Passing Percentage	867.63 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 28.925 mm Limit by Woolcock et al, 1999 Span/100 = 31.18 mm

Reactions

Maximum = 2.78 kn

Girt Design Front and Back

Girt's Spacing = 900 mm Girt's Span = 1667 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.96 S_1 Downward = 9.63 S_1 Upward = 13.11

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	0.37 Kn-m	Capacity	2.02 Kn-m	Passing Percentage	545.95 %
$V_{0.9D-WnUp}$	0.89 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	1355.06 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 1.14 mm Limit by Woolcock et al, 1999 Span/100 = 16.66 mm

Sag during installation = 0.47 mm

Reactions

Maximum = 0.89 kn

Girt Design Sides

Girt's Spacing = 900 mm

Girt's Span = 3000 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.79 S1 Downward =9.63 S1 Upward =17.59

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	1.20 Kn-m	Capacity	1.65 Kn-m	Passing Percentage	137.50 %
V _{0.9D-WnUp}	1.61 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	749.07 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 11.99 mm

Limit by Woolcock et al. 1999 Span/100 = 30.00 mm

Sag during installation =4.91 mm

Reactions

Maximum = 1.61 kn

Middle Pole Design

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	mm
Area	20729 mm ²	As	15546.6796875 mm ²
I _x	34210793 mm ⁴	Z _x	421056 mm ³
I _y	34210793 mm ⁴	Z _y	421056 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 19.998 m²

Dead	5.00 Kn	Live	5.00 Kn
Wind Down	15.00 Kn	Snow	0.00 Kn
Moment wind	16.52 Kn-m		
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Pole Shed App Ver 01 2022

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	$E =$	9257 MPa

Capacities

PhiNcx Wind	298.50 Kn	PhiMnx Wind	12.23 Kn-m	PhiVnx Wind	36.81 Kn
PhiNcx Dead	179.10 Kn	PhiMnx Dead	7.34 Kn-m	PhiVnx Dead	22.09 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 1.43 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 1.91 < 1$ OK

Deflection at top under service lateral loads = 0.00 mm < 0.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
$K_0 =$	$(1 - \sin(30)) / (1 + \sin(30))$				
$K_p =$	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

$D_s =$	0.6 mm	Pile Diameter
$L =$	mm	Pile embedment length
$f_1 =$	3750 mm	Distance at which the shear force is applied
$f_2 =$	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	16.52 Kn-m
Shear Wind =	4.41 Kn

Pile Properties

Safety Factory	0.55	
$H_u =$	0.00 Kn	Ultimate Lateral Strength of the Pile, Short pile
$M_u =$	0.00 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = Infinity < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	4700 mm
Area	20729 mm ²	A_s	15546.6796875 mm ²

Pole Shed App Ver 01 2022

Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zy	421056 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 9.999 m²

Dead	2.50 Kn	Live	2.50 Kn
Wind Down	7.50 Kn	Snow	0.00 Kn
Moment Wind	5.51 Kn-m		
Phi	0.8	K8	0.35
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f _b =	36.3 MPa	f _s =	2.96 MPa
f _c =	18 MPa	f _p =	7.2 MPa
f _t =	22 MPa	E =	9257 MPa

Capacities

PhiN _{cx} Wind	103.93 Kn	PhiM _{nx} Wind	4.26 Kn-m	PhiV _{nx} Wind	36.81 Kn
PhiN _{cx} Dead	62.36 Kn	PhiM _{nx} Dead	2.55 Kn-m	PhiV _{nx} Dead	22.09 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 1.41 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 1.79 < 1$ OK

Deflection at top under service lateral loads = 60.92 mm < 49.88 mm

D _s =	0.6 mm	Pile Diameter
L =	mm	Pile embedment length
f ₁ =	3750 mm	Distance at which the shear force is applied
f ₂ =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 9.999 m²

Moment Wind =	5.51 Kn-m
Shear Wind =	1.47 Kn

Pile Properties

Safety Factory	0.55	
H _u =	0.00 Kn	Ultimate Lateral Strength of the Pile, Short pile
M _u =	0.00 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = Infinity < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	mm	Pile embedment length
f1 =	3750 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	5.51 Kn-m
Shear Wind =	1.47 Kn

Pile Properties

Safety Factory	0.55	
Hu =	0.00 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	0.00 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = Infinity < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile() x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile()

Skin Friction = 0.00 Kn

Weight of Pile + Pile Skin Friction = 0.00 Kn

Uplift on one Pile = 22.90 Kn

Uplift is ok