Pole Shed App Ver 01 2022

Pole Shed App Ver 01 2022

Job No.: 4 ONeills Road Swanson - 1 **Address:** 4 ONeills Road, Swanson, New Zealand **Date:** 19/08/2024

Latitude: -36.866736 **Longitude:** 174.587101 **Elevation:** 37.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	6 m
Wind Region	NZ1	Terrain Category	3.0	Design Wind Speed	33.58 m/s
Wind Pressure	0.68 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Medium	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Open

For roof Cp,i = 0.63

For roof CP,e from 0 m To 2.85 m Cpe = -0.9145 pe = -0.55 KPa pnet = -1.10 KPa

For roof CP,e from 2.85 m To 5.70 m Cpe = -0.8927 pe = -0.54 KPa pnet = -1.00 KPa

For wall Windward Cp,i = 0.63 side Wall Cp,i = -0.52

For wall Windward and Leeward CP,e from 0 m To 36 m Cpe = 0.7 pe = 0.43 KPa pnet = 0.81 KPa

For side wall CP,e from 0 m To 5.7 m Cpe = pe = -0.40 KPa pnet = -0.02 KPa

Maximum Upward pressure used in roof member Design = 1.01 KPa

Maximum Downward pressure used in roof member Design = 0.50 KPa

Maximum Wall pressure used in Design = 0.81 KPa

Maximum Racking pressure used in Design = 0.73 KPa

Design Summary

Girt Design Front and Back

Girt's Spacing = 0 mm Girt's Span = 1800 mm Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =11.27 S1 Upward =9.20

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	3.73 Kn-m	Passing Percentage	**Infinity %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	16.08 Kn	Passing Percentage	**Infinity %**

Deflections

Second page

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.00 mm	Limit by Woolcock et al, 1999 Span/100 = 18.00 mm
Sag during installation = 0.64 mm	

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 1300 mm	Girt's Span = 2200 mm	Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.85   S1 Downward =10.36   S1 Upward =16.20

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.64 Kn-m	Capacity	1.40 Kn-m	Passing Percentage	**218.75 %**
$V_{0.9D-WnUp}$	1.16 Kn	Capacity	10.13 Kn	Passing Percentage	**873.28 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 4.66 mm	Limit by Woolcock et al. 1999 Span/100 = 22.00 mm
Sag during installation =1.75 mm	

Reactions

Maximum = 1.16 kn

End Pole Design

Geometry For End Bay Pole

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	5850 mm
Area	27598 mm2	As	20698.2421875 mm2
Ix	60639381 mm4	Zx	646820 mm3
Iy	60639381 mm4	Zx	646820 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 3.96 m2

Dead	0.99 Kn	Live	0.99 Kn
Wind Down	1.98 Kn	Snow	0.00 Kn
Moment Wind	2.95 Kn-m		
Phi	0.8	K8	0.30

K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	119.47 Kn	PhiMnx Wind	5.65 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	71.68 Kn	PhiMnx Dead	3.39 Kn-m	PhiVnx Dead	29.41 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.56 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.31 < 1 OK

Deflection at top under service lateral loads = 26.51 mm < 59.85 mm

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	4500 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 3.96 m2

Moment Wind =	2.95 Kn-m
Shear Wind =	0.66 Kn

Pile Properties

Safety Factory	0.55	
Hu =	3.38 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.68 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.34 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter

L =	1300 mm	Pile embedment length
f1 =	4500 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	2.95 Kn-m
Shear Wind =	0.66 Kn

Pile Properties

Safety Factory	0.55	
Hu =	3.38 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	8.68 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.34 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2000) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2000)

Skin Friction = 32.31 Kn

Weight of Pile + Pile Skin Friction = 35.80 Kn

Uplift on one Pile = 15.54 Kn

Uplift is ok