First Page

Job No.: 7 Terrace Road Reikorangi Waikanae   **Address:** 7 Terrace Road, Waikanae, New Zealand   **Date:** 23/07/2024

Latitude: -40.902599   **Longitude:** 175.11522   **Elevation:** 132.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N1	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.55 m
Wind Region	NZ2	Terrain Category	2.24	Design Wind Speed	39.24 m/s
Wind Pressure	0.92 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof $C_{p,i}$ = -0.3

For roof $C_{P,e}$ from 0 m To 4.55 m C_{pe} = -0.9 pe = -0.75 KPa pnet = -0.75 KPa

For roof $C_{P,e}$ from 4.55 m To 9.10 m C_{pe} = -0.5 pe = -0.42 KPa pnet = -0.42 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward $C_{P,e}$ from 0 m To 9 m C_{pe} = 0.7 pe = 0.58 KPa pnet = 0.86 KPa

For side wall $C_{P,e}$ from 0 m To 4.55 m C_{pe} =   pe = -0.54 KPa pnet = -0.54 KPa

Maximum Upward pressure used in roof member Design = 0.75 KPa

Maximum Downward pressure used in roof member Design = 0.45 KPa

Maximum Wall pressure used in Design = 0.86 KPa

Maximum Racking pressure used in Design = 1 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm   Purlin Span = 4050 mm   Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.98

K8 Upward =0.43   S1 Downward =12.23   S1 Upward =25.78

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.62 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	**288.71 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.67 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	**142.51 %**
$M_{0.9D-WnUp}$	-0.97 Kn-m	Capacity	-1.32 Kn-m	Passing Percentage	**136.08 %**

Second page

$V_{1.35D}$	0.62 Kn	Capacity	8.25 Kn	Passing Percentage	**1330.65 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.37 Kn	Capacity	11.00 Kn	Passing Percentage	**802.92 %**
$V_{0.9D-WnUp}$	-0.96 Kn	Capacity	-13.75 Kn	Passing Percentage	**1432.29 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 10.44 mm   Limit by Woolcock et al, 1999 Span/240 = 16.67 mm
Deflection under Dead and Service Wind = 12.62 mm   Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

Reactions

Maximum downward =1.37 kn   Maximum upward = -0.96 kn

Number of Blocking = 0   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4200 mm   Internal Rafter Span = 4350 mm   Try Rafter 2x290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =7.47   S1 Upward =7.47

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.35 Kn-m	Capacity	8.48 Kn-m	Passing Percentage	**253.13 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	7.45 Kn-m	Capacity	11.3 Kn-m	Passing Percentage	**151.68 %**
$M_{0.9D-WnUp}$	-5.22 Kn-m	Capacity	-14.12 Kn-m	Passing Percentage	**270.50 %**
$V_{1.35D}$	3.08 Kn	Capacity	25.18 Kn	Passing Percentage	**817.53 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	6.85 Kn	Capacity	33.58 Kn	Passing Percentage	**490.22 %**
$V_{0.9D-WnUp}$	-4.80 Kn	Capacity	-41.96 Kn	Passing Percentage	**874.17 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 6.13 mm   Limit by Woolcock et al, 1999 Span/240 = 18.75 mm
Deflection under Dead and Service Wind = 8.23 mm   Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

Reactions

Maximum downward =6.85 kn   Maximum upward = -4.80 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K_{11} = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K_{11} = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 19.50 Kn > -4.80 Kn

Rafter Design External

External Rafter Load Width = 2100 mm   External Rafter Span = 4766 mm   Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 K_4 =1 K_5 =1 K_8 Downward =0.89

K_8 Upward =0.89 S_1 Downward =15.23 S_1 Upward =15.23

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	2.01 Kn-m	Capacity	3.78 Kn-m	Passing Percentage	**188.06 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	4.47 Kn-m	Capacity	5.04 Kn-m	Passing Percentage	**112.75 %**
$M_{0.9D-WnUp}$	-3.13 Kn-m	Capacity	-6.29 Kn-m	Passing Percentage	**200.96 %**
$V_{1.35D}$	1.69 Kn	Capacity	12.59 Kn	Passing Percentage	**744.97 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	3.75 Kn	Capacity	16.79 Kn	Passing Percentage	**447.73 %**
$V_{0.9D-WnUp}$	-2.63 Kn	Capacity	-20.98 Kn	Passing Percentage	**797.72 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 6.81 mm   Limit by Woolcock et al, 1999 Span/240= 18.75 mm
Deflection under Dead and Service Wind = 8.23 mm   Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

Reactions

Maximum downward =3.75 kn   Maximum upward = -2.63 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -21.73 kn > -2.63 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -2.63 Kn

Intermediate Design Sides

Intermediate Spacing = 2250 mm   Intermediate Span = 3350 mm   Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =10.36   S1 Upward =0.63

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.36 Kn-m	Capacity	3.3 Kn-m	Passing Percentage	**242.65 %**
$V_{0.9D-WnUp}$	1.62 Kn	Capacity	20.26 Kn	Passing Percentage	**1250.62 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 28.55 mm   Limit by Woolcock et al, 1999 Span/100 = 33.50 mm

Reactions

Maximum = 1.62 kn

Girt Design Front and Back

Girt's Spacing = 750 mm   Girt's Span = 4200 mm   Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.87   S1 Downward =10.36   S1 Upward =15.83

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.42 Kn-m	Capacity	1.43 Kn-m	Passing Percentage	**100.70 %**
$V_{0.9D-WnUp}$	1.35 Kn	Capacity	10.13 Kn	Passing Percentage	**750.37 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 37.91 mm   Limit by Woolcock et al, 1999 Span/100 = 42.00 mm

Sag during installation = 23.29 mm

Reactions

Maximum = 1.35 kn

Girt Design Sides

Girt's Spacing = 1300 mm   Girt's Span = 2250 mm   Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.84   S1 Downward =10.36   S1 Upward =16.38

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.71 Kn-m	Capacity	1.39 Kn-m	Passing Percentage	**195.77 %**
$V_{0.9D-WnUp}$	1.26 Kn	Capacity	10.13 Kn	Passing Percentage	**803.97 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 5.41 mm   Limit by Woolcock et al. 1999 Span/100 = 22.50 mm
Sag during installation =1.92 mm

Reactions

Maximum = 1.26 kn

Middle Pole Design

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	5310 mm
Area	35448 mm2	As	26585.7421875 mm2
Ix	100042702 mm4	Zx	941578 mm3
Iy	100042702 mm4	Zx	941578 mm3
Lateral Restraint	5310 mm c/c		

Loads

Total Area over Pole = 18.9 m2

Dead	4.72 Kn	Live	4.72 Kn
Wind Down	8.51 Kn	Snow	0.00 Kn
Moment wind	10.84 Kn-m		
Phi	0.8	K8	0.46
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling		Steaming		Normal		Dry Use	
f_b =	36.3 MPa			f_s =		2.96 MPa	
f_c =	18 MPa			f_p =		7.2 MPa	
f_t =	22 MPa			E =		9257 MPa	

Capacities

PhiNcx Wind	234.99 Kn	PhiMnx Wind	12.59 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	140.99 Kn	PhiMnx Dead	7.55 Kn-m	PhiVnx Dead	37.77 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.94 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.82 < 1 OK

Deflection at top under service lateral loads = 39.74 mm < 53.10 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3
K_0 =	(1-sin(30)) / (1+sin(30))					
K_p =	(1+sin(30)) / (1-sin(30))					

Geometry For Middle Bay Pole

D_s =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f1 =	3412 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	10.84 Kn-m
Shear Wind =	3.18 Kn

Pile Properties

Safety Factory	0.55	
H_u =	5.59 Kn	Ultimate Lateral Strength of the Pile, Short pile
M_u =	11.18 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.97 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	4350 mm
Area	35448 mm2	As	26585.7421875 mm2

Ix			100042702 mm4	Zx	941578 mm3
Iy			100042702 mm4	Zx	941578 mm3
Lateral Restraint			mm c/c		

Loads

Total Area over Pole = 9.45 m2

Dead	2.36 Kn	Live	2.36 Kn
Wind Down	4.25 Kn	Snow	0.00 Kn
Moment Wind	5.42 Kn-m		
Phi	0.8	K8	0.65
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f_b =	36.3 MPa	f_s =	2.96 MPa
f_c =	18 MPa	f_p =	7.2 MPa
f_t =	22 MPa	E =	9257 MPa

Capacities

| PhiNcx Wind | 330.42 Kn | PhiMnx Wind | 17.70 Kn-m | PhiVnx Wind | 62.96 Kn |
| PhiNcx Dead | 198.25 Kn | PhiMnx Dead | 10.62 Kn-m | PhiVnx Dead | 37.77 Kn |

Checks

$(M_x/PhiMnx)+(N/phiNcx) = 0.33 < 1$ OK

$(M_x/PhiMnx)^2+(N/phiNcx) = 0.12 < 1$ OK

Deflection at top under service lateral loads = 16.98 mm < 45.39 mm

Ds =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f1 =	3412 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 9.45 m2

| Moment Wind = | 5.42 Kn-m |
| Shear Wind = | 1.59 Kn |

Pile Properties

Safety Factory	0.55	
Hu =	5.59 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.18 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.48 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma   18 Kn/m3   Friction angle   30 deg   Cohesion   0 Kn/m3

$K0 =$ (1-sin(30)) / (1+sin(30))

$Kp =$ (1+sin(30)) / (1-sin(30))

Geometry For End Bay Pole

$Ds =$ 0.6 mm   Pile Diameter

$L =$ 1450 mm   Pile embedment length

$f1 =$ 3412 mm   Distance at which the shear force is applied

$f2 =$ 0 mm   Distance of top soil at rest pressure

Loads

Moment Wind =   5.42 Kn-m

Shear Wind =   1.59 Kn

Pile Properties

Safety Factory   0.55

$Hu =$ 5.59 Kn   Ultimate Lateral Strength of the Pile, Short pile

$Mu =$ 11.18 Kn-m   Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.48 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1450) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1450)

Skin Friction = 16.98 Kn

Weight of Pile + Pile Skin Friction = 20.75 Kn

Uplift on one Pile = 9.92 Kn

Uplift is ok

Last Page