Pole Shed App Ver 01 2022

Job No.: EHB 203 **Address:** 67 William Street Appleby, Invercargill, New Zealand **Date:** 09/05/2024

Latitude: -46.432167 **Longitude:** 168.355369 **Elevation:** 12 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.3 m
Wind Region	NZ4	Terrain Category	2.89	Design Wind Speed	34.98 m/s
Wind Pressure	0.73 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Medium	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Free

For roof Cp,i = -0.3

For roof CP,e from 0 m To 1.43 m Cpe = -1.1333 pe = -0.75 KPa pnet = -0.75 KPa

For roof CP,e from 1.43 m To 2.85 m Cpe = -0.7833 pe = -0.52 KPa pnet = -0.52 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 6 m Cpe = 0.7 pe = 0.46 KPa pnet = 0.68 KPa

For side wall CP,e from 0 m To 2.85 m Cpe = pe = -0.43 KPa pnet = -0.43 KPa

Maximum Upward pressure used in roof member Design = 0.75 KPa

Maximum Downward pressure used in roof member Design = 0.29 KPa

Maximum Wall pressure used in Design = 0.68 KPa

Maximum Racking pressure used in Design = 0.35 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm Purlin Span = 3450 mm Try Purlin 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.73 S1 Downward =9.63 S1 Upward =18.72

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.45 Kn-m	Capacity	1.26 Kn-m	Passing Percentage	**280.00 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.35 Kn-m	Capacity	1.68 Kn-m	Passing Percentage	**124.44 %**
$M_{0.9D-WnUp}$	-0.7 Kn-m	Capacity	-1.54 Kn-m	Passing Percentage	**220.00 %**
$V_{1.35D}$	0.52 Kn	Capacity	7.24 Kn	Passing Percentage	**1392.31 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.44 Kn	Capacity	9.65 Kn	Passing Percentage	**670.14 %**
$V_{0.9D\text{-}WnUp}$	-0.82 Kn	Capacity	-12.06 Kn	Passing Percentage	**1470.73 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 9.97 mm   Limit by Woolcock et al, 1999 Span/240 = 14.17 mm
Deflection under Dead and Service Wind = 10.72 mm   Limit by Woolcock et al, 1999 Span/100 = 34.00 mm

Reactions

Maximum downward =1.44 kn   Maximum upward = -0.82 kn

Number of Blocking = 0   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design External

External Rafter Load Width = 1800 mm   External Rafter Span = 5867 mm   Try Rafter 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.94

K8 Upward =0.94   S1 Downward =13.93   S1 Upward =13.93

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	2.61 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	**180.84 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	7.20 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	**87.50 %**
$M_{0.9D\text{-}WnUp}$	-4.07 Kn-m	Capacity	-7.87 Kn-m	Passing Percentage	**193.37 %**
$V_{1.35D}$	1.78 Kn	Capacity	14.47 Kn	Passing Percentage	**812.92 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	4.91 Kn	Capacity	19.30 Kn	Passing Percentage	**393.08 %**
$V_{0.9D\text{-}WnUp}$	-2.77 Kn	Capacity	-24.12 Kn	Passing Percentage	**870.76 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 15.00 mm   Limit by Woolcock et al, 1999 Span/240= 25.00 mm
Deflection under Dead and Service Wind = 16.13 mm   Limit by Woolcock et al, 1999 Span/100 = 60.00 mm

Reactions

Maximum downward =4.91 kn   Maximum upward = -2.77 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -25.20 kn > -2.77 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -2.77 Kn

Girt Design Front and Back

Girt's Spacing = 0 mm Girt's Span = 1800 mm Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm Limit by Woolcock et al, 1999 Span/100 = 18.00 mm
Sag during installation = NaN mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm Girt's Span = 3000 mm Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm	Limit by Woolcock et al. 1999 Span/100 = 30.00 mm
Sag during installation =NaN mm	

Reactions

Maximum = 0.00 kn

End Pole Design

Geometry For End Bay Pole

Geometry

150x150 SG8 Dry	Dry Use	Height	3000 mm
Area	22500 mm2	As	16875 mm2
Ix	42187500 mm4	Zx	562500 mm3
Iy	42187500 mm4	Zx	562500 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 10.8 m2

Dead	2.70 Kn	Live	2.70 Kn
Wind Down	3.13 Kn	Snow	6.80 Kn
Moment Wind	1.28 Kn-m	Moment snow	1.33 Kn-m
Phi	0.8	K8	0.67
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Shaving	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	217.17 Kn	PhiMnx Wind	10.95 Kn-m	PhiVnx Wind	39.96 Kn
PhiNcx Dead	130.30 Kn	PhiMnx Dead	6.57 Kn-m	PhiVnx Dead	23.98 Kn
PhiNcx Snow	173.73 Kn	PhiMnx Snow	8.76 Kn-m	PhiVnx Snow	31.97 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.22 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.09 < 1 OK

Deflection at top under service lateral loads = 5.01 mm < 32.92 mm

Ds =	0.6 mm	Pile Diameter

L =	1300 mm	Pile embedment length
f1 =	2475 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 10.8 m2

Moment Wind =	1.28 Kn-m	Moment Snow =	1.33 Kn-m
Shear Wind =	0.52 Kn	Shear Snow =	1.33 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.19 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.68 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.26 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1300 mm	Pile embedment length
f1 =	2475 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	1.28 Kn-m	Moment Snow =	1.33 Kn-m
Shear Wind =	0.52 Kn	Shear Snow =	1.33 Kn

Pile Properties

Safety Factory	0.55	
Hu =	5.19 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	7.68 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.26 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1300)

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 17.91 Kn

Uplift on one Pile = 5.67 Kn

Uplift is ok