Job No.: GSH391 - 1   **Address:** 17 Zwies Road West, Lintley, New Zealand   **Date:** 14/12/2023

Latitude: -45.78195   **Longitude:** 168.474331   **Elevation:** 182 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.6 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	38.22 m/s
Wind Pressure	0.88 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Open

For roof $C_{p,i}$ = 0.6704

For roof CP,e from 0 m To 1.71 m Cpe = -0.8717 pe = -0.56 KPa $pnet$ = -1.08 KPa

For roof CP,e from 1.71 m To 3.43 m Cpe = -0.8717 pe = -0.56 KPa $pnet$ = -1.08 KPa

For wall Windward $C_{p,i}$ = 0.6704   side Wall $C_{p,i}$ = -0.5951

For wall Windward and Leeward CP,e from 0 m To 10.6 m Cpe = 0.7 pe = 0.55 KPa $pnet$ = 1.12 KPa

For side wall CP,e from 0 m To 3.43 m Cpe = pe = -0.51 KPa $pnet$ = 0.06 KPa

Maximum Upward pressure used in roof member Design = 1.08 KPa

Maximum Downward pressure used in roof member Design = 0.73 KPa

Maximum Wall pressure used in Design = 1.12 KPa

Maximum Racking pressure used in Design = 0.94 KPa

Design Summary

Girt Design Front and Back

Girt's Spacing = 600 mm   Girt's Span = 3600 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after

installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.71   S1 Downward =9.63   S1 Upward =19.27

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{Wind+Snow}$ | 1.09 Kn-m | Capacity | 1.48 Kn-m | Passing Percentage | **135.78 %** |
| $V_{0.9D-WnUp}$ | 1.21 Kn-m | Capacity | 12.06 Kn-m | Passing Percentage | **996.69 %** |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 24.37 mm   Limit by Woolcock et al, 1999 Span/100 = 36.00 mm
Sag during installation = 10.18 mm

Reactions

Maximum = 1.21 kn

Girt Design Sides

Girt's Spacing = 600 mm   Girt's Span = 4000 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.65   S1 Downward =9.63   S1 Upward =20.31

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

| $M_{Wind+Snow}$ | 1.34 Kn-m | Capacity | 1.38 Kn-m | Passing Percentage | **102.99 %** |
| $V_{0.9D-WnUp}$ | 1.34 Kn-m | Capacity | 12.06 Kn-m | Passing Percentage | **900.00 %** |

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 37.15 mm   Limit by Woolcock et al. 1999 Span/100 = 40.00 mm

Second page

Sag during installation =15.52 mm

Reactions

Maximum = 1.34 kn

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 19.92 Kn

Uplift on one Pile = 9.23 Kn

Uplift is ok

Last Page