First Page

Job No.: Colin & Marian Merrin   **Address:** 21 Waiata Rd, Wairoa, New Zealand   **Date:** 09/07/2024

Latitude: -37.715533   **Longitude:** 176.033217   **Elevation:** 258 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.3 m
Wind Region	NZ1	Terrain Category	2.1	Design Wind Speed	41.53 m/s
Wind Pressure	1.03 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Open

For roof $C_{p,i} = 0.6773$

For roof $C_{P,e}$ from 0 m To 1.58 m $C_{pe} = -1.025$ $p_e = -0.87$ KPa $p_{net} = -1.56$ KPa

For roof $C_{P,e}$ from 1.58 m To 3.15 m $C_{pe} = -0.8375$ $p_e = -0.71$ KPa $p_{net} = -1.08$ KPa

For wall Windward $C_{p,i} = 0.6773$ side Wall $C_{p,i} = -0.6078$

For wall Windward and Leeward $C_{P,e}$ from 0 m To 7.2 m $C_{pe} = 0.7$ $p_e = 0.65$ KPa $p_{net} = 1.33$ KPa

For side wall $C_{P,e}$ from 0 m To 3.15 m $C_{pe} =$ $p_e = -0.61$ KPa $p_{net} = 0.07$ KPa

Maximum Upward pressure used in roof member Design = 1.56 KPa

Maximum Downward pressure used in roof member Design = 0.77 KPa

Maximum Wall pressure used in Design = 1.33 KPa

Maximum Racking pressure used in Design = 1.12 KPa

Design Summary

Purlin Design

Purlin Spacing = 750 mm   Purlin Span = 3450 mm   Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.98

K8 Upward =0.50   S1 Downward =12.23   S1 Upward =23.77

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.38 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	**471.05 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.28 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	**185.94 %**
$M_{0.9D-WnUp}$	-1.49 Kn-m	Capacity	-1.52 Kn-m	Passing Percentage	**80.85 %**
$V_{1.35D}$	0.44 Kn	Capacity	8.25 Kn	Passing Percentage	**1875.00 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.38 Kn	Capacity	11.00 Kn	Passing Percentage	**797.10 %**
$V_{0.9D-WnUp}$	-1.73 Kn	Capacity	-13.75 Kn	Passing Percentage	**794.80 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 4.54 mm   Limit by Woolcock et al, 1999 Span/240 = 14.17 mm

Deflection under Dead and Service Wind = 6.70 mm   Limit by Woolcock et al, 1999 Span/100 = 34.00 mm

Reactions

Maximum downward =1.38 kn   Maximum upward = -1.73 kn

Number of Blocking = 0   if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 3600 mm   Internal Rafter Span = 4650 mm   Try Rafter 2x290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =7.47   S1 Upward =7.47

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.28 Kn-m	Capacity	8.48 Kn-m	Passing Percentage	**258.54 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	10.41 Kn-m	Capacity	11.3 Kn-m	Passing Percentage	**108.55 %**
$M_{0.9D-WnUp}$	-12.99 Kn-m	Capacity	-14.12 Kn-m	Passing Percentage	**108.70 %**
$V_{1.35D}$	2.82 Kn	Capacity	25.18 Kn	Passing Percentage	**892.91 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	8.96 Kn	Capacity	33.58 Kn	Passing Percentage	**374.78 %**
$V_{0.9D-WnUp}$	-11.17 Kn	Capacity	-41.96 Kn	Passing Percentage	**375.65 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 6.8 mm   Limit by Woolcock et al, 1999 Span/240 = 20.00 mm

Deflection under Dead and Service Wind = 11.145 mm   Limit by Woolcock et al, 1999 Span/100 = 48.00 mm

Reactions

Maximum downward =8.96 kn   Maximum upward = -11.17 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 19.50 Kn > -11.17 Kn

Intermediate Design Sides

Intermediate Spacing = 2400 mm   Intermediate Span = 3000 mm   Try Intermediate 2x140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =10.36   S1 Upward =0.60

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.80 Kn-m	Capacity	3.3 Kn-m	Passing Percentage	**183.33 %**
$V_{0.9D-WnUp}$	2.39 Kn	Capacity	20.26 Kn	Passing Percentage	**847.70 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 30.285 mm   Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Reactions

Maximum = 2.39 kn

Girt Design Front and Back

Girt's Spacing = 600 mm   Girt's Span = 3600 mm   Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.91   S1 Downward =10.36   S1 Upward =14.65

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.29 Kn-m	Capacity	1.50 Kn-m	Passing Percentage	**116.28 %**
$V_{0.9D-WnUp}$	1.44 Kn	Capacity	10.13 Kn	Passing Percentage	**703.47 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 25.31 mm   Limit by Woolcock et al, 1999 Span/100 = 36.00 mm

Sag during installation = 12.57 mm

Reactions

Maximum = 1.44 kn

Girt Design Sides

Girt's Spacing = 600 mm   Girt's Span = 2400 mm   Try Girt 140x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.82   S1 Downward =10.36   S1 Upward =16.92

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.57 Kn-m	Capacity	1.35 Kn-m	Passing Percentage	**236.84 %**
$V_{0.9D-WnUp}$	0.96 Kn	Capacity	10.13 Kn	Passing Percentage	**1055.21 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 5.00 mm   Limit by Woolcock et al. 1999 Span/100 = 24.00 mm

Sag during installation =2.48 mm

Reactions

Maximum = 0.96 kn

Middle Pole Design

Geometry

175 UNI H5	Dry Use	Height	3000 mm
Area	24041 mm2	As	18030.46875 mm2
Ix	46015259 mm4	Zx	525889 mm3
Iy	46015259 mm4	Zx	525889 mm3
Lateral Restraint	1300 mm c/c		

Loads

Total Area over Pole = 8.64 m2

Dead	2.16 Kn	Live	2.16 Kn
Wind Down	6.65 Kn	Snow	0.00 Kn
Moment wind	8.21 Kn-m		
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

5/8

Shaving		Steaming		Normal		Dry Use
fb =		34.325 MPa		fs =		2.96 MPa
fc =		18 MPa		fp =		7.2 MPa
ft =		20.75 MPa		E =		8793 MPa

Capacities

PhiNcx Wind	346.19 Kn	PhiMnx Wind	14.44 Kn-m	PhiVnx Wind	42.70 Kn
PhiNcx Dead	207.71 Kn	PhiMnx Dead	8.66 Kn-m	PhiVnx Dead	25.62 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.60 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.36 < 1 OK

Deflection at top under service lateral loads = 28.23 mm < 30.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))					
Kp =	(1+sin(30)) / (1-sin(30))					

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2475 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	8.21 Kn-m
Shear Wind =	3.32 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.31 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.43 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.87 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

175 UNI H5		Dry Use		Height	3100 mm
Area		24041 mm2		As	18030.46875 mm2

Ix	46015259 mm4		Zx	525889 mm3
Iy	46015259 mm4		Zx	525889 mm3
Lateral Restraint	mm c/c			

Loads

Total Area over Pole = 8.64 m2

Dead	2.16 Kn		Live	2.16 Kn
Wind Down	6.65 Kn		Snow	0.00 Kn
Moment Wind	4.11 Kn-m			
Phi	0.8		K8	0.78
K1 snow	0.8		K1 Dead	0.6
K1wind	1			

Material

Shaving	Steaming		Normal	Dry Use
fb =	34.325 MPa		fs =	2.96 MPa
fc =	18 MPa		fp =	7.2 MPa
ft =	20.75 MPa		E =	8793 MPa

Capacities

PhiNcx Wind	270.69 Kn	PhiMnx Wind	11.29 Kn-m	PhiVnx Wind	42.70 Kn
PhiNcx Dead	162.41 Kn	PhiMnx Dead	6.78 Kn-m	PhiVnx Dead	25.62 Kn

Checks

$(Mx/PhiMnx)+(N/phiNcx) = 0.40 < 1$ OK

$(Mx/PhiMnx)^2+(N/phiNcx) = 0.17 < 1$ OK

Deflection at top under service lateral loads = 15.49 mm < 32.92 mm

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2475 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 8.64 m2

Moment Wind =	4.11 Kn-m
Shear Wind =	1.66 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.31 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.43 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.44 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3

$K0 =$ (1-sin(30)) / (1+sin(30))

$Kp =$ (1+sin(30)) / (1-sin(30))

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2475 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind = 4.11 Kn-m

Shear Wind = 1.66 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.31 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.43 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.44 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1400) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1400)

Skin Friction = 15.83 Kn

Weight of Pile + Pile Skin Friction = 20.17 Kn

Uplift on one Pile = 11.53 Kn

Uplift is ok

Last Page