

Job Number:

**BWhite
Consulting Ltd**

Issue:

PRODUCER STATEMENT-PS1-DESIGN

ISSUED BY: **BWhite Consulting Ltd (Design Engineer: Bevan White)**

TO BE SUPPLIED TO: **Clutha District Council** IN RESPECT OF: **Proposed NEW Farm Shed**

AT: **94 Brookdale Road, Kaka Point 9271, New Zealand**

LEGAL DESCRIPTION

We have been engaged by **Ezequote Pty Ltd** to provide **Specific Structural Engineering Design** services in respect of the requirements of Clause(s) **B1** of the Building Code for part only (as specified in the attachment to this statement), of the proposed building work.

☐ ALL ☒ Part only as specified: Purlins, Rafters, Girts, Poles, Columns, Pole embedment and all connections

The design has been prepared in accordance with compliance documents to NZ Building Code issued by Ministry of Business, Innovation & Employment Clauses **B1/VM1 and B1/VM4**

The proposed building work covered by the producer statement is described on **Ezequote** drawings title **EHB 248** and numbered **A101-A128 Rev-1** dated **30/08/2024** together with the following specification, and other documents set out in the schedule attached to this statement: **Design Featured Report Dated 03/09/2024 and numbered "Second Page"**

On behalf of **BWhite Consulting Ltd**, and subject to:

1. Site verification of the following design assumptions: **an Ultimate foundation bearing pressure of 300 kPa in accordance with NZS3604:2011**
2. **The building has a design life of 50 years and an Importance Level 2**
3. **Unless specifically noted, compliance of the drawings to None-Specific codes such as NZS3604 and NZS4229 have not been checked by this practice**
4. **This Certificate does not cover any other building code clause including weather tightness**
5. **Inspections of the building to be completed by Clutha District Council. As BWhite Consulting Ltd are not undertaking inspections, we cannot issue a producer Statement-PS4- Construction Review.**
6. **This Producer Statement- Design is valid for a building consent issued within 1 year from the date of issue**
7. All proprietary products meeting their performance specification requirements

I believe on reasonable grounds that a) the building, if constructed in accordance with the drawings, specifications, and other documents provided or listed in the attached schedule, will comply with the relevant provisions of the Building Code and that b), the persons who have undertaken the design have the necessary competency to do so. I also recommend the following level of construction monitoring/observation:

☒ CM1 ☐ CM2 ☐ CM3 ☐ CM4 ☐ CM5 or as per agreement with owner/developer (**stated above**)

I, Bevan White am CPEng **108276** I am Member of Engineering New Zealand and hold the following qualification: **BE.Civil** and holds a current policy of Professional Indemnity Insurance no less than \$200,000

Signed by **Bevan White** on behalf of **BWhite Consulting Ltd** Dated: **03/09/2024**

Email: bwhitecpeng@gmail.com Phone: 0211-979786

Note: This statement shall only be relied upon by the Building Consent Authority named above. Liability under this statement accrues to the Design Firm only. The total maximum amount of damages payable arising from this statement and all other statements provided to the Building Consent Authority in relation to this building work, whether in contract, tort or otherwise (including negligence), is limited to the sum of \$200,000.

This form is to accompany Form 2 of the Building (Forms) Regulations 2004 for the application of a Building Consent

Date: 03/09/2024

18B Jules Crescent,

Bell Block New Plymouth 4312

New Zealand

File No:

DESIGN FEATURES SUMMARY FOR PROPOSED NEW FARM SHED 94 BROOKDALE ROAD, KAKA POINT 9271, NEW ZEALAND

Site Specific Loads

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	2	Ultimate wind & EQ ARI	500 Years	Max Height	3 m
Wind Region	NZ2	Terrain Category	2.32	Design Wind Speed	45.28 m/s
Wind Pressure	1.23 KPa	Lee Zone	NO	Ultimate Snow ARI	150 Years

Timber

Sawn Timber to be graded to the properties of SG6 and SG8 or better as mentioned on plans, with moisture content of 18% or less for dry and 25% or less for wet.

The following standards have been used in the design of this structure

- NZS 3603:1993 Timber Structures Standard
- NZS 3604:2011 Timber Framed Buildings. Standards New Zealand, 2011
- NZS 3404:1997 Steel Structures
- AS/NZS 1170 2003 Structural Design Actions
- AS/NZS 1170.2 2021 Structural Design Actions- Wind Action
- Branz. "Engineering Basis of NZS 3604". April 2013

Yours Faithfully

BWhite CONSULTING LTD

Bevan White

Director | BE Civil . CMengNZ CPEng

Email: bwhitecpeng@gmail.com Contact: 0211 979 786

Job No.: EHB 248

Address: 94 Brookdale Road,Kaka Point 9271,New Zealand

Date: 03/09/2024

Latitude: -46.373161

Longitude: 169.765452

Elevation: 35 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	2	Ultimate wind & Earthquake ARI	500 Years	Max Height	3 m
Wind Region	NZ2	Terrain Category	2.32	Design Wind Speed	45.28 m/s
Wind Pressure	1.23 KPa	Lee Zone	NO	Ultimate Snow ARI	150 Years
Wind Category	Very High	Earthquake ARI	500		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Gable Open

For roof $C_{p,i} = 0.5616$

For roof $C_{p,e}$ from 0 m To 3.47 m $C_{p,e} = -0.9$ $p_e = -0.74$ KPa $p_{net} = -1.25$ KPa

For roof $C_{p,e}$ from 3.47 m To 6.94 m $C_{p,e} = -0.5$ $p_e = -0.41$ KPa $p_{net} = -0.92$ KPa

For wall Windward $C_{p,i} = 0.5616$ side Wall $C_{p,i} = -0.5771$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 12 m $C_{p,e} = 0.7$ $p_e = 0.78$ KPa $p_{net} = 1.49$ KPa

For side wall $C_{p,e}$ from 0 m To 3.47 m $C_{p,e} =$ $p_e = -0.72$ KPa $p_{net} = -0.01$ KPa

Maximum Upward pressure used in roof member Design = 1.25 KPa

Maximum Downward pressure used in roof member Design = 0.93 KPa

Maximum Wall pressure used in Design = 1.49 KPa

Maximum Racking pressure used in Design = 1.26 KPa

Design Summary

Purlin Design

Purlin Spacing = 850 mm

Purlin Span = 5850 mm

Try Purlin 300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.94

K8 Upward = 0.46 S1 Downward = 13.93 S1 Upward = 25.01

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	1.23 Kn-m	Capacity	4.72 Kn-m	Passing Percentage	383.74 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	4.47 Kn-m	Capacity	6.30 Kn-m	Passing Percentage	140.94 %
M _{0.9D-W_nUp}	-3.73 Kn-m	Capacity	-3.87 Kn-m	Passing Percentage	103.75 %

Pole Shed App Ver 01 2022

V _{1.35D}	0.84 Kn	Capacity	14.47 Kn	Passing Percentage	1722.62 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	3.06 Kn	Capacity	19.30 Kn	Passing Percentage	630.72 %
V _{0.9D-WnUp}	-2.55 Kn	Capacity	-24.12 Kn	Passing Percentage	945.88 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 9.97 mm	Limit by Woolcock et al, 1999 Span/360 = 16.11 mm
Deflection under Dead and Service Wind = 16.04 mm	Limit by Woolcock et al, 1999 Span/250 = 38.67 mm

Reactions

Maximum downward = 3.06 kn Maximum upward = -2.55 kn

Number of Blocking = 1 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 6000 mm Internal Rafter Span = 5150 mm Try Rafter 2x300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 7.61 S₁ Upward = 7.61

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	6.71 Kn-m	Capacity	31.1 Kn-m	Passing Percentage	463.49 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	24.47 Kn-m	Capacity	41.48 Kn-m	Passing Percentage	169.51 %
M _{0.9D-WnUp}	-20.39 Kn-m	Capacity	-51.84 Kn-m	Passing Percentage	254.24 %
V _{1.35D}	5.21 Kn	Capacity	46.02 Kn	Passing Percentage	883.30 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	19.00 Kn	Capacity	61.36 Kn	Passing Percentage	322.95 %
V _{0.9D-WnUp}	-15.84 Kn	Capacity	-76.7 Kn	Passing Percentage	484.22 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 7.47 mm	Limit by Woolcock et al, 1999 Span/360 = 14.72 mm
Deflection under Dead and Service Wind = 13.355 mm	Limit by Woolcock et al, 1999 Span/250 = 35.33 mm

Reactions

Maximum downward = 19.00 kn Maximum upward = -15.84 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ f}_{pj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 90 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ f}_{cj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -15.84 Kn

Rafter Design External

External Rafter Load Width = 3000 mm

External Rafter Span = 5137 mm

Try Rafter 300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.88

K_8 Upward = 0.88 S_1 Downward = 15.50 S_1 Upward = 15.50

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.34 Kn-m	Capacity	13.69 Kn-m	Passing Percentage	409.88 %
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	12.17 Kn-m	Capacity	18.26 Kn-m	Passing Percentage	150.04 %
$M_{0.9D-W_nUp}$	-10.14 Kn-m	Capacity	-22.82 Kn-m	Passing Percentage	225.05 %
$V_{1.35D}$	2.60 Kn	Capacity	23.01 Kn	Passing Percentage	885.00 %
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	9.48 Kn	Capacity	30.68 Kn	Passing Percentage	323.63 %
$V_{0.9D-W_nUp}$	-7.90 Kn	Capacity	-38.35 Kn	Passing Percentage	485.44 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 8.30 mm

Limit by Woolcock et al, 1999 Span/360 = 14.72 mm

Deflection under Dead and Service Wind = 13.35 mm

Limit by Woolcock et al, 1999 Span/250 = 35.33 mm

Reactions

Maximum downward = 9.48 kn Maximum upward = -7.90 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ fpj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 45 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ fcj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi_i \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots$ (Eq 4.12) = -40.07 kn > -7.90 Kn

Single Shear Capacity under short term loads = -21.83 Kn > -7.90 Kn

Intermediate Design Front and Back

Intermediate Spacing = 3000 mm

Intermediate Span = 1909 mm

Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 1.00 S_1 Downward = 9.63 S_1 Upward = 0.44

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	2.04 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	205.88 %
$V_{0.9D-WnUp}$	4.27 Kn	Capacity	-24.12 Kn	Passing Percentage	564.87 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 8.165 mm

Limit by Woolcock et al, 1999 Span/250 = 7.64 mm

Reactions

Maximum = 4.27 kn

Girt Design Front and Back

Girt's Spacing = 1150 mm

Girt's Span = 3000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.64 S_1 Downward = 11.27 S_1 Upward = 20.58

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	1.93 Kn-m	Capacity	2.40 Kn-m	Passing Percentage	124.35 %
$V_{0.9D-WnUp}$	2.57 Kn	Capacity	16.08 Kn	Passing Percentage	625.68 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 11.51 mm

Limit by Woolcock et al, 1999 Span/250 = 12.00 mm

Sag during installation = 4.91 mm

Reactions

Maximum = 2.57 kn

Girt Design Sides

Girt's Spacing = 700 mm

Girt's Span = 2650 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.84 S1 Downward =9.63 S1 Upward =16.53

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.92 Kn-m	Capacity	1.76 Kn-m	Passing Percentage	191.30 %
$V_{0.9D-WnUp}$	1.38 Kn	Capacity	12.06 Kn	Passing Percentage	873.91 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 10.11 mm

Limit by Woolcock et al. 1999 Span/100 = 10.60 mm

Sag during installation =2.99 mm

Reactions

Maximum = 1.38 kn

Middle Pole Design

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3440 mm
Area	27598 mm ²	As	20698.2421875 mm ²
I _x	60639381 mm ⁴	Z _x	646820 mm ³
I _y	60639381 mm ⁴	Z _y	646820 mm ³
Lateral Restraint	1300 mm c/c		

Loads

Total Area over Pole = 31.8 m²

Dead	7.95 Kn	Live	7.95 Kn
Wind Down	29.57 Kn	Snow	20.03 Kn
Moment wind	6.36 Kn-m	Moment snow	2.02 Kn-m
Phi	0.8	K8	1.00
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Pole Shed App Ver 01 2022

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	397.41 Kn	PhiMnx Wind	18.78 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	238.44 Kn	PhiMnx Dead	11.27 Kn-m	PhiVnx Dead	29.41 Kn
PhiNcx Snow	317.93 Kn	PhiMnx Snow	15.03 Kn-m	PhiVnx Snow	39.21 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.45 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.23 < 1$ OK

Deflection at top under service lateral loads = 16.44 mm < 22.93 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	2000 mm	Pile embedment length
f1 =	2250 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	6.36 Kn-m	Moment Snow =	Kn-m
Shear Wind =	2.83 Kn	Shear Snow =	2.02 Kn

Pile Properties

Safety Factory	0.55	
Hu =	16.77 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	24.39 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.26 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

150 SED H5 (Minimum 175 dia. at Floor Level)	Dry Use	Height	2700 mm
--	---------	--------	---------

Pole Shed App Ver 01 2022

Area	20729 mm ²	As	15546.6796875 mm ²
Ix	34210793 mm ⁴	Zx	421056 mm ³
Iy	34210793 mm ⁴	Zy	421056 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 15.9 m²

Dead	3.98 Kn	Live	3.98 Kn
Wind Down	14.79 Kn	Snow	10.02 Kn
Moment Wind	3.18 Kn-m	Moment snow	1.01 Kn-m
Phi	0.8	K _s	0.83
K ₁ snow	0.8	K ₁ Dead	0.6
K ₁ wind	1		

Material

Peeling	Steaming	Normal	Dry Use
f _b =	36.3 MPa	f _s =	2.96 MPa
f _c =	18 MPa	f _p =	7.2 MPa
f _t =	22 MPa	E =	9257 MPa

Capacities

PhiN _c Wind	248.61 Kn	PhiM _n Wind	10.18 Kn-m	PhiV _n Wind	36.81 Kn
PhiN _c Dead	149.17 Kn	PhiM _n Dead	6.11 Kn-m	PhiV _n Dead	22.09 Kn
PhiN _c Snow	198.89 Kn	PhiM _n Snow	8.15 Kn-m	PhiV _n Snow	29.45 Kn

Checks

$$(M_x/\Phi M_n) + (N/\Phi N_c) = 0.40 < 1 \text{ OK}$$

$$(M_x/\Phi M_n)^2 + (N/\Phi N_c) = 0.19 < 1 \text{ OK}$$

Deflection at top under service lateral loads = 12.67 mm < 19.95 mm

D _s =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f ₁ =	2250 mm	Distance at which the shear force is applied
f ₂ =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 15.9 m²

Moment Wind =	3.18 Kn-m	Moment Snow =	1.01 Kn-m
Shear Wind =	1.41 Kn	Shear Snow =	1.01 Kn

Pile Properties

Safety Factory	0.55		
H _u =	6.70 Kn	Ultimate Lateral Strength of the Pile, Short pile	
M _u =	9.21 Kn-m	Ultimate Moment Capacity of Pile	

Checks

Applied Forces/Capacities = $0.35 < 1$ OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1400 mm	Pile embedment length
f1 =	2250 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	3.18 Kn-m	Moment Snow =	1.01 Kn-m
Shear Wind =	1.41 Kn	Shear Snow =	1.01 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.70 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	9.21 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = $0.35 < 1$ OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(2000) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2000)

Skin Friction = 32.31 Kn

Weight of Pile + Pile Skin Friction = 38.15 Kn

Uplift on one Pile = 32.59 Kn

Uplift is ok