First Page

**Job No.:**  Mark Galvin      **Address:**  295 Te Rakehou Rd, Feilding, New Zealand      **Date:**  31/10/2024

**Latitude:**  -40.198765      **Longitude:**  175.494393      **Elevation:**  79 m

## General Input

| | | | | | |
|---|---|---|---|---|---|
| Roof Live Load | 0.25 KPa | Roof Dead Load | 0.25 KPa | Roof Live Point Load | 1.1 Kn |
| Snow Zone | N1 | Ground Snow Load | 0 KPa | Roof Snow Load | 0 KPa |
| Earthquake Zone | 3 | Subsoil Category | D | Exposure Zone | B |
| Importance Level | 1 | Ultimate wind & Earthquake ARI | 100 Years | Max Height | 5.4 m |
| Wind Region | NZ2 | Terrain Category | 2.0 | Design Wind Speed | 38.52 m/s |
| Wind Pressure | 0.89 KPa | Lee Zone | NO | Ultimate Snow ARI | 50 Years |
| Wind Category | High | Earthquake ARI | 100 | | |

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

## Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof $C_{p,i}$ = -0.3

For roof  $CP_{,e}$  from 0 m  To 5.40 m  $C_{pe}$ = -0.9   $p_e$ = -0.72 KPa   $p_{net}$ = -0.72 KPa

For roof  $CP_{,e}$  from 5.40 m  To 10.80 m  $C_{pe}$ = -0.5   $p_e$ = -0.40 KPa   $p_{net}$ = -0.40 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward   $CP_{,e}$  from 0 m  To 12 m  $C_{pe}$ = 0.7   $p_e$ = 0.56 KPa   $p_{net}$ = 0.83 KPa

For side wall  $CP_{,e}$  from 0 m  To 5.40 m  $C_{pe}$ =   $p_e$ = -0.52 KPa   $p_{net}$ = -0.52 KPa

Maximum Upward pressure used in roof member Design = 0.72 KPa

Maximum Downward pressure used in roof member Design = 0.35 KPa

Maximum Wall pressure used in Design = 0.83 KPa

Maximum Racking pressure used in Design = 0.80 KPa

## Design Summary

## Purlin Design

Purlin Spacing = 750 mm      Purlin Span = 3850 mm      Try Purlin 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.68     S1 Downward =9.63     S1 Upward =19.79

Shear Capacity of timber =3 MPa     Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{1.35D}$ | 0.47 Kn-m | Capacity | 1.26 Kn-m | Passing Percentage | **268.09 %** |
| $M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 1.48 Kn-m | Capacity | 1.68 Kn-m | Passing Percentage | **113.51 %** |
| $M_{0.9D-WnUp}$ | -0.69 Kn-m | Capacity | -1.43 Kn-m | Passing Percentage | **77.72 %** |
| $V_{1.35D}$ | 0.49 Kn | Capacity | 7.24 Kn | Passing Percentage | **1477.55 %** |

Second page

| | | | | | |
|---|---|---|---|---|---|
| $V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 0.97 Kn | Capacity | 9.65 Kn | Passing Percentage | **994.85 %** |
| $V_{0.9D-WnUp}$ | -0.71 Kn | Capacity | -12.06 Kn | Passing Percentage | **1698.59 %** |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 12.97 mm                Limit by Woolcock et al, 1999 Span/240 = 15.83 mm
Deflection under Dead and Service Wind = 14.59 mm        Limit by Woolcock et al, 1999 Span/100 = 38.00 mm

**Reactions**

Maximum downward =0.97 kn   Maximum upward = -0.71 kn

Number of Blocking = 0   if 0 then no blocking required, if 1 then one midspan blocking required

## Rafter Design External

External Rafter Load Width = 2000 mm                External Rafter Span = 3879 mm                Try Rafter 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 =1    K5 =1    K8 Downward =0.97

K8 Upward =0.97     S1 Downward =12.68     S1 Upward =12.68

Shear Capacity of timber =3 MPa     Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

**Capacity Checks**

| | | | | | |
|---|---|---|---|---|---|
| $M_{1.35D}$ | 1.27 Kn-m | Capacity | 3.40 Kn-m | Passing Percentage | **267.72 %** |
| $M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 2.54 Kn-m | Capacity | 4.53 Kn-m | Passing Percentage | **178.35 %** |
| $M_{0.9D-WnUp}$ | -1.86 Kn-m | Capacity | -5.67 Kn-m | Passing Percentage | **304.84 %** |
| $V_{1.35D}$ | 1.31 Kn | Capacity | 12.06 Kn | Passing Percentage | **920.61 %** |
| $V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$ | 2.62 Kn | Capacity | 16.08 Kn | Passing Percentage | **613.74 %** |
| $V_{0.9D-WnUp}$ | -1.92 Kn | Capacity | -20.10 Kn | Passing Percentage | **1046.88 %** |

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 5.69 mm                Limit by Woolcock et al, 1999 Span/240= 16.67 mm
Deflection under Dead and Service Wind = 6.40 mm         Limit by Woolcock et al, 1999 Span/100 = 40.00 mm

**Reactions**

Maximum downward =2.62 kn   Maximum upward = -1.92 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 50 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds ........... (Eq 4.12) = -19.95 kn > -1.92 Kn

Single Shear Capacity under short term loads = -10.84 Kn > -1.92 Kn

## Girt Design Front and Back

 Girt's Spacing = 900 mm                     Girt's Span = 4000 mm                     Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1     K4 =1     K5 =1     K8 Downward =1.00

K8 Upward =0.50     S1 Downward =11.27     S1 Upward =23.76

Shear Capacity of timber =3 MPa     Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 1.49 Kn-m | Capacity | 1.87 Kn-m | Passing Percentage | **125.50 %** |
| $V_{0.9D-WnUp}$ | 1.49 Kn | Capacity | 16.08 Kn | Passing Percentage | **1079.19 %** |

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 11.15 mm                     Limit by Woolcock et al, 1999 Span/100 = 40.00 mm
Sag during installation = 15.52 mm

### Reactions

Maximum = 1.49 kn

## Girt Design Sides

 Girt's Spacing = 900 mm                     Girt's Span = 4000 mm                     Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1     K4 =1     K5 =1     K8 Downward =1.00

K8 Upward =0.50     S1 Downward =11.27     S1 Upward =23.76

Shear Capacity of timber =3 MPa     Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

| | | | | | |
|---|---|---|---|---|---|
| $M_{Wind+Snow}$ | 1.49 Kn-m | Capacity | 1.87 Kn-m | Passing Percentage | **125.50 %** |
| $V_{0.9D-WnUp}$ | 1.49 Kn | Capacity | 16.08 Kn | Passing Percentage | **1079.19 %** |

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 11.15 mm          Limit by Woolcock et al. 1999 Span/100 = 40.00 mm

Sag during installation = 15.52 mm

**Reactions**

Maximum = 1.49 kn

## End Pole Design

**Geometry For End Bay Pole**

**Geometry**

| | | | |
|---|---|---|---|
| 200 SED H5 (Minimum 225 dia. at Floor Level) | Dry Use | Height | 5150 mm |
| Area | 35448 mm2 | As | 26585.7421875 mm2 |
| Ix | 100042702 mm4 | Zx | 941578 mm3 |
| Iy | 100042702 mm4 | Zx | 941578 mm3 |
| Lateral Restraint | mm c/c | | |

**Loads**

Total Area over Pole = 8 m2

| | | | |
|---|---|---|---|
| Dead | 2.00 Kn | Live | 2.00 Kn |
| Wind Down | 2.80 Kn | Snow | 0.00 Kn |
| Moment Wind | 4.36 Kn-m | | |
| Phi | 0.8 | K8 | 0.49 |
| K1 snow | 0.8 | K1 Dead | 0.6 |
| K1wind | 1 | | |

**Material**

| Peeling | Steaming | Normal | Dry Use |
|---|---|---|---|
| $f_b$ = | 36.3 MPa | $f_s$ = | 2.96 MPa |
| $f_c$ = | 18 MPa | $f_p$ = | 7.2 MPa |
| $f_t$ = | 22 MPa | E = | 9257 MPa |

**Capacities**

| | | | | | |
|---|---|---|---|---|---|
| PhiNcx Wind | 247.60 Kn | PhiMnx Wind | 13.26 Kn-m | PhiVnx Wind | 62.96 Kn |
| PhiNcx Dead | 148.56 Kn | PhiMnx Dead | 7.96 Kn-m | PhiVnx Dead | 37.77 Kn |

**Checks**

(Mx/PhiMnx)+(N/phiNcx) = 0.36 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.14 < 1 OK

Deflection at top under service lateral loads = 19.25 mm < 53.87 mm

| | | |
|---|---|---|
| Ds = | 0.6 mm | Pile Diameter |
| L = | 1300 mm | Pile embedment length |

| f1 = | 4050 mm | Distance at which the shear force is applied |
| f2 = | 0 mm | Distance of top soil at rest pressure |

**Loads**

Total Area over Pole = 8 m2

| Moment Wind = | 4.36 Kn-m |
| Shear Wind = | 1.08 Kn |

**Pile Properties**

| Safety Factory | 0.55 | |
| Hu = | 3.66 Kn | Ultimate Lateral Strength of the Pile, Short pile |
| Mu = | 8.52 Kn-m | Ultimate Moment Capacity of Pile |

**Checks**

Applied Forces/Capacities = 0.51 < 1 OK

## Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

**Assumed Soil Properties**

| Gamma | 18 Kn/m3 | | Friction angle | 30 deg | Cohesion | 0 Kn/m3 |
| K0 = | $(1-\sin(30)) / (1+\sin(30))$ | | | | | |
| Kp = | $(1+\sin(30)) / (1-\sin(30))$ | | | | | |

**Geometry For End Bay Pole**

| Ds = | 0.6 mm | Pile Diameter |
| L = | 1300 mm | Pile embedment length |
| f1 = | 4050 mm | Distance at which the shear force is applied |
| f2 = | 0 mm | Distance of top soil at rest pressure |

**Loads**

| Moment Wind = | 4.36 Kn-m |
| Shear Wind = | 1.08 Kn |

**Pile Properties**

| Safety Factory | 0.55 | |
| Hu = | 3.66 Kn | Ultimate Lateral Strength of the Pile, Short pile |
| Mu = | 8.52 Kn-m | Ultimate Moment Capacity of Pile |

**Checks**

Applied Forces/Capacities = 0.51 < 1 OK

## Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1300) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1300)

Skin Friction = 13.65 Kn

Weight of Pile + Pile Skin Friction = 16.63 Kn

Uplift on one Pile = 11.88 Kn

Uplift is ok

Last Page