First Page

Job No.: 483-218539C-gable   **Address:** 761 Esdaile Road, Whakamaramara, New Zealand   **Date:** 28/03/2025

Latitude: -37.707421   **Longitude:** 175.965488   **Elevation:** 272 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.2 m
Wind Region	NZ1	Terrain Category	2.15	Design Wind Speed	44.25 m/s
Wind Pressure	1.17 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Gable   Enclosed

For roof $C_{p,i}$ = -0.3

For roof $C_{P,e}$ from 0 m To 4.10 m C_{pe} = -0.9 pe = -0.9 KPa   pnet = -1.12 KPa

For roof $C_{P,e}$ from 4.10 m To 8.20 m C_{pe} = -0.5 pe = -0.5 KPa   pnet = -0.72 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward $C_{P,e}$ from 0 m To 21 m C_{pe} = 0.7   pe = 0.74 KPa   pnet = 1.09 KPa

For side wall $C_{P,e}$ from 0 m To 4.10 m C_{pe} =   pe = -0.69 KPa   pnet = -0.69 KPa

Maximum Upward pressure used in roof member Design = 1.12 KPa

Maximum Downward pressure used in roof member Design = 0.44 KPa

Maximum Wall pressure used in Design = 1.09 KPa

Maximum Racking pressure used in Design = 1.07 KPa

Design Summary

Purlin Design

 Purlin Spacing = 900 mm   Purlin Span = 3450 mm   Try Purlin 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 K_4 =1 K_5 =1 K_8 Downward =0.98

K_8 Upward =0.50 S_1 Downward =12.23 S_1 Upward =23.77

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.45 Kn-m	Capacity	1.79 Kn-m	Passing Percentage	**397.78 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.82 Kn-m	Capacity	2.38 Kn-m	Passing Percentage	**130.77 %**
$M_{0.9D-WnUp}$	-1.2 Kn-m	Capacity	-1.52 Kn-m	Passing Percentage	**126.67 %**
$V_{1.35D}$	0.52 Kn	Capacity	8.25 Kn	Passing Percentage	**1586.54 %**

Second page

$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	1.15 Kn	Capacity	11.00 Kn	Passing Percentage	**956.52 %**
$V_{0.9D-WnUp}$	-1.39 Kn	Capacity	-13.75 Kn	Passing Percentage	**989.21 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 9.77 mm Limit by Woolcock et al, 1999 Span/240 = 14.17 mm

Deflection under Dead and Service Wind = 6.54 mm Limit by Woolcock et al, 1999 Span/100 = 34.00 mm

Reactions

Maximum downward =1.15 kn Maximum upward = -1.39 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 3600 mm Internal Rafter Span = 4850 mm Try Rafter 2x290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =7.47 S1 Upward =7.47

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.57 Kn-m	Capacity	8.48 Kn-m	Passing Percentage	**237.54 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	7.83 Kn-m	Capacity	11.3 Kn-m	Passing Percentage	**144.32 %**
$M_{0.9D-WnUp}$	-9.47 Kn-m	Capacity	-14.12 Kn-m	Passing Percentage	**149.10 %**
$V_{1.35D}$	2.95 Kn	Capacity	25.18 Kn	Passing Percentage	**853.56 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	6.46 Kn	Capacity	33.58 Kn	Passing Percentage	**519.81 %**
$V_{0.9D-WnUp}$	-7.81 Kn	Capacity	-41.96 Kn	Passing Percentage	**537.26 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 8.01 mm Limit by Woolcock et al, 1999 Span/240 = 20.83 mm

Deflection under Dead and Service Wind = 10.68 mm Limit by Woolcock et al, 1999 Span/100 = 50.00 mm

Reactions

Maximum downward =6.46 kn Maximum upward = -7.81 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K_{11} = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K_{11} = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 19.50 Kn > -7.81 Kn

Rafter Design External

External Rafter Load Width = 1800 mm   External Rafter Span = 5031 mm   Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =0.89

K8 Upward =0.89   S1 Downward =15.23   S1 Upward =15.23

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.92 Kn-m	Capacity	3.78 Kn-m	Passing Percentage	**196.88 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	4.21 Kn-m	Capacity	5.04 Kn-m	Passing Percentage	**119.71 %**
$M_{0.9D-WnUp}$	-5.10 Kn-m	Capacity	-6.29 Kn-m	Passing Percentage	**123.33 %**
$V_{1.35D}$	1.53 Kn	Capacity	12.59 Kn	Passing Percentage	**822.88 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	3.35 Kn	Capacity	16.79 Kn	Passing Percentage	**501.19 %**
$V_{0.9D-WnUp}$	-4.05 Kn	Capacity	-20.98 Kn	Passing Percentage	**518.02 %**

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 8.90 mm   Limit by Woolcock et al, 1999 Span/240= 20.83 mm
Deflection under Dead and Service Wind = 10.68 mm   Limit by Woolcock et al, 1999 Span/100 = 50.00 mm

Reactions

Maximum downward =3.35 kn   Maximum upward = -4.05 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K_{11} = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -21.73 kn > -4.05 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -4.05 Kn

Girt Design Front and Back

Girt's Spacing = 900 mm   Girt's Span = 3600 mm   Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =0.98

K8 Upward =0.48   S1 Downward =12.23   S1 Upward =24.46

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.59 Kn-m	Capacity	1.45 Kn-m	Passing Percentage	**91.19 %**
$V_{0.9D-WnUp}$	1.77 Kn	Capacity	13.75 Kn	Passing Percentage	**776.84 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 12.45 mm   Limit by Woolcock et al, 1999 Span/100 = 36.00 mm
Sag during installation = 12.57 mm

Reactions

Maximum = 1.77 kn

Girt Design Sides

Girt's Spacing = 900 mm   Girt's Span = 5000 mm   Try Girt 190x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =0.98

K8 Upward =0.35   S1 Downward =12.23   S1 Upward =28.82

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	3.07 Kn-m	Capacity	1.06 Kn-m	Passing Percentage	**34.53 %**
$V_{0.9D-WnUp}$	2.45 Kn	Capacity	13.75 Kn	Passing Percentage	**561.22 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 46.33 mm   Limit by Woolcock et al. 1999 Span/100 = 50.00 mm

Sag during installation =46.79 mm

Reactions

Maximum = 2.45 kn

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile() x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile()

Skin Friction = 0.00 Kn

Weight of Pile + Pile Skin Friction = 0.00 Kn

Uplift on one Pile = 16.11 Kn

Uplift is ok

Last Page