

Pole Shed App Ver 01 2022

Job No.: DW & AM Gee

Address: 44 Rene Street Blenheim, Rapaura, New Zealand

Date: 15/05/2024

Latitude: -41.503771

Longitude: 173.91948

Elevation: 11.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N3	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	3	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.05 m
Wind Region	NZ2	Terrain Category	2.07	Design Wind Speed	37.98 m/s
Wind Pressure	0.87 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Gable Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 4.05 m $C_{p,e} = -0.9$ $p_e = -0.70$ KPa $p_{net} = -0.70$ KPa

For roof $C_{p,e}$ from 4.05 m To 8.10 m $C_{p,e} = -0.5$ $p_e = -0.39$ KPa $p_{net} = -0.39$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 7.20 m $C_{p,e} = 0.7$ $p_e = 0.55$ KPa $p_{net} = 0.81$ KPa

For side wall $C_{p,e}$ from 0 m To 4.05 m $C_{p,e} =$ $p_e = -0.51$ KPa $p_{net} = -0.51$ KPa

Maximum Upward pressure used in roof member Design = 0.70 KPa

Maximum Downward pressure used in roof member Design = 0.42 KPa

Maximum Wall pressure used in Design = 0.81 KPa

Maximum Racking pressure used in Design = 0.78 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm

Purlin Span = 4650 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.44 S1 Downward = 11.27 S1 Upward = 25.48

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.82 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	271.95 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	2.01 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	147.76 %
M _{0.9D-W_nUp}	-1.16 Kn-m	Capacity	-1.66 Kn-m	Passing Percentage	76.85 %
V _{1.35D}	0.71 Kn	Capacity	9.65 Kn	Passing Percentage	1359.15 %

Pole Shed App Ver 01 2022

V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	1.51 Kn	Capacity	12.86 Kn	Passing Percentage	851.66 %
V _{0.9D-WnUp}	-0.99 Kn	Capacity	-16.08 Kn	Passing Percentage	1624.24 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 14.10 mm Limit by Woolcock et al, 1999 Span/240 = 19.17 mm

Deflection under Dead and Service Wind = 16.68 mm Limit by Woolcock et al, 1999 Span/100 = 46.00 mm

Reactions

Maximum downward = 1.51 kn Maximum upward = -0.99 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4800 mm Internal Rafter Span = 7050 mm Try Rafter 2x300x45 LVL11

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K₁ Short term = 1 K₁ Medium term = 0.8 K₁ Long term = 0.6 K₄ = 1 K₅ = 1 K₈ Downward = 1.00

K₈ Upward = 1.00 S₁ Downward = 7.61 S₁ Upward = 7.61

Shear Capacity of timber = 5 MPa Bending Capacity of timber = 38 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	10.06 Kn-m	Capacity	24.62 Kn-m	Passing Percentage	244.73 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	21.47 Kn-m	Capacity	32.84 Kn-m	Passing Percentage	152.96 %
M _{0.9D-WnUp}	-14.17 Kn-m	Capacity	-41.04 Kn-m	Passing Percentage	289.63 %
V _{1.35D}	5.71 Kn	Capacity	43.42 Kn	Passing Percentage	760.42 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	12.18 Kn	Capacity	57.88 Kn	Passing Percentage	475.21 %
V _{0.9D-WnUp}	-8.04 Kn	Capacity	-72.36 Kn	Passing Percentage	900.00 %

Deflections

Modulus of Elasticity = 9900 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 22.62 mm Limit by Woolcock et al, 1999 Span/240 = 30.00 mm

Deflection under Dead and Service Wind = 29.745 mm Limit by Woolcock et al, 1999 Span/100 = 72.00 mm

Reactions

Maximum downward = 12.18 kn Maximum upward = -8.04 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 12.6 \text{ fpj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 90 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ fcj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Capacity under short term loads = 29.11 Kn > -8.04 Kn

Rafter Design External

External Rafter Load Width = 2400 mm

External Rafter Span = 3511 mm

Try Rafter 250x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 K_1 Medium term = 0.8 K_1 Long term = 0.6 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 0.97

K_8 Upward = 0.97 S_1 Downward = 12.68 S_1 Upward = 12.68

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	1.25 Kn-m	Capacity	3.40 Kn-m	Passing Percentage	272.00 %
$M_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	2.66 Kn-m	Capacity	4.53 Kn-m	Passing Percentage	170.30 %
$M_{0.9D-W_nUp}$	-1.76 Kn-m	Capacity	-5.67 Kn-m	Passing Percentage	322.16 %
$V_{1.35D}$	1.42 Kn	Capacity	12.06 Kn	Passing Percentage	849.30 %
$V_{1.2D+1.5L \ 1.2D+S_n \ 1.2D+W_nD_n}$	3.03 Kn	Capacity	16.08 Kn	Passing Percentage	530.69 %
$V_{0.9D-W_nUp}$	-2.00 Kn	Capacity	-20.10 Kn	Passing Percentage	1005.00 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k_2 for Long Term Loads = 2

Deflection under Dead and Live Load = 4.48 mm

Limit by Woolcock et al, 1999 Span/240 = 15.00 mm

Deflection under Dead and Service Wind = 5.30 mm

Limit by Woolcock et al, 1999 Span/100 = 36.00 mm

Reactions

Maximum downward = 3.03 kn Maximum upward = -2.00 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

$K_{11} = 14.9 \text{ fpj} = 12.9 \text{ Mpa}$ for Rafter with effective thickness = 50 mm

For Parallel to grain loading

$K_{11} = 2.0 f_{cj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots (\text{Eq 4.12}) = -19.95 \text{ kn} > -2.00 \text{ Kn}$

Single Shear Capacity under short term loads = -10.84 Kn > -2.00 Kn

Intermediate Design Front and Back

Intermediate Spacing = 2400 mm Intermediate Span = 3000 mm Try Intermediate 2x150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 1.00 S_1 Downward = 9.63 S_1 Upward = 0.56

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	2.19 Kn-m	Capacity	4.2 Kn-m	Passing Percentage	191.78 %
$V_{0.9D-WnUp}$	2.92 Kn	Capacity	-24.12 Kn	Passing Percentage	826.03 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 13.495 mm Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Reactions

Maximum = 2.92 kn

Girt Design Front and Back

Girt's Spacing = 1300 mm Girt's Span = 2400 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.87 S_1 Downward = 9.63 S_1 Upward = 15.73

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	0.76 Kn-m	Capacity	1.83 Kn-m	Passing Percentage	240.79 %
$V_{0.9D-WnUp}$	1.26 Kn	Capacity	12.06 Kn	Passing Percentage	957.14 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 4.83 mm Limit by Woolcock et al, 1999 Span/100 = 24.00 mm

Sag during installation = 2.01 mm

Reactions

Maximum = 1.26 kn

Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 3600 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.95 S1 Downward =9.63 S1 Upward =13.62

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	1.71 Kn-m	Capacity	1.99 Kn-m	Passing Percentage	116.37 %
V _{0.9D-WnUp}	1.90 Kn	Capacity	12.06 Kn	Passing Percentage	634.74 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 24.44 mm

Limit by Woolcock et al. 1999 Span/100 = 36.00 mm

Sag during installation =10.18 mm

Reactions

Maximum = 1.90 kn

Middle Pole Design

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3750 mm
Area	35448 mm ²	As	26585.7421875 mm ²
I _x	100042702 mm ⁴	Z _x	941578 mm ³
I _y	100042702 mm ⁴	Z _y	941578 mm ³
Lateral Restraint	3750 mm c/c		

Loads

Total Area over Pole = 17.28 m²

Dead	4.32 Kn	Live	4.32 Kn
Wind Down	7.26 Kn	Snow	0.00 Kn
Moment wind	11.49 Kn-m		
Phi	0.8	K8	0.78
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
---------	----------	--------	---------

Pole Shed App Ver 01 2022

fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	400.65 Kn	PhiMnx Wind	21.46 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	240.39 Kn	PhiMnx Dead	12.88 Kn-m	PhiVnx Dead	37.77 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.57 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.33 < 1$ OK

Deflection at top under service lateral loads = 26.47 mm < 37.50 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3037 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	11.49 Kn-m
Shear Wind =	3.78 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.63 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.97 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.96 < 1 OK

End Pole Design

Geometry For End Bay Pole

Geometry

175 SED H5 (Minimum 200 dia. at Floor Level)	Dry Use	Height	3800 mm
Area	27598 mm ²	As	20698.2421875 mm ²
Ix	60639381 mm ⁴	Zx	646820 mm ³

Pole Shed App Ver 01 2022

Iy	60639381 mm ⁴	Zx	646820 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 8.64 m²

Dead	2.16 Kn	Live	2.16 Kn
Wind Down	3.63 Kn	Snow	0.00 Kn
Moment Wind	3.83 Kn-m		
Phi	0.8	K8	0.66
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	261.19 Kn	PhiMnx Wind	12.35 Kn-m	PhiVnx Wind	49.01 Kn
PhiNcx Dead	156.71 Kn	PhiMnx Dead	7.41 Kn-m	PhiVnx Dead	29.41 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.34 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.13 < 1$ OK

Deflection at top under service lateral loads = 15.68 mm < 40.40 mm

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3037 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 8.64 m²

Moment Wind =	3.83 Kn-m
Shear Wind =	1.26 Kn

Pile Properties

Safety Factor	0.55	
Hu =	6.63 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.97 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.32 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	3037 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	3.83 Kn-m
Shear Wind =	1.26 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.63 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	11.97 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.32 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1500) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1500)

Skin Friction = 18.17 Kn

Weight of Pile + Pile Skin Friction = 22.07 Kn

Uplift on one Pile = 8.21 Kn

Uplift is ok