



Pole Shed App Ver 01 2022

**Job No.:** 471-266585c

**Address:** 16 Chelmsford Street, Tahawai 3170, New Zealand

**Date:** 02/12/2024

**Latitude:** -37.512802

**Longitude:** 175.973924

**Elevation:** 30 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	D
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	5.9 m
Wind Region	NZ1	Terrain Category	1.66	Design Wind Speed	41.12 m/s
Wind Pressure	1.01 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Enclosed

For roof  $C_{p,i} = -0.3$

For roof  $C_{p,e}$  from 0 m To 5.35 m  $C_{p,e} = -0.9$   $p_e = -0.82$  KPa  $p_{net} = -0.82$  KPa

For roof  $C_{p,e}$  from 5.35 m To 10.7 m  $C_{p,e} = -0.5$   $p_e = -0.46$  KPa  $p_{net} = -0.46$  KPa

For wall Windward  $C_{p,i} = -0.3$  side Wall  $C_{p,i} = -0.3$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 13 m  $C_{p,e} = 0.7$   $p_e = 0.64$  KPa  $p_{net} = 0.94$  KPa

For side wall  $C_{p,e}$  from 0 m To 5.35 m  $C_{p,e} =$   $p_e = -0.59$  KPa  $p_{net} = -0.59$  KPa

Maximum Upward pressure used in roof member Design = 0.82 KPa

Maximum Downward pressure used in roof member Design = 0.42 KPa

Maximum Wall pressure used in Design = 0.94 KPa

Maximum Racking pressure used in Design = 1.10 KPa

**Design Summary**

**Purlin Design**

Purlin Spacing = 750 mm

Purlin Span = 5850 mm

Try Purlin 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Second page

### Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.94

K8 Upward = 0.47    S1 Downward = 13.82    S1 Upward = 24.81

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	1.08 Kn-m	Capacity	2.73 Kn-m	Passing Percentage	<b>252.78 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>nDn</sub></sub>	2.57 Kn-m	Capacity	3.64 Kn-m	Passing Percentage	<b>141.63 %</b>
M <sub>0.9D-W<sub>nUp</sub></sub>	-1.91 Kn-m	Capacity	-2.25 Kn-m	Passing Percentage	<b>117.80 %</b>
V <sub>1.35D</sub>	0.74 Kn	Capacity	10.42 Kn	Passing Percentage	<b>1408.11 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>nDn</sub></sub>	1.58 Kn	Capacity	13.89 Kn	Passing Percentage	<b>879.11 %</b>
V <sub>0.9D-W<sub>nUp</sub></sub>	-1.31 Kn	Capacity	-17.37 Kn	Passing Percentage	<b>1325.95 %</b>

#### **Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 19.09 mm    Limit by Woolcock et al, 1999 Span/240 = 24.17 mm

Deflection under Dead and Service Wind = 22.59 mm    Limit by Woolcock et al, 1999 Span/100 = 58.00 mm

#### **Reactions**

Maximum downward = 1.58 kn    Maximum upward = -1.31 kn

Number of Blocking = 1    if 0 then no blocking required, if 1 then one midspan blocking required

#### **Rafter Design Internal**

Internal Rafter Load Width = 6000 mm    Internal Rafter Span = 4183.333333333333 mm    Try Rafter 2x290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 1.00

K8 Upward = 1.00    S1 Downward = 7.47    S1 Upward = 7.47

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	4.43 Kn-m	Capacity	8.48 Kn-m	Passing Percentage	<b>191.42 %</b>
--------------------	-----------	----------	-----------	--------------------	-----------------

Pole Shed App Ver 01 2022

M <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	9.45 Kn-m	Capacity	11.3 Kn-m	Passing Percentage	<b>119.58 %</b>
M <sub>0.9D-WnUp</sub>	-7.81 Kn-m	Capacity	-14.12 Kn-m	Passing Percentage	<b>180.79 %</b>
V <sub>1.35D</sub>	4.24 Kn	Capacity	25.18 Kn	Passing Percentage	<b>593.87 %</b>
V <sub>1.2D+1.5L 1.2D+Sn 1.2D+WnDn</sub>	9.04 Kn	Capacity	33.58 Kn	Passing Percentage	<b>371.46 %</b>
V <sub>0.9D-WnUp</sub>	-7.47 Kn	Capacity	-41.96 Kn	Passing Percentage	<b>561.71 %</b>

**Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 7.53 mm      Limit by Woolcock et al, 1999 Span/240 = 18.06 mm

Deflection under Dead and Service Wind = 9.9 mm      Limit by Woolcock et al, 1999 Span/100 = 43.33 mm

**Reactions**

Maximum downward = 9.04 kn    Maximum upward = -7.47 kn

**Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 14.9 fpj = 12.9 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 19.50 Kn > -7.47 Kn

**Rafter Design External**

External Rafter Load Width = 3000 mm      External Rafter Span = 4149 mm      Try Rafter 290x45 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

### Pole Shed App Ver 01 2022

K1 Short term = 1    K1 Medium term = 0.8    K1 Long term = 0.6    K4 = 1    K5 = 1    K8 Downward = 0.89

K8 Upward = 0.89    S1 Downward = 15.23    S1 Upward = 15.23

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>1.35D</sub>	2.18 Kn-m	Capacity	3.78 Kn-m	Passing Percentage	<b>173.39 %</b>
M <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	4.65 Kn-m	Capacity	5.04 Kn-m	Passing Percentage	<b>108.39 %</b>
M <sub>0.9D-W<sub>n</sub>Up</sub>	-3.84 Kn-m	Capacity	-6.29 Kn-m	Passing Percentage	<b>163.80 %</b>
V <sub>1.35D</sub>	2.10 Kn	Capacity	12.59 Kn	Passing Percentage	<b>599.52 %</b>
V <sub>1.2D+1.5L 1.2D+S<sub>n</sub> 1.2D+W<sub>n</sub>D<sub>n</sub></sub>	4.48 Kn	Capacity	16.79 Kn	Passing Percentage	<b>374.78 %</b>
V <sub>0.9D-W<sub>n</sub>Up</sub>	-3.70 Kn	Capacity	-20.98 Kn	Passing Percentage	<b>567.03 %</b>

#### **Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k<sub>2</sub> for Long Term Loads = 2

Deflection under Dead and Live Load = 8.37 mm      Limit by Woolcock et al, 1999 Span/240 = 18.06 mm

Deflection under Dead and Service Wind = 9.90 mm      Limit by Woolcock et al, 1999 Span/100 = 43.33 mm

#### **Reactions**

Maximum downward = 4.48 kn    Maximum upward = -3.70 kn

#### **Rafter to Pole Connection check**

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K<sub>11</sub> = 14.9 f<sub>pj</sub> = 12.9 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K<sub>11</sub> = 2.0 f<sub>cj</sub> = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V =  $\phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s$  ..... (Eq 4.12) = -21.73 kn > -3.70 Kn

Single Shear Capacity under short term loads = -9.75 Kn > -3.70 Kn

### Intermediate Design Front and Back

Intermediate Spacing = 3000 mm      Intermediate Span = 4649 mm      Try Intermediate 2x240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 = 1    K5 = 1    K8 Downward = 0.94

K8 Upward = 1.00    S1 Downward = 13.82    S1 Upward = 0.99

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>Wind+Snow</sub>	7.62 Kn-m	Capacity	9.68 Kn-m	Passing Percentage	<b>127.03 %</b>
V <sub>0.9D-WnUp</sub>	6.56 Kn	Capacity	-34.74 Kn	Passing Percentage	<b>529.57 %</b>

#### Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 30.64 mm    Limit by Woolcock et al, 1999 Span/100 = 46.49 mm

#### Reactions

Maximum = 6.56 kn

### Girt Design Front and Back

Girt's Spacing = 1200 mm      Girt's Span = 3000 mm      Try Girt 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 = 1    K5 = 1    K8 Downward = 0.94

K8 Upward = 0.45    S1 Downward = 13.82    S1 Upward = 25.23

Shear Capacity of timber = 3 MPa    Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

#### Capacity Checks

M <sub>Wind+Snow</sub>	1.27 Kn-m	Capacity	2.19 Kn-m	Passing Percentage	<b>172.44 %</b>
V <sub>0.9D-WnUp</sub>	1.69 Kn	Capacity	17.37 Kn	Passing Percentage	<b>1027.81 %</b>

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 3.43 mm Limit by Woolcock et al, 1999 Span/100 = 30.00 mm

Sag during installation = 6.06 mm

### Reactions

Maximum = 1.69 kn

### Girt Design Sides

Girt's Spacing = 1200 mm

Girt's Span = 4333 mm

Try Girt 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =0.94

K8 Upward =0.60 S1 Downward =13.82 S1 Upward =21.44

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

M <sub>Wind+Snow</sub>	2.65 Kn-m	Capacity	2.91 Kn-m	Passing Percentage	<b>109.81 %</b>
V <sub>0.9D-WnUp</sub>	2.44 Kn	Capacity	17.37 Kn	Passing Percentage	<b>711.89 %</b>

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 14.91 mm Limit by Woolcock et al. 1999 Span/100 = 43.33 mm

Sag during installation =26.40 mm

### Reactions

Maximum = 2.44 kn

### Middle Pole Design

#### Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	5610 mm
Area	54091 mm <sup>2</sup>	As	40568.5546875 mm <sup>2</sup>

Pole Shed App Ver 01 2022

Ix	232952248 mm <sup>4</sup>	Zx	1774874 mm <sup>3</sup>
Iy	232952248 mm <sup>4</sup>	Zx	1774874 mm <sup>3</sup>
Lateral Restraint	5610 mm c/c		

**Loads**

Total Area over Pole = 26 m<sup>2</sup>

Dead	6.50 Kn	Live	6.50 Kn
Wind Down	10.92 Kn	Snow	0.00 Kn
Moment wind	21.48 Kn-m		
Phi	0.8	K8	0.60
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

**Material**

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

**Capacities**

PhiNcx Wind	470.52 Kn	PhiMnx Wind	31.14 Kn-m	PhiVnx Wind	96.07 Kn
PhiNcx Dead	282.31 Kn	PhiMnx Dead	18.68 Kn-m	PhiVnx Dead	57.64 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.74 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.53 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 46.34 \text{ mm} < 56.10 \text{ mm}$$

**Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

**Geometry For Middle Bay Pole**



Pole Shed App Ver 01 2022

Ds =	0.6 mm	Pile Diameter
L =	1900 mm	Pile embedment length
f1 =	4425 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

**Loads**

Moment Wind =	21.48 Kn-m
Shear Wind =	4.86 Kn

**Pile Properties**

Safety Factory	0.55	
Hu =	9.66 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	25.10 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

Applied Forces/Capacities = 0.86 < 1 OK

**End Pole Design**

**Geometry For End Bay Pole**

**Geometry**

225 SED H5 (Minimum 250 dia. at Floor Level)	Dry Use	Height	5700 mm
Area	44279 mm <sup>2</sup>	As	33209.1796875 mm <sup>2</sup>
Ix	156100441 mm <sup>4</sup>	Zx	1314530 mm <sup>3</sup>
Iy	156100441 mm <sup>4</sup>	Zx	1314530 mm <sup>3</sup>
Lateral Restraint	mm c/c		

**Loads**

Total Area over Pole = 13 m<sup>2</sup>

Dead	3.25 Kn	Live	3.25 Kn
Wind Down	5.46 Kn	Snow	0.00 Kn
Moment Wind	10.74 Kn-m		
Phi	0.8	K8	0.49
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

**Material**

Pole Shed App Ver 01 2022

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	$E =$	9257 MPa

**Capacities**

PhiNcx Wind	314.62 Kn	PhiMnx Wind	18.84 Kn-m	PhiVnx Wind	78.64 Kn
PhiNcx Dead	188.77 Kn	PhiMnx Dead	11.30 Kn-m	PhiVnx Dead	47.18 Kn

**Checks**

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.61 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.36 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 36.27 \text{ mm} < 58.85 \text{ mm}$$

$D_s =$	0.6 mm	Pile Diameter
$L =$	1500 mm	Pile embedment length
$f_l =$	4425 mm	Distance at which the shear force is applied
$f_2 =$	0 mm	Distance of top soil at rest pressure

**Loads**

$$\text{Total Area over Pole} = 13 \text{ m}^2$$

Moment Wind =	10.74 Kn-m
Shear Wind =	2.43 Kn

**Pile Properties**

Safety Factory	0.55	
$H_u =$	5.08 Kn	Ultimate Lateral Strength of the Pile, Short pile
$M_u =$	12.96 Kn-m	Ultimate Moment Capacity of Pile

**Checks**

$$\text{Applied Forces/Capacities} = 0.83 < 1 \text{ OK}$$

**Drained Lateral Strength of End pile in cohesionless soils Free Head short pile**

**Assumed Soil Properties**

Gamma	18 Kn/m <sup>3</sup>	Friction angle	30 deg	Cohesion	0 Kn/m <sup>3</sup>
-------	----------------------	----------------	--------	----------	---------------------

## Pole Shed App Ver 01 2022

$$K_0 = (1 - \sin(30)) / (1 + \sin(30))$$

$$K_p = (1 + \sin(30)) / (1 - \sin(30))$$

### Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1500 mm	Pile embedment length
f1 =	4425 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

### Loads

Moment Wind =	10.74 Kn-m
Shear Wind =	2.43 Kn

### Pile Properties

Safety Factor	0.55	
Hu =	5.08 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	12.96 Kn-m	Ultimate Moment Capacity of Pile

### Checks

Applied Forces/Capacities = 0.83 < 1 OK

### Uplift Check

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1900) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1900)

Skin Friction = 29.16 Kn

Weight of Pile + Pile Skin Friction = 32.97 Kn

Uplift on one Pile = 15.47 Kn

Uplift is ok