

Pole Shed App Ver 01 2022

Job No.: 623649 - 1
Latitude: -35.176367

Address: 252 Ness Rd, Waipapa, New Zealand
Longitude: 173.885113

Date: 18/12/2023
Elevation: 145 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.75 m
Wind Region	NZ1	Terrain Category	2.0	Design Wind Speed	39.83 m/s
Wind Pressure	0.95 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Gable Enclosed

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0 m To 4.35 m $C_{p,e} = -0.9$ $p_e = -0.77$ KPa $p_{net} = -0.77$ KPa

For roof $C_{p,e}$ from 4.35 m To 8.70 m $C_{p,e} = -0.5$ $p_e = -0.43$ KPa $p_{net} = -0.43$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0 m To 10 m $C_{p,e} = 0.7$ $p_e = 0.60$ KPa $p_{net} = 0.89$ KPa

For side wall $C_{p,e}$ from 0 m To 4.35 m $C_{p,e} =$ $p_e = -0.56$ KPa $p_{net} = -0.56$ KPa

Maximum Upward pressure used in roof member Design = 0.77 KPa

Maximum Downward pressure used in roof member Design = 0.46 KPa

Maximum Wall pressure used in Design = 0.89 KPa

Maximum Racking pressure used in Design = 0.86 KPa

Design Summary

Rafter Design Internal

Internal Rafter Load Width = 4500 mm Internal Rafter Span = 9850 mm Try Rafter 2x360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =1.00 S1 Downward =5.90 S1 Upward =5.90

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	18.42 Kn-m	Capacity	60.82 Kn-m	Passing Percentage	330.18 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	41.48 Kn-m	Capacity	81.1 Kn-m	Passing Percentage	195.52 %
M _{0.9D-W_nUp}	-29.74 Kn-m	Capacity	-101.38 Kn-m	Passing Percentage	340.89 %
V _{1.35D}	7.48 Kn	Capacity	77.32 Kn	Passing Percentage	1033.69 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	16.84 Kn	Capacity	103.08 Kn	Passing Percentage	612.11 %
V _{0.9D-W_nUp}	-12.08 Kn	Capacity	-128.86 Kn	Passing Percentage	1066.72 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 29.36 mm Limit by Woolcock et al, 1999 Span/240 = 41.67 mm

Deflection under Dead and Service Wind = 39.69 mm Limit by Woolcock et al, 1999 Span/100 = 100.00 mm

Reactions

Maximum downward =16.84 kn Maximum upward = -12.08 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 126 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Second page

Capacity under short term loads = 43.67 Kn > -12.08 Kn

Rafter Design External

External Rafter Load Width = 2250 mm External Rafter Span = 10084 mm Try Rafter 360x63 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 0.98

K8 Upward = 0.98 S1 Downward = 12.10 S1 Upward = 12.10

Shear Capacity of timber = 5.3 MPa Bending Capacity of timber = 48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	9.65 Kn-m	Capacity	29.91 Kn-m	Passing Percentage	309.95 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	21.74 Kn-m	Capacity	39.88 Kn-m	Passing Percentage	183.44 %
M _{0.9D-W_nUp}	-15.59 Kn-m	Capacity	-49.85 Kn-m	Passing Percentage	319.76 %
V _{1.35D}	3.83 Kn	Capacity	38.66 Kn	Passing Percentage	1009.40 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	8.62 Kn	Capacity	51.54 Kn	Passing Percentage	597.91 %
V _{0.9D-W_nUp}	-6.18 Kn	Capacity	-64.43 Kn	Passing Percentage	1042.56 %

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 32.62 mm Limit by Woolcock et al, 1999 Span/240 = 41.67 mm

Deflection under Dead and Service Wind = 39.69 mm Limit by Woolcock et al, 1999 Span/100 = 100.00 mm

Reactions

Maximum downward = 8.62 kn Maximum upward = -6.18 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

Pole Shed App Ver 01 2022

$K_{11} = 12.6 \text{ f}_{pj} = 22.7 \text{ Mpa}$ for Rafter with effective thickness = 63 mm

For Parallel to grain loading

$K_{11} = 2.0 \text{ f}_{cj} = 36.1 \text{ Mpa}$ for Pole with effective thickness = 100 mm

Eccentric Load check

$V = \phi \times k_1 \times k_4 \times k_5 \times f_s \times b \times d_s \dots\dots\dots (\text{Eq 4.12}) = -70.12 \text{ kn} > -6.18 \text{ Kn}$

Single Shear Capacity under short term loads = -14.56 Kn > -6.18 Kn

Girt Design Front and Back

Girt's Spacing = 900 mm

Girt's Span = 4500 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K_1 Short term = 1 $K_4 = 1$ $K_5 = 1$ K_8 Downward = 1.00

K_8 Upward = 0.78 S_1 Downward = 11.27 S_1 Upward = 17.82

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{\text{Wind+Snow}}$	2.03 Kn-m	Capacity	2.90 Kn-m	Passing Percentage	142.86 %
$V_{0.9D-WnUp}$	1.80 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	893.33 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 19.15 mm Limit by Woolcock et al, 1999 Span/100 = 45.00 mm

Sag during installation = 24.86 mm

Reactions

Maximum = 1.80 kn

Girt Design Sides

Girt's Spacing = 900 mm

Girt's Span = 5000 mm

Try Girt 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.73 S1 Downward =11.27 S1 Upward =18.79

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	2.50 Kn-m	Capacity	2.72 Kn-m	Passing Percentage	108.80 %
V _{0.9D-WnUp}	2.00 Kn-m	Capacity	16.08 Kn-m	Passing Percentage	804.00 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 29.19 mm Limit by Woolcock et al. 1999 Span/100 = 50.00 mm
Sag during installation =37.90 mm

Reactions

Maximum = 2.00 kn

Middle Pole Design

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3390 mm
Area	35448 mm ²	As	26585.7421875 mm ²
I _x	100042702 mm ⁴	Z _x	941578 mm ³
I _y	100042702 mm ⁴	Z _x	941578 mm ³
Lateral Restraint	3390 mm c/c		

Loads

Total Area over Pole = 22.5 m²

Dead	5.63 Kn	Live	5.63 Kn
Wind Down	10.35 Kn	Snow	0.00 Kn
Moment wind	10.18 Kn-m		
Phi	0.8	K8	0.86
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Pole Shed App Ver 01 2022

Peeling	Steaming	Normal	Dry Use
$f_b =$	36.3 MPa	$f_s =$	2.96 MPa
$f_c =$	18 MPa	$f_p =$	7.2 MPa
$f_t =$	22 MPa	$E =$	9257 MPa

Capacities

PhiNcx Wind	439.80 Kn	PhiMnx Wind	23.56 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	263.88 Kn	PhiMnx Dead	14.14 Kn-m	PhiVnx Dead	37.77 Kn

Checks

$$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.48 < 1 \text{ OK}$$

$$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.24 < 1 \text{ OK}$$

$$\text{Deflection at top under service lateral loads} = 19.63 \text{ mm} < 33.90 \text{ mm}$$

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
$K_0 =$	$(1 - \sin(30)) / (1 + \sin(30))$				
$K_p =$	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For Middle Bay Pole

$D_s =$	0.6 mm	Pile Diameter
$L =$	1450 mm	Pile embedment length
$f_1 =$	2813 mm	Distance at which the shear force is applied
$f_2 =$	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	10.18 Kn-m
Shear Wind =	3.62 Kn

Pile Properties

Safety Factory	0.55	
$H_u =$	6.37 Kn	Ultimate Lateral Strength of the Pile, Short pile
$M_u =$	10.71 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = $0.95 < 1$ OK

End Pole Design

Geometry For End Bay Pole

Geometry

200 SED H5 (Minimum 225 dia. at Floor Level)	Dry Use	Height	3390 mm
Area	35448 mm ²	As	26585.7421875 mm ²
Ix	100042702 mm ⁴	Zx	941578 mm ³
Iy	100042702 mm ⁴	Zx	941578 mm ³
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 22.5 m²

Dead	5.63 Kn	Live	5.63 Kn
Wind Down	10.35 Kn	Snow	0.00 Kn
Moment Wind	5.09 Kn-m		
Phi	0.8	K8	0.86
K1 snow	0.8	K1 Dead	0.6
K1 wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	439.90 Kn	PhiMnx Wind	23.56 Kn-m	PhiVnx Wind	62.96 Kn
PhiNcx Dead	263.94 Kn	PhiMnx Dead	14.14 Kn-m	PhiVnx Dead	37.77 Kn

Checks

$(M_x/\Phi M_{nx}) + (N/\Phi N_{cx}) = 0.27 < 1$ OK

$(M_x/\Phi M_{nx})^2 + (N/\Phi N_{cx}) = 0.10 < 1$ OK

Pole Shed App Ver 01 2022

Deflection at top under service lateral loads = 10.83 mm < 37.41 mm

Ds =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f1 =	2813 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 22.5 m²

Moment Wind =	5.09 Kn-m
Shear Wind =	1.81 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.37 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.71 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.48 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m ³	Friction angle	30 deg	Cohesion	0 Kn/m ³
K0 =	$(1 - \sin(30)) / (1 + \sin(30))$				
Kp =	$(1 + \sin(30)) / (1 - \sin(30))$				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1450 mm	Pile embedment length
f1 =	2813 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	5.09 Kn-m
Shear Wind =	1.81 Kn

Pile Properties

Safety Factory	0.55	
Hu =	6.37 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	10.71 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.48 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1450) x Ks(1.5) x $0.5 \times \tan(30)$ x π x Dia of Pile(0.6) x Height of Pile(1450)

Skin Friction = 16.98 Kn

Weight of Pile + Pile Skin Friction = 20.75 Kn

Uplift on one Pile = 12.26 Kn

Uplift is ok