

Pole Shed App Ver 01 2022

Job No.: John Clark - 1

Address: 1819 Cust Road, Cust, New Zealand

Date: 10/3/2023

Latitude: -43.314267

Longitude: 172.364092

Elevation: 138.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	C
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	2.67 m
Wind Region	NZ2	Terrain Category	2.0	Design Wind Speed	38.22 m/s
Wind Pressure	0.88 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressures

Shed Type = Mono Open

For roof $C_{p,i} = -0.3$

For roof $C_{p,e}$ from 0.00 m To 2.44 m $C_{p,e} = -0.9$ $p_e = -0.71$ KPa $p_{net} = -0.71$ KPa

For roof $C_{p,e}$ from 2.44 m To 4.88 m $C_{p,e} = -0.5$ $p_e = -0.39$ KPa $p_{net} = -0.39$ KPa

For wall Windward $C_{p,i} = -0.3$ side Wall $C_{p,i} = -0.3$

For wall Windward and Leeward $C_{p,e}$ from 0.0 m To 5.4 m $C_{p,e} = 0.7$ $p_e = 0.55$ KPa $p_{net} = 0.81$ KPa

For side wall $C_{p,e}$ from 0.0 m To 2.44 m $C_{p,e} =$ $p_e = -0.51$ KPa $p_{net} = -0.51$ KPa

Maximum Upward pressure used in roof member Design = 0.71 KPa

Maximum Downward pressure used in roof member Design = 0.42 KPa

Maximum Wall pressure used in Design = 0.81 KPa

Maximum Racking pressure used in Design = 0.94 KPa

Design Summary

Purlin Design

Purlin Spacing = 900 mm

Purlin Span = 3900 mm

Try Purlin 200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet

condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 0.52 S1 Downward = 11.27 S1 Upward = 23.31

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{1.35D}	0.58 Kn-m	Capacity	2.23 Kn-m	Passing Percentage	384.48 %
M _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.59 Kn-m	Capacity	2.97 Kn-m	Passing Percentage	186.79 %
M _{0.9D-W_nUp}	-0.83 Kn-m	Capacity	-1.94 Kn-m	Passing Percentage	Infinity %
V _{1.35D}	0.59 Kn	Capacity	9.65 Kn	Passing Percentage	1635.59 %
V _{1.2D+1.5L 1.2D+S_n 1.2D+W_nD_n}	1.63 Kn	Capacity	12.86 Kn	Passing Percentage	788.96 %
V _{0.9D-W_nUp}	-0.85 Kn	Capacity	-16.08 Kn	Passing Percentage	1891.76 %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 6.92 mm Limit by Woolcock et al, 1999 Span/240 = 16.04 mm

Deflection under Dead and Service Wind = 8.19 mm Limit by Woolcock et al, 1999 Span/100 = 38.50 mm

Reactions

Maximum downward = 1.63 kn Maximum upward = -0.85 kn

Number of Blocking = 0 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design Internal

Internal Rafter Load Width = 4050 mm Internal Rafter Span = 5250 mm Try Rafter 2x300x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 = 1 K5 = 1 K8 Downward = 1.00

K8 Upward = 1.00 S1 Downward = 6.81 S1 Upward = 6.81

Shear Capacity of timber = 3 MPa Bending Capacity of timber = 14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

Pole Shed App Ver 01 2022

M _{1.35D}	4.71 Kn-m	Capacity	10.08 Kn-m	Passing Percentage	214.01 %
M _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	12.98 Kn-m	Capacity	13.44 Kn-m	Passing Percentage	103.54 %
M _{0.9D-WnUp}	-6.77 Kn-m	Capacity	-16.8 Kn-m	Passing Percentage	248.15 %
V _{1.35D}	3.59 Kn	Capacity	28.94 Kn	Passing Percentage	806.13 %
V _{1.2D+1.5L 1.2D+Sn 1.2D+WnDn}	9.89 Kn	Capacity	38.6 Kn	Passing Percentage	390.29 %
V _{0.9D-WnUp}	-5.16 Kn	Capacity	-48.24 Kn	Passing Percentage	934.88 %

Deflections

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

k₂ for Long Term Loads = 2

Deflection under Dead and Live Load = 9.965 mm Limit by Woolcock et al, 1999 Span/240 = 22.50 mm

Deflection under Dead and Service Wind = 13.1 mm Limit by Woolcock et al, 1999 Span/100 = 54.00 mm

Reactions

Maximum downward = 9.89 kn Maximum upward = -5.16 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters = J5 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K₁₁ = 14.9 f_{pj} = 12.9 Mpa for Rafter with effective thickness = 100 mm

For Parallel to grain loading

K₁₁ = 2.0 f_{cj} = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 21.67 Kn > -5.16 Kn

Girt Design Front and Back

Girt's Spacing = 0 mm

Girt's Span = 4050 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

Pole Shed App Ver 01 2022

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	NaN %
V _{0.9D-WnUp}	0.00 Kn-m	Capacity	0.00 Kn-m	Passing Percentage	NaN %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm Limit by Woolcock et al, 1999 Span/100 = 40.50 mm

Sag during installation = NaN mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm

Girt's Span = 2700 mm

Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

M _{Wind+Snow}	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	NaN %
V _{0.9D-WnUp}	0.00 Kn-m	Capacity	0.00 Kn-m	Passing Percentage	NaN %

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm Limit by Woolcock et al. 1999 Span/100 = 27.00 mm

Sag during installation =NaN mm

Reactions

Maximum = 0.00 kn

Uplift Check

Density of Concrete = 24 Kn/m³

Density of Timber Pole = 5 Kn/m³

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1350) x Ks(1.5) x $0.5 \times \tan(30)$ x π x Dia of Pile(0.6) x Height of Pile(1350)

Skin Friction = 14.72 Kn

Weight of Pile + Pile Skin Friction = 19.14 Kn

Uplift on one Pile = 5.30 Kn

Uplift is ok