

**Job Number:**

***BWhite  
Consulting Ltd***

**Issue:**

## **PRODUCER STATEMENT-PS1-DESIGN**

**ISSUED BY: BWhite Consulting Ltd (Design Engineer: Bevan White)**

**TO BE SUPPLIED TO: Southland District Council IN RESPECT OF: Proposed NEW Farm Shed**

**AT: 555 Hutchinson Road, Richmond Downs 3371, New Zealand**

### **LEGAL DESCRIPTION**

We have been engaged by **Ezequote Pty Ltd** to provide **Specific Structural Engineering Design** services in respect of the requirements of Clause(s) **B1** of the Building Code for part only (as specified in the attachment to this statement), of the proposed building work.

☐ ALL    ☒ Part only as specified: Purlins, Rafters, Girts, Poles, Columns, Pole embedment and all connections

The design has been prepared in accordance with compliance documents to NZ Building Code issued by Ministry of Business, Innovation & Employment Clauses **B1/VM1 and B1/VM4**

The proposed building work covered by the producer statement is described on **Ezequote** drawings title **412-Cover - 1** and numbered **A101 - A116 Rev-1** dated **21/05/2025** together with the following specification, and other documents set out in the schedule attached to this statement: **Design Featured Report Dated 3/11/2025 and numbered "Second Page"**

**On behalf of BWhite Consulting Ltd, and subject to:**

1. Site verification of the following design assumptions: **an Ultimate foundation bearing pressure of 300 kPa in accordance with NZS3604:2011**
2. **The building has a design life of 50 years and an Importance Level 1**
3. **Unless specifically noted, compliance of the drawings to None-Specific codes such as NZS3604 and NZS4229 have not been checked by this practice**
4. **This Certificate does not cover any other building code clause including weather tightness**
5. **Inspections of the building to be completed by Southland District Council. As BWhite Consulting Ltd are not undertaking inspections, we cannot issue a producer Statement-PS4- Construction Review.**
6. **This Producer Statement- Design is valid for a building consent issued within 1 year from the date of issue**
7. **All proprietary products meeting their performance specification requirements**

**I believe on reasonable grounds** that a) the building, if constructed in accordance with the drawings, specifications, and other documents provided or listed in the attached schedule, will comply with the relevant provisions of the Building Code and that b), the persons who have undertaken the design have the necessary competency to do so. I also recommend the following level of construction monitoring/observation:

☒ CM1 ☐ CM2 ☐ CM3 ☐ CM4 ☐ CM5 or as per agreement with owner/developer (**stated above**)

I, **Bevan White** am CPEng **108276** I am Member of Engineering New Zealand and hold the following qualification: **BE.Civil** and holds a current policy of Professional Indemnity Insurance no less than \$200,000

Signed by **Bevan White** on behalf of **BWhite Consulting Ltd** Dated: **3/11/2025**

Email: [bwhitecpeng@gmail.com](mailto:bwhitecpeng@gmail.com) Phone: 0211-979786

Note: This statement shall only be relied upon by the Building Consent Authority named above. Liability under this statement accrues to the Design Firm only. The total maximum amount of damages payable arising from this statement and all other statements provided to the Building Consent Authority in relation to this building work, whether in contract, tort or otherwise(including negligence), is limited to the sum of \$200,000.

This form is to accompany Form 2 of the Building(Forms) Regulations 2004 for the application of a Building Consent

**Date:** 3/11/2025

18B Jules Crescent,

Bell Block New Plymouth 4312

New Zealand

File No:

**DESIGN FEATURES SUMMARY FOR PROPOSED NEW FARM SHED 555 HUTCHINSON ROAD,  
RICHMOND DOWNS 3371, NEW ZEALAND**

**Site Specific Loads**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & EQ ARI	100 Years	Max Height	4.6 m
Wind Region	NZ1	Terrain Category	2.0	Design Wind Speed	44.63 m/s
Wind Pressure	1.2 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years

**Timber**

Sawn Timber to be graded to the properties of SG6 and SG8 or better as mentioned on plans, with moisture content of 18% or less for dry and 25% or less for wet.

The following standards have been used in the design of this structure

- NZS 3603:1993 Timber Structures Standard
- NZS 3604:2011 Timber Framed Buildings. Standards New Zealand, 2011
- NZS 3404:1997 Steel Structures
- AS/NZS 1170 2003 Structural Design Actions
- AS/NZS 1170.2 2021 Structural Design Actions-Wind Action
- Branz. "Engineering Basis of NZS 3604". April 2013

Yours Faithfully

**BWhite CONSULTING LTD**

**Bevan White**

Director | BE Civil . CMengNZ CPEng

Email: [bwhitecpeng@gmail.com](mailto:bwhitecpeng@gmail.com) Contact: 0211 979 786

Pole Shed App Ver 01 2022

**Job No.:** 412-Cover - 1      **Address:** 555 Hutchinson Road, Richmond Downs 3371, New Zealand      **Date:** 3/11/2025  
**Latitude:** -37.712492      **Longitude:** 175.639468      **Elevation:** 67 m

**General Input**

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N0	Ground Snow Load	0 KPa	Roof Snow Load	0 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	4.6 m
Wind Region	NZ1	Terrain Category	2.0	Design Wind Speed	44.63 m/s
Wind Pressure	1.2 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	Very High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

**Pressure Coefficients and Pressures**

Shed Type = Mono Open

For roof  $C_{p,i} = 0.6409$

For roof  $C_{p,e}$  from 0 m To 4.15 m  $C_{p,e} = -0.9$   $p_e = -0.70$  KPa  $p_{net} = -1.30$  KPa

For roof  $C_{p,e}$  from 4.15 m To 8.30 m  $C_{p,e} = -0.5$   $p_e = -0.39$  KPa  $p_{net} = -0.99$  KPa

For wall Windward  $C_{p,i} = 0.6409$  side Wall  $C_{p,i} = -0.5402$

For wall Windward and Leeward  $C_{p,e}$  from 0 m To 9 m  $C_{p,e} = 0.7$   $p_e = 0.75$  KPa  $p_{net} = 1.38$  KPa

For side wall  $C_{p,e}$  from 0 m To 4.15 m  $C_{p,e} =$   $p_e = -0.70$  KPa  $p_{net} = -0.07$  KPa

Maximum Upward pressure used in roof member Design = 1.30 KPa

Maximum Downward pressure used in roof member Design = 0.74 KPa

Maximum Wall pressure used in Design = 1.38 KPa

Maximum Racking pressure used in Design = 1.29 KPa

**Design Summary**

**Intermediate Design Front and Back**

Intermediate Spacing = 2300 mm      Intermediate Span = 3549 mm      Try Intermediate 2x200x50 SG8 Dry

### Pole Shed App Ver 01 2022

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =1.00    S1 Downward =11.27    S1 Upward =0.71

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>Wind+Snow</sub>	5.00 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	<b>149.20 %</b>
V <sub>0.9D-WnUp</sub>	5.63 Kn	Capacity	-32.16 Kn	Passing Percentage	<b>571.23 %</b>

#### **Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 18.2 mm    Limit by Woolcock et al, 1999 Span/100 = 35.49 mm

#### **Reactions**

Maximum = 5.63 kn

#### **Intermediate Design Sides**

Intermediate Spacing = 2250 mm    Intermediate Span = 4225 mm    Try Intermediate 2x200x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =1.00    S1 Downward =11.27    S1 Upward =0.77

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

#### **Capacity Checks**

M <sub>Wind+Snow</sub>	3.46 Kn-m	Capacity	7.46 Kn-m	Passing Percentage	<b>215.61 %</b>
V <sub>0.9D-WnUp</sub>	3.28 Kn	Capacity	32.16 Kn	Passing Percentage	<b>980.49 %</b>

#### **Deflections**

Modulus of Elasticity = 5400 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 35.775 mm    Limit by Woolcock et al, 1999 Span/100 = 42.25 mm

### Reactions

Maximum = 3.28 kn

### Girt Design Front and Back

Girt's Spacing = 1300 mm

Girt's Span = 2300 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.88    S1 Downward =9.63    S1 Upward =15.40

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

M <sub>Wind+Snow</sub>	1.19 Kn-m	Capacity	1.86 Kn-m	Passing Percentage	<b>156.30 %</b>
V <sub>0.9D-WnUp</sub>	2.06 Kn	Capacity	12.06 Kn	Passing Percentage	<b>585.44 %</b>

### Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 6.94 mm    Limit by Woolcock et al, 1999 Span/100 = 23.00 mm

Sag during installation = 1.70 mm

### Reactions

Maximum = 2.06 kn

### Girt Design Sides

Girt's Spacing = 1300 mm

Girt's Span = 2250 mm

Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1    K4 =1    K5 =1    K8 Downward =1.00

K8 Upward =0.89    S1 Downward =9.63    S1 Upward =15.23

Shear Capacity of timber =3 MPa    Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

### Capacity Checks

Pole Shed App Ver 01 2022

M <sub>Wind+Snow</sub>	1.14 Kn-m	Capacity	1.87 Kn-m	Passing Percentage	<b>164.04 %</b>
V <sub>0.9D-WnUp</sub>	2.02 Kn	Capacity	12.06 Kn	Passing Percentage	<b>597.03 %</b>

**Deflections**

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 6.35 mm      Limit by Woolcock et al. 1999 Span/100 = 22.50 mm  
Sag during installation = 1.55 mm

**Reactions**

Maximum = 2.02 kn

**Uplift Check**

Density of Concrete = 24 Kn/m<sup>3</sup>

Density of Timber Pole = 5 Kn/m<sup>3</sup>

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

K<sub>s</sub> (Lateral Earth Pressure Coefficient) for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safety factor (0.55) x Density of Soil(18) x Height of Pile(1700) x K<sub>s</sub>(1.5) x 0.5 x tan(30) x  $\pi$  x Dia of Pile(0.6) x Height of Pile(1700)

Skin Friction = 23.34 Kn

Weight of Pile + Pile Skin Friction = 27.76 Kn

Uplift on one Pile = 22.25 Kn

Uplift is ok