Pole Shed App Ver 01 2022

Job No.: 511-5025142 **Address:** 3219 Arundel Rakaia Gorge Road, Cavendish, New Zealand **Date:** 18/09/2024

Latitude: -43.720174 **Longitude:** 171.387041 **Elevation:** 365.5 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N4	Ground Snow Load	1.68 KPa	Roof Snow Load	1.06 KPa
Earthquake Zone	2	Subsoil Category	D	Exposure Zone	B
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	6 m
Wind Region	NZ2	Terrain Category	2.09	Design Wind Speed	50.1 m/s
Wind Pressure	1.51 KPa	Lee Zone	YES	Ultimate Snow ARI	50 Years
Wind Category	extra High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono Enclosed

For roof Cp,i = -0.3

For roof CP,e from 0 m To 6.05 m Cpe = -0.9 pe = -1.22 KPa pnet = -1.22 KPa

For roof CP,e from 6.05 m To 12.10 m Cpe = -0.5 pe = -0.68 KPa pnet = -0.68 KPa

For wall Windward Cp,i = -0.3 side Wall Cp,i = -0.3

For wall Windward and Leeward CP,e from 0 m To 11.50 m Cpe = 0.7 pe = 0.95 KPa pnet = 1.40 KPa

For side wall CP,e from 0 m To 6.05 m Cpe = pe = -0.88 KPa pnet = -0.88 KPa

Maximum Upward pressure used in roof member Design = 1.22 KPa

Maximum Downward pressure used in roof member Design = 0.59 KPa

Maximum Wall pressure used in Design = 1.40 KPa

Maximum Racking pressure used in Design = 1.36 KPa

Design Summary

Purlin Design

Purlin Spacing = 700 mm Purlin Span = 5183 mm Try Purlin 240x45 SG8

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.94

K8 Upward =0.52 S1 Downward =13.82 S1 Upward =23.34

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	0.79 Kn-m	Capacity	2.73 Kn-m	Passing Percentage	**345.57 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	3.2 Kn-m	Capacity	3.64 Kn-m	Passing Percentage	**113.75 %**
$M_{0.9D-WnUp}$	-2.34 Kn-m	Capacity	-2.51 Kn-m	Passing Percentage	**107.26 %**

Second page

$V_{1.35D}$	0.61 Kn	Capacity	10.42 Kn	Passing Percentage	**1708.20 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	2.47 Kn	Capacity	13.89 Kn	Passing Percentage	**562.35 %**
$V_{0.9D-WnUp}$	-1.80 Kn	Capacity	-17.37 Kn	Passing Percentage	**965.00 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3 considering at least 4 members acting together

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 10.93 mm	Limit by Woolcock et al, 1999 Span/240 = 21.39 mm
Deflection under Dead and Service Wind = 14.48 mm	Limit by Woolcock et al, 1999 Span/100 = 51.33 mm

Reactions

Maximum downward =2.47 kn Maximum upward = -1.80 kn

Number of Blocking = 1 if 0 then no blocking required, if 1 then one midspan blocking required

Rafter Design External

External Rafter Load Width = 2666.5 mm External Rafter Span = 5743 mm Try Rafter 300x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K1 Medium term = 0.8 K1 Long term = 0.6 K4 =1 K5 =1 K8 Downward =0.88

K8 Upward =0.88 S1 Downward =15.50 S1 Upward =15.50

Shear Capacity of timber =5.3 MPa Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	3.71 Kn-m	Capacity	13.69 Kn-m	Passing Percentage	**369.00 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	14.95 Kn-m	Capacity	18.26 Kn-m	Passing Percentage	**122.14 %**
$M_{0.9D-WnUp}$	-10.94 Kn-m	Capacity	-22.82 Kn-m	Passing Percentage	**208.59 %**
$V_{1.35D}$	2.58 Kn	Capacity	23.01 Kn	Passing Percentage	**891.86 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	10.41 Kn	Capacity	30.68 Kn	Passing Percentage	**294.72 %**
$V_{0.9D-WnUp}$	-7.62 Kn	Capacity	-38.35 Kn	Passing Percentage	**503.28 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 10.22 mm	Limit by Woolcock et al, 1999 Span/240= 23.96 mm
Deflection under Dead and Service Wind = 13.55 mm	Limit by Woolcock et al, 1999 Span/100 = 57.50 mm

Reactions

Maximum downward =10.41 kn Maximum upward = -7.62 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 2

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 45 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Eccentric Load check

V = phi x k1 x k4 x k5 x fs x b x ds .... (Eq 4.12) = -40.07 kn > -7.62 Kn

Single Shear Capacity under short term loads = -14.56 Kn > -7.62 Kn

Girt Design Front and Back

Girt's Spacing = 1 mm Girt's Span = 2667 mm Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =1.00

K8 Upward =0.83 S1 Downward =9.63 S1 Upward =16.58

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	1.75 Kn-m	Passing Percentage	**Infinity %**
$V_{0.9D-WnUp}$	0.00 Kn	Capacity	12.06 Kn	Passing Percentage	**Infinity %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 0.02 mm Limit by Woolcock et al, 1999 Span/100 = 26.66 mm
Sag during installation = 3.07 mm

Reactions

Maximum = 0.00 kn

Girt Design Sides

Girt's Spacing = 0 mm Girt's Span = 2875 mm Try Girt SG8 Dry

Moisture Condition = Wet (Moisture in timber is less than 18% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1 K4 =1 K5 =1 K8 Downward =NaN

K8 Upward =NaN S1 Downward =NaN S1 Upward =NaN

Shear Capacity of timber =3 MPa Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.00 Kn-m	Capacity	NaN Kn-m	Passing Percentage	**NaN %**

$V_{0.9D\text{-}WnUp}$	0.00 Kn	Capacity	0.00 Kn	Passing Percentage	**NaN %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = NaN mm   Limit by Woolcock et al. 1999 Span/100 = 28.75 mm
Sag during installation =NaN mm

Reactions

Maximum = 0.00 kn

End Pole Design

Geometry For End Bay Pole

Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)	Dry Use	Height	5700 mm
Area	54091 mm2	As	40568.5546875 mm2
Ix	232952248 mm4	Zx	1774874 mm3
Iy	232952248 mm4	Zx	1774874 mm3
Lateral Restraint	mm c/c		

Loads

Total Area over Pole = 15.332375 m2

Dead	3.83 Kn	Live	3.83 Kn
Wind Down	9.05 Kn	Snow	16.25 Kn
Moment Wind	16.28 Kn-m	Moment snow	4.47 Kn-m
Phi	0.8	K8	0.59
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

Peeling	Steaming	Normal	Dry Use
fb =	36.3 MPa	fs =	2.96 MPa
fc =	18 MPa	fp =	7.2 MPa
ft =	22 MPa	E =	9257 MPa

Capacities

PhiNcx Wind	458.35 Kn	PhiMnx Wind	30.33 Kn-m	PhiVnx Wind	96.07 Kn
PhiNcx Dead	275.01 Kn	PhiMnx Dead	18.20 Kn-m	PhiVnx Dead	57.64 Kn
PhiNcx Snow	366.68 Kn	PhiMnx Snow	24.26 Kn-m	PhiVnx Snow	76.85 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.60 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.35 < 1 OK

Deflection at top under service lateral loads = 38.09 mm < 59.85 mm

Ds =	0.6 mm	Pile Diameter
L =	1700 mm	Pile embedment length
f1 =	4500 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Total Area over Pole = 15.332375 m2

Moment Wind =	16.28 Kn-m	Moment Snow =	4.47 Kn-m
Shear Wind =	3.62 Kn	Shear Snow =	4.47 Kn

Pile Properties

Safety Factory	0.55	
Hu =	7.06 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	18.47 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.88 < 1 OK

Drained Lateral Strength of End pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3	Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For End Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1700 mm	Pile embedment length
f1 =	4500 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	16.28 Kn-m	Moment Snow =	4.47 Kn-m
Shear Wind =	3.62 Kn	Shear Snow =	4.47 Kn

Pile Properties

Safety Factory	0.55	
Hu =	7.06 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	18.47 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.88 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(2000) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(2000)

Skin Friction = 32.31 Kn

Weight of Pile + Pile Skin Friction = 38.15 Kn

Uplift on one Pile = 30.51 Kn

Uplift is ok