Job No.: EHB 06 - 1   **Address:** 10 Kowhai Lane, Oban, New Zealand   **Date:** 24/01/2024

Latitude: -46.897257   **Longitude:** 168.122623   **Elevation:** 25 m

General Input

Roof Live Load	0.25 KPa	Roof Dead Load	0.25 KPa	Roof Live Point Load	1.1 Kn
Snow Zone	N5	Ground Snow Load	0.9 KPa	Roof Snow Load	0.63 KPa
Earthquake Zone	1	Subsoil Category	D	Exposure Zone	D
Importance Level	1	Ultimate wind & Earthquake ARI	100 Years	Max Height	3.9 m
Wind Region	NZ4	Terrain Category	3.0	Design Wind Speed	39.97 m/s
Wind Pressure	0.96 KPa	Lee Zone	NO	Ultimate Snow ARI	50 Years
Wind Category	High	Earthquake ARI	100		

Note: Wind lateral loads are governing over Earthquake loads, So only wind loads are considered in calculations

Pressure Coefficients and Pressues

Shed Type = Mono   Enclosed

For roof $C_{p,i}$ = -0.3

For roof C_{Pe} from 0 m To 3.30 m C_{pe} = -0.9   pe = -0.78 KPa   pnet = -0.78 KPa

For roof C_{Pe} from 3.30 m To 6.60 m C_{pe} = -0.5   pe = -0.43 KPa   pnet = -0.43 KPa

For wall Windward $C_{p,i}$ = -0.3   side Wall $C_{p,i}$ = -0.3

For wall Windward and Leeward C_{Pe} from 0 m To 8.50 m C_{pe} = 0.7   pe = 0.60 KPa   pnet = 0.89 KPa

For side wall C_{Pe} from 0 m To 3.30 m C_{pe} =   pe = -0.56 KPa   pnet = -0.56 KPa

Maximum Upward pressure used in roof member Design = 0.78 KPa

Maximum Downward pressure used in roof member Design = 0.45 KPa

Maximum Wall pressure used in Design = 0.89 KPa

Maximum Racking pressure used in Design = 1.03 KPa

Design Summary

Rafter Design Internal

Internal Rafter Load Width = 4500 mm   Internal Rafter Span = 8350 mm   Try Rafter 2x360x45 LVL13

Moisture Condition = Dry (Moisture in timber is less than 16% and timber does not remain in continuous wet condition after installation)

K1 Short term = 1   K1 Medium term = 0.8   K1 Long term = 0.6   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =1.00   S1 Downward =8.40   S1 Upward =8.40

Shear Capacity of timber =5.3 MPa   Bending Capacity of timber =48 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{1.35D}$	13.24 Kn-m	Capacity	43.44 Kn-m	Passing Percentage	**328.10 %**
$M_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	36.47 Kn-m	Capacity	57.92 Kn-m	Passing Percentage	**158.82 %**
$M_{0.9D-WnUp}$	-21.77 Kn-m	Capacity	-72.42 Kn-m	Passing Percentage	**332.66 %**

First Page

$V_{1.35D}$	6.34 Kn	Capacity	55.22 Kn	Passing Percentage	**870.98 %**
$V_{1.2D+1.5L\ 1.2D+Sn\ 1.2D+WnDn}$	17.47 Kn	Capacity	73.64 Kn	Passing Percentage	**421.52 %**
$V_{0.9D-WnUp}$	-10.43 Kn	Capacity	-92.04 Kn	Passing Percentage	**882.45 %**

Deflections

Modulus of Elasticity = 11000 MPa NZS3603 Amt 4, Table 2.3

k2 for Long Term Loads = 2

Deflection under Dead and Live Load = 21.455 mm   Limit by Woolcock et al, 1999 Span/240 = 35.42 mm

Deflection under Dead and Service Wind = 28.805 mm   Limit by Woolcock et al, 1999 Span/100 = 85.00 mm

Reactions

Maximum downward =17.47 kn   Maximum upward = -10.43 kn

Rafter to Pole Connection check

Bolt Size = M12 Number of Bolts = 3

Calculations as per NZS 3603:1993 Amend 2005 clause 4.4

Joint Group for Rafters =J2 Joint Group for Pole = J5

Minimum Bolt edge, end and spacing for Load perpendicular to grains = 60 mm

Factor of Safety = 0.7

For Perpendicular to grain loading

K11 = 12.6 fpj = 22.7 Mpa for Rafter with effective thickness = 90 mm

For Parallel to grain loading

K11 = 2.0 fcj = 36.1 Mpa for Pole with effective thickness = 100 mm

Capacity under short term loads = 43.67 Kn > -10.43 Kn

Girt Design Front and Back

Girt's Spacing = 1200 mm   Girt's Span = 2250 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.89   S1 Downward =9.63   S1 Upward =15.23

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	0.68 Kn-m	Capacity	1.87 Kn-m	Passing Percentage	**275.00 %**
$V_{0.9D-WnUp}$	1.20 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	**1005.00 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Second page

Deflection under Snow and Service Wind = 6.46 mm   Limit by Woolcock et al, 1999 Span/100 = 22.50 mm

Sag during installation = 1.55 mm

Reactions

Maximum = 1.20 kn

Girt Design Sides

Girt's Spacing = 600 mm   Girt's Span = 4250 mm   Try Girt 150x50 SG8 Dry

Moisture Condition = Dry (Moisture in timber is less than 16% and does not remain in continuous wet condition after installation)

K1 Short term = 1   K4 =1   K5 =1   K8 Downward =1.00

K8 Upward =0.91   S1 Downward =9.63   S1 Upward =14.80

Shear Capacity of timber =3 MPa   Bending Capacity of timber =14 MPa NZS3603 Amt 4, table 2.3

Capacity Checks

$M_{Wind+Snow}$	1.21 Kn-m	Capacity	1.91 Kn-m	Passing Percentage	**157.85 %**
$V_{0.9D-WnUp}$	1.13 Kn-m	Capacity	12.06 Kn-m	Passing Percentage	**1067.26 %**

Deflections

Modulus of Elasticity = 6700 MPa NZS3603 Amt 4, Table 2.3

Deflection under Snow and Service Wind = 41.12 mm   Limit by Woolcock et al. 1999 Span/100 = 42.50 mm

Sag during installation =19.78 mm

Reactions

Maximum = 1.13 kn

Middle Pole Design

Geometry

250 SED H5 (Minimum 275 dia. at Floor Level)		Dry Use	Height	3500 mm
Area		13125 mm2	As	9843.75 mm2
Ix		75366211 mm4	Zx	574219 mm3
Iy		75366211 mm4	Zx	574219 mm3
Lateral Restraint		3500 mm c/c		

Loads

Total Area over Pole = 19.125 m2

Dead	4.78 Kn	Live	4.78 Kn
Wind Down	8.61 Kn	Snow	12.05 Kn
Moment wind	13.19 Kn-m	Moment snow	3.94 Kn-m
Phi	0.8	K8	0.96
K1 snow	0.8	K1 Dead	0.6
K1wind	1		

Material

3/5

Peeling		Steaming		Normal		Dry Use
fb =		36.3 MPa		fs =		2.96 MPa
fc =		18 MPa		fp =		7.2 MPa
ft =		22 MPa		E =		9257 MPa

Capacities

PhiNcx Wind	180.53 Kn	PhiMnx Wind	15.93 Kn-m	PhiVnx Wind	23.31 Kn
PhiNcx Dead	108.32 Kn	PhiMnx Dead	9.56 Kn-m	PhiVnx Dead	13.99 Kn
PhiNcx Snow	144.42 Kn	PhiMnx Snow	12.74 Kn-m	PhiVnx Snow	18.65 Kn

Checks

(Mx/PhiMnx)+(N/phiNcx) = 0.96 < 1 OK

(Mx/PhiMnx)^2+(N/phiNcx) = 0.82 < 1 OK

Deflection at top under service lateral loads = 36.25 mm < 35.00 mm

Drained Lateral Strength of Middle pile in cohesionless soils Free Head short pile

Assumed Soil Properties

Gamma	18 Kn/m3		Friction angle	30 deg	Cohesion	0 Kn/m3
K0 =	(1-sin(30)) / (1+sin(30))				
Kp =	(1+sin(30)) / (1-sin(30))				

Geometry For Middle Bay Pole

Ds =	0.6 mm	Pile Diameter
L =	1600 mm	Pile embedment length
f1 =	2925 mm	Distance at which the shear force is applied
f2 =	0 mm	Distance of top soil at rest pressure

Loads

Moment Wind =	13.19 Kn-m	Moment Snow =	Kn-m
Shear Wind =	4.51 Kn	Shear Snow =	3.94 Kn

Pile Properties

Safety Factory	0.55	
Hu =	8.07 Kn	Ultimate Lateral Strength of the Pile, Short pile
Mu =	14.19 Kn-m	Ultimate Moment Capacity of Pile

Checks

Applied Forces/Capacities = 0.93 < 1 OK

Uplift Check

Density of Concrete = 24 Kn/m3

Density of Timber Pole = 5 Kn/m3

Due to cast in place pile, the surface interaction between soil and pile will be rough thus angle of friction between both is taken equal to soil angle of

internal friction

Ks (Lateral Earth Pressure Coefficient)for cast into place concrete piles = 1.5

Formula to calculate Skin Friction = Safecty factor (0.55) x Density of Soil(18) x Height of Pile(1600) x Ks(1.5) x 0.5 x tan(30) x Pi x Dia of Pile(0.6) x Height of Pile(1600)

Skin Friction = 20.68 Kn

Weight of Pile + Pile Skin Friction = 23.89 Kn

Uplift on one Pile = 10.61 Kn

Uplift is ok

Last Page